



Conservation

Environmental Stewardship Division
Environmental Assessment & Licensing Branch
123 Main Street, Suite 160
Winnipeg, Manitoba R3C 1A5
CANADA
www.gov.mb.ca/conservation/envapprovals

FAXED

File 2731.20

September 24, 2007

Mr. Hardy Hofer
Shady Lane Holding Co. Ltd.
Box 117
Treherne MB R0G 2V0

Dear Mr. Hofer:

Re: Shady Lane Colony Wastewater Treatment Lagoon – Environment Act Licence No. 2724

Receipt of the February 20, 2007, April 19, 2007 and August 13, 2007 letters from Genivar on behalf of the Shady Lane Holding Co. Ltd. is acknowledged as a notice of alteration in accordance with Section 14 of The Environment Act.

The requested changes to the Development as Licensed are:

1. To construct a new two-cell wastewater treatment lagoon approximately 100 metres from the existing lagoon and decommission the existing lagoon; and
2. To utilize the existing wastewater treatment lagoon as a crop irrigation storage pond once all wastewater and sludge are removed.

The potential environmental effects of the requested changes are considered to be a minor alteration in accordance with section 14(2) of The Environment Act. Accordingly, the requests as indicated in the February 20, 2007, April 19, 2007 and August 13, 2007 letters are approved subject to the limits, terms and conditions set forth in the attached revised Environment Act Licence 2724 R.

If you have any questions, please contact Jennifer Winsor at 945-7012.

Yours truly,

Tracey Braun, M.Sc.
Director
Environment Act

Attachment

cc: B. Gillespie, Regional Director – Central Region, Manitoba Conservation
Jason Bunn – Genivar (by fax)
Millennium Public Library/Mb. Eco-Network/Portage la Prairie City Library
R.M. of South Norfolk

NOTE: Confirmation of Receipt of this Licence No. 2724 R (*by the Licencee only*) is required by the Director of Environmental Assessment and Licensing. Please acknowledge receipt by signing in the space provided below and faxing a copy back to the Department by September 28, 2007.

On behalf of Shady Lane Holding Co. Ltd.

Date

****A COPY OF THE LICENCE MUST BE KEPT ON SITE AT THE DEVELOPMENT AT ALL TIMES****

LICENCE

Licence No. / Licence n° 2724 R

Issue Date / Date de délivrance May 29, 2006

REVISED : September 24, 2007

In accordance with The Environment Act (C.C.S.M. c. E125) /
Conformément à la Loi sur l'environnement (C.P.L.M. c. E125)

Pursuant to Section 11(1) and 14(2) / Conformément au Paragraphe 11(1) and 14(2)

THIS LICENCE IS ISSUED TO: / CETTE LICENCE EST DONNÉE À

SHADY LANE HOLDING COMPANY LIMITED; "the Licencee"

for the construction and operation of the Development being a wastewater collection system and wastewater treatment lagoon located in the north half of the southeast quarter of Section 5-9-9 WPM in the Rural Municipality of South Norfolk with discharge of treated effluent by irrigation onto agricultural land owned by the Licencee and in accordance with the Proposal filed under The Environment Act on December 12, 2005 and subsequent information supplied in letter dated March 20, 2006 and a Notice of Alteration submitted on February 20, 2007 with additional information submitted April 19, 2007 and August 13, 2007 and subject to the following specifications, limits, terms and conditions:

DEFINITIONS

In this Licence,

"**accredited laboratory**" means an analytical facility accredited by the Standard Council of Canada (SCC), or accredited by another accrediting agency recognized by Manitoba Conservation to be equivalent to the SCC, or be able to demonstrate, upon request, that it has the quality assurance/quality control (QA/QC) procedures in place equivalent to accreditation based on the international standard ISO/IEC 17025, or otherwise approved by the Director;

"**appurtenances**" means machinery, appliances, or auxiliary structures attached to a main structure to enable it to function, but not considered an integral part of it;

"**as constructed drawings**" means engineering drawings complete with all dimensions which indicate all features of the Development as it has actually been built;

****A COPY OF THE LICENCE MUST BE KEPT ON SITE AT THE DEVELOPMENT AT ALL TIMES****

"**ASTM**" means the American Society for Testing and Materials;

"**bentonite**" means specially formulated standard mill grade sodium bentonite conforming to American Petroleum Institute Specification 13-A;

"**cut-off**" means a vertical-side trench filled with compacted clay or a wall constructed from compacted clay;

"**Director**" means an employee so designated pursuant to The Environment Act;

"**effluent**" means treated wastewater flowing or pumped out of the wastewater treatment lagoon or sewage treatment plant;

"**Environment Officer**" means an employee so appointed pursuant to The Environment Act;

"**fecal coliform**" means aerobic and facultative, Gram-negative, nonspore-forming, rod-shaped bacteria capable of growth at 44.5°C, and associated with fecal matter of warm-blooded animals;

"**five-day biochemical oxygen demand**" means that part of the oxygen demand usually associated with biochemical oxidation of organic matter within five days at a temperature of 20°C;

"**flooding**" means the flowing of water onto lands, other than waterways, due to the overtopping of a waterway or waterways;

"**grab sample**" means a quantity of wastewater taken at a given place and time;

"**high water mark**" means the line on the interior surface of the primary and secondary cells which is normally reached when the cell is at the maximum allowable liquid level;

"**hydraulic conductivity**" means the quantity of water that will flow through a unit cross-sectional area of a porous material per unit of time under a hydraulic gradient of 1.0;

"**influent**" means water, wastewater, or other liquid flowing into a wastewater treatment facility;

"**in-situ**" means on the site;

"**livestock waste**" means manure from livestock;

"**low water mark**" means the line on the interior surface of the primary and secondary cells which is normally reached when the cell is discharged;

"**MPN Index**" means the most probable number of coliform organisms in a given volume of wastewater which, in accordance with statistical theory, would yield the observed test result with the greatest frequency;

"**primary cell**" means the first in a series of cells of the wastewater treatment lagoon system and which is the cell that receives the untreated wastewater;

"**riprap**" means small, broken stones or boulders placed compactly or irregularly on dykes or similar embankments for protection of earth surfaces against wave action or current;

"**secondary cell**" means a cell of the wastewater treatment lagoon system which is the cell that receives partially treated wastewater from the primary cell;

"**sewage**" means household wastewater that contains human waste;

"**sludge**" means accumulated solid material containing large amounts of entrained water, which has separated from wastewater during processing;

"**Sodium adsorption ratio**" means the dimensionless value where:

$$\text{SAR} = \frac{0.043 \times \text{Sodium concentration}}{\sqrt{(0.025) \text{ Calcium concentration} + (0.04) \text{ Magnesium concentration}}}$$

"**Standard Methods for the Examination of Water and Wastewater**" means the most recent edition of Standard Methods for the Examination of Water and Wastewater published jointly by the American Public Health Association, the American Waterworks Association and the Water Environment Federation;

"**total coliform**" means a group of aerobic and facultative anaerobic, Gram-negative, nonspore-forming, rod-shaped bacteria, that ferment lactose with gas and acid formation within 48 hours at 35°C, and inhabit predominantly the intestines of man or animals, but are occasionally found elsewhere and include the sub-group of fecal coliform bacteria;

"**wastewater**" means the spent or used water of a community or industry which contains dissolved and suspended matter; and

"**wastewater collection system**" means the sewer and pumping system used for the collection and conveyance of domestic, commercial and industrial wastewater; and

"**wastewater treatment lagoon**" means the component of this development which consists of an impoundment into which wastewater is discharged for storage and treatment by natural oxidation.

GENERAL TERMS AND CONDITIONS

This Section of the Licence contains requirements intended to provide guidance to the Licencee in implementing practices to ensure that the environment is maintained in such a manner as to sustain a high quality of life, including social and economic development, recreation and leisure for present and future Manitobans.

1. The Licencee shall direct all sewage generated within the farmsite toward the wastewater treatment lagoon or other approved sewage treatment facility.
2. The Licencee shall not direct livestock or agriculture related waste toward the wastewater treatment lagoon.
3. In addition to any of the limits, terms and conditions specified in this Licence, the Licencee shall, upon the request of the Director:
 - a) sample, monitor, analyze and/or investigate specific areas of concern regarding any segment, component or aspect of pollutant storage, containment, treatment, handling, disposal or emission systems, for such pollutants or ambient quality, aquatic toxicity, leachate characteristics and discharge or emission rates, for such duration and at such frequencies as may be specified;
 - b) determine the environmental impact associated with the release of any pollutant(s) from the Development; or
 - c) provide the Director, within such time as may be specified, with such reports, drawings, specifications, analytical data, descriptions of sampling and analytical procedures being used, bioassay data, flow rate measurements and such other information as may from time to time be requested.
4. The Licencee shall, unless otherwise specified in this Licence:
 - a) carry out all preservations and analyses on liquid samples in accordance with the methods prescribed in "Standard Methods for the Examination of Water and Wastewater" or in accordance with an equivalent analytical methodology approved by the Director;
 - b) have all analytical determinations undertaken by an accredited laboratory; and
 - c) report the results to the Director, in writing or in a format acceptable to the Director, within 60 days of the samples being taken.
5. The Licencee shall, in case of physical or mechanical breakdown of the wastewater collection and/or treatment system:
 - a) notify the Director immediately;
 - b) identify the repairs required to the wastewater collection and/or treatment system;
 - c) undertake all repairs to minimize unauthorized discharges of wastewater; and

- d) complete the repairs in accordance with any written instructions of the Director.
6. The Licencee shall, during construction and operation of the Development, report spills of fuels or other contaminants to an Environment Officer in accordance with the requirements of *Manitoba Regulation 439/87* respecting *Environmental Accident Reporting* or any future amendment thereof.

SPECIFICATIONS, LIMITS, TERMS AND CONDITIONS

7. The Licencee shall notify the assigned Environment Officer not less than two weeks prior to beginning construction of the Development. The notification shall include the intended starting date of construction and the name of the contractor responsible for construction.
8. The Licencee shall operate and maintain the wastewater treatment lagoon in such a manner that:
- a) the release of offensive odours is minimized;
 - b) the organic loading on the primary cell, as indicated by the five-day biochemical oxygen demand, is not in excess of 56 kilograms per hectare per day;
 - c) the depth of liquid in the primary cell or secondary cells does not exceed 1.5 meters; and
 - d) a 1.0 meter freeboard is maintained in primary and secondary cells.
9. The Licencee shall, prior to the construction of the wastewater treatment lagoon:
- a) remove all organic topsoil from the area where the dykes will be constructed; or
 - b) remove all organic material for a depth of 0.3 metres and a width of 3.0 metres from the area where the cut-off will be constructed.
10. The Licencee shall construct and maintain the wastewater treatment lagoon with a continuous liner, including cutoffs, under all interior surfaces of the cells in accordance with the following specifications:
- a) the liner shall be made of clay;
 - b) the liner shall be at least one metre in thickness;
 - c) the liner shall have a hydraulic conductivity of 1×10^{-7} centimetres per second or less at all locations; and
 - d) the liner shall be constructed to an elevation of 2.5 metres above the floor elevation of both the primary and the secondary cells.
11. The Licencee shall, if in the opinion of the Director, significant erosion of the interior surfaces of the dykes occurs, repair the dyke and install riprap as necessary. The riprap shall be placed on the interior dyke surfaces from 0.6 metres above the high water mark to at least 0.6 metres below the low water mark to protect the dykes from wave action.

12. The Licencee shall provide and maintain a grass cover on the dykes of the wastewater treatment lagoon and shall regulate the growth of the vegetation so that the height of the vegetation does not exceed 0.3 metres on all dykes.
13. The Licencee shall annually remove by mechanical methods all reeds, rushes and trees located above the low water mark in every cell of the wastewater treatment lagoon.
14. The Licencee shall implement an ongoing program to remove burrowing animals from the site of the wastewater treatment lagoon.
15. The Licencee shall notify the assigned Environment Officer not less than two weeks prior to discharge of effluent from the wastewater treatment lagoon.
16. The Licencee shall not discharge effluent from the wastewater treatment lagoon:
 - a) where the organic content of the effluent, as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;
 - b) where the fecal coliform content of the effluent, as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample;
 - c) where the total coliform content of the effluent, as indicated by the MPN index, is in excess of 1500 per 100 millilitres of sample;
 - d) between the 15th day of October of any year and the 15th day of May of the following year; and
 - e) when flooding from any cause is occurring on lands where effluent irrigation is to occur.
17. The Licencee shall:
 - a) dispose of all effluent by irrigation onto land owned by the Licencee;
 - b) only discharge effluent to irrigate:
 - (i) actively growing cereal, forage or oil seed crops;
 - (ii) grasslands which will not be utilized for grazing:
 - A. by dairy cattle for at least 30 days after effluent is applied; or
 - B. by livestock other than dairy cattle for at least 7 days after effluent is applied;
 - c) not harvest agriculture crops for at least 7 days after the crops are irrigated with effluent;
 - d) use any corn irrigated with effluent solely for making silage;
 - e) not apply effluent to particular lands for more than 10 continuous hours in every 24-hour period;
 - f) if ponding or surface runoff occurs during application, reduce the gross depth of effluent applied during any application of effluent so that ponding or surface runoff does not occur; and
 - g) if wind conditions cause the effluent to drift within the restricted zones outlined in Clause 18 of this Licence, stop the spray irrigation until the wind conditions subside.

18. The Licencee shall not discharge effluent, by spray irrigation:
 - a) within 300 metres of any dwelling not owned or lawfully controlled by the Licencee;
 - b) within 100 metres of any surface watercourse or groundwater well; or
 - c) within 100 metres of any adjoining property boundary.
19. The Licencee shall take necessary steps, approved by the Director, to reduce the Sodium Adsorption Ratio or concentrations of other constituents of effluent from the wastewater treatment lagoon to acceptable limits if the Director determines that effluent discharge is causing or contributing to deleterious impacts to the surrounding environment.
20. The Licencee shall install and maintain a fence with warning signs around the wastewater treatment lagoon and a locking gate to control access.

MONITORING AND REPORTING

21. The Licencee shall prior to each effluent discharge campaign obtain grab samples of the treated wastewater and have them analyzed for:
 - a) the organic content as indicated by the five day biochemical oxygen demand and expressed as milligrams per litre;
 - b) the fecal coliform content as indicated by the MPN index and expressed as MPN per 100 millilitres per sample; and
 - c) the total coliform content as indicated by the MPN index and expressed as MPN per 100 millilitres per sample.
22. The Licencee shall:
 - a) during each year maintain records of:
 - i) wastewater sample dates;
 - ii) original copies of laboratory analytical results of the sampled wastewater;
 - iii) effluent discharge dates;
 - b) make the records being maintained pursuant to sub-Clause 22 a) of this Licence available to an Environment Officer upon request; and
 - c) keep the maintained records of any one calendar year available for inspection for a period of three years following the respective calendar year in which they were recorded.
23. The Licencee shall prior to each effluent discharge campaign obtain samples of treated wastewater. The samples shall be preserved, analyzed and reported in accordance with the requirements of Clause 4 of this Licence, and shall be analyzed for:
 - a) total calcium;
 - b) total magnesium;
 - c) total sodium;
 - d) chloride; and

- e) resultant SAR value.
- 24. The Licencee shall submit to the Director for approval, within six months of the date of this Licence, a groundwater monitoring plan for the site of the Development to monitor for liner integrity, to be carried out as approved by the Director.
- 25. The Licencee shall arrange with the designated Environment Officer a mutually acceptable time and date for any required soil sampling between the 15th day of May and the 15th day of October of any year.
- 26. The Licencee shall take and test undisturbed soil samples, in accordance with Schedule "A" attached to this Licence, from the liner of the wastewater treatment lagoon; the number and location of samples and test methods to be specified by the designated Environment Officer up to a maximum of 30 samples.
- 27. The Licencee shall, not less than two weeks before the wastewater treatment lagoon is placed in operation, submit to the Director the results of the tests carried out pursuant to Clause 26 of this Licence.
- 28. The Licencee shall actively participate in any future watershed-based management study, plan and/or nutrient reduction program, approved by the Director, for the Assiniboine River and/or associated waterways and watersheds.
- 29. The Licencee shall:
 - a) prepare "as constructed drawings" for the Development and shall label the drawings "As Constructed"; and
 - b) provide to the Director, on or before 1st day of January 2009, two sets of "As Constructed drawings" of the wastewater treatment lagoon.

DECOMMISSIONING

- 30. The Licencee shall, after placing the Development into operation, prevent any additional wastewater from being discharged into the existing wastewater treatment lagoon.
- 31. The Licencee shall decommission the existing wastewater treatment lagoon located within one year of commencing operation of the Development.
- 32. The Licencee shall:
 - a) discharge treated effluent from the existing wastewater treatment lagoon in accordance with the wastewater treatment lagoon discharge requirements of Licence No. 1199;
 - b) dewater the sludge in the existing cells which will act as temporary dewatering cells;


- c) remove all the supernatant from the sludge and return the supernatant to the primary cell of the wastewater treatment lagoon, so that only sludge solids remain; and
 - d) dispose of the dewatered sludge in the new wastewater treatment lagoon once it is commissioned and approved for use.
33. The Licencee shall transport sludge solids in containers in such a manner as to prevent loss of sludge solids to the satisfaction of an Environment Officer.
34. The Licencee shall, for a period of three years following the decommissioning of the existing wastewater treatment lagoon:
- a) only discharge irrigation water stored in the lagoon cells to irrigate actively growing cereal, forage, or oil seed crops;
 - b) not harvest agriculture crops for at least 7 days after the crops are irrigated;
 - c) use any corn irrigated solely for making silage;
 - d) not apply irrigation water to particular lands for more than 10 continuous hours in every 24-hour period;
 - e) if ponding or surface runoff occurs during application, reduce the gross depth of irrigation water applied during any application so that ponding or surface runoff does not occur; and
 - f) if wind conditions cause the effluent to drift within the restricted zones outlined in Clause 18 of this Licence, stop the irrigation until the wind conditions subside.
35. The Licencee shall utilize the water stored in the decommissioned wastewater treatment lagoon for irrigation purposes only.

REVIEW AND REVOCATION

- A. This Licence replaces Licence No. 2724 which is hereby rescinded.
- B. Environment Act Licence No. 1199 is rescinded upon approved commissioning of the new wastewater treatment lagoon.
- C. If, in the opinion of the Director, the Licencee has exceeded or is exceeding or has or is failing to meet the specifications, limits, terms, or conditions set out in this Licence, the Director may, temporarily or permanently, revoke this Licence.
- D. If the Licencee has not commenced construction of the Development within three years of the date of this Licence, the Licence is revoked.

Shady Lane Holding Co. Ltd.
Licence No. 2724 R
Page 10 of 10

E. If, in the opinion of the Director, new evidence warrants a change in the specifications, limits, terms or conditions of this Licence, the Director may require the filing of a new proposal pursuant to Section 11 of The Environment Act.


Tracey Braun, M.Sc.
Director
Environment Act

Client File No.: 2731.20

Schedule "A" to Environment Act Licence No. 2724 R

Soil Sampling:

1. The Licencee shall provide a drilling rig, acceptable to the designated Environment Officer, to extract soil samples from the liner which is not placed or found at the surface of the lagoon structure. This includes all wastewater treatment lagoons constructed with clay cutoffs at the interior base of the dyke or with a clay cutoff in the centre of the dyke. The drill rig shall have the capacity to drill to the maximum depth of the clay cutoff plus an additional 2 metres. The drill rig shall be equipped with both standard and hollow stem augers. The minimum hole diameter shall be 5 inches.
2. For lagoon liners placed or found at the surface of the lagoon structure, the Licencee shall provide a machine, acceptable to the designated Environment Officer, capable of pressing a sampling tube into the liner in a straight line motion along the centre axis line of the sample tube and without sideways movement.
3. Soil samples shall be collected and shipped in accordance with ASTM Standard D 1587 (Standard Practice for Thin-Walled Tube Sampling of Soils), D 4220 (Standard Practice for Preserving and Transporting Soil Samples) and D 3550 (Standard Practice for Ring-Lines Barrel Sampling of Soils). Thin-walled tubes shall meet the stated requirements including length, inside clearance ratio and corrosion protection. An adequate venting area shall be provided through the sampling head.
4. At the time of sample collection, the designated Environment Officer shall advise the Licencee as to the soil testing method that must be used on each sample. The oedometer method may be used for a sample were the Environment Officer determines that the soil sample is taken from an undisturbed clay soil which has not been remoulded and which is homogeneous and unweathered. The triaxial test shall be used for all samples taken from disturbed and remoulded soils or from non-homogenous and weathered soils.
5. The Licencee shall provide a report on the collection of soil samples to the designated Environment Officer and to the laboratory technician which includes but is not limited to: a plot plan indicating sample location, depth or elevation of sample, length of advance of the sample tube length of soil sample contained in the tube after its advancement, the soil test method specified by the Environment Officer for each soil sample and all necessary instructions from the site engineer to the laboratory technician.
6. All drill and sample holes shall be sealed with bentonite pellets after the field drilling and sampling has been completed.

Soil Testing Methods:

1. Triaxial Test Method
 - a) The soil samples shall be tested for hydraulic conductivity using ASTM D 5084 (Standard Test Method for Measurement of Hydraulic Conductivity of Saturated Porous Materials Using a Flexible Wall Permeameter).
 - b) Soil specimens shall have a minimum diameter of 70 mm (2.75 inches) and a minimum height of 70 mm (2.75 inches). The soil specimens shall be selected from a section of the soil sample which contains the most porous material based on a visual inspection. The hydraulic gradient shall not exceed 30 during sample preparation and testing. Swelling of the soil specimen should be controlled to adjust for: the amount of compaction measured during sample collection and extraction from the tube and the depth or elevation of the sample. The effective stress used during saturation or consolidation of the sample shall not exceed 40 kPa (5.7 psi) or the specific stress level, that is expected in the field location were the sample was taken, which ever is greater.
 - c) The complete laboratory report, as outlined in ASTM D 5084, shall be supplied for each soil sample collected in the field.

2. Oedometer Test Method
 - a) The soil samples shall be tested for hydraulic conductivity using ASTM D 2435 (Standard Test Method for One-Dimensional Consolidation Properties of Soils).
 - b) Soil specimens shall have a minimum diameter of 50 mm (2 inches) and a minimum height of 20 mm (0.8 inches). The soil specimens shall be selected from a section of the soil sample which contains the most porous material based on a visual inspection. The soil specimen shall be taken from an undisturbed soil sample. The soil specimen shall be completely saturated.
 - c) The complete laboratory report, as outlined in ASTM D 2435, shall be supplied for each soil sample collected in the field.