

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION

UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and the BARICKMAN COLONY, Applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, Mr. Michael Hofer, on behalf of the Barickman Colony, filed a proposal with the Department of Mines, Resources and Environmental Management in connection with the operation of a sewage lagoon system located on part of Lot 77 Baie St. Paul in the Rural Municipality of Cartier, Manitoba, with discharge of treated effluent to cropland for irrigation purposes;

AND WHEREAS in the absence of limits being prescribed by a Regulation under the said Act, the said application was referred to The Clean Environment Commission for the prescribing of limits;

AND WHEREAS a representation was made to the said Commission by persons who are, or who are likely to be, affected by an Order of the Commission prescribing limits in connection with the said operation;

AND WHEREAS the said Commission held a public hearing on the 2nd day of February, 1976, in the City of Winnipeg, Manitoba;

AND WHEREAS The Clean Environment Commission considered the application on the 9th day of February, 1976;

IT IS HEREBY ORDERED THAT

1. The Applicant shall ensure that all the facilities for the treatment of sewage and the holding of effluent are so constructed, maintained and operated as to:
 - (a) prevent the contamination of groundwater; and
 - (b) minimize the release of offensive odours.
2. The Applicant shall ensure that the biochemical oxygen demand (5-day BOD) loading on the primary cell of the said lagoon system does not exceed 50 pounds per acre per day.
3. The Applicant shall ensure that the quality of the effluent from the said sewage lagoon system is such that:

*assigned to S.P.C.
76 02 24
CBO/ci*

Cont'd . . .

- 3. (a) the biochemical oxygen demand (5-day BOD) does not exceed 30 milligrams per litre; and
 (b) the total coliform content as indicated by the MPN Index does not exceed 1500 per 100 millilitres of sample.
- 4. The Applicant shall ensure that effluent is discharged subject to Clause 6, only onto land owned or lawfully controlled by the said Colony; and then only with due regard to the type of crop or usage of said lands so as to minimize the danger to health.
- 5. The Applicant shall ensure that effluent is not discharged within one thousand feet of any residence which is off the property owned or lawfully controlled by the said Colony.
- 6. The Applicant shall ensure that no discharge of effluent from the said sewage lagoon system takes place during the period between the 1st day of November in any year and the 15th day of May in the year following.
- 7. The Applicant shall ensure that no livestock wastes are deposited in the said sewage lagoon system.


IT IS HEREBY FURTHER ORDERED THAT

- 8. Subject to Clause 6, the Applicant shall give at least 14 days notice of intention to discharge effluent from the said sewage lagoon system to the Environmental Management Division of the said Department.

Order No. 533

Dated at the City of Winnipeg

this 19 day of FEBRUARY, 1976.



 Chairman,
 The Clean Environment Commission.