

360 Portage Ave (17) • Winnipeg Manitoba Canada • R3C 0G8 Telephone / Nº de téléphone : 204-360-4773 • Fax / Nº de télécopieur : 204-360-6138 dbowen@hydro.mb.ca

2018 10 09

Siobhan Burland Ross A/Director - Environmental Approvals Branch Manitoba Sustainable Development 1007 Century Street Winnipeg, MB R3H 0W4

Dear Ms. Burland Ross:

RE: KEEYASK GENERATION PROJECT – NOTICE OF ALTERATION, SHORT TERM RELEASE OF SEEPAGE WATER WITH ELEVATED TSS AT THE SOUTH DAM COFFERDAM ENVIRONMENT ACT LICENCE NO. 3107, CLIENT FILE 5550.00

Manitoba Hydro, in its delegated authority to manage construction of the Keeyask Generation Project on behalf of the Keeyask Hydropower Limited Partnership, is submitting a notice of alteration to Environment Act Licence (EAL) No. 3107 to temporarily release seepage water from the South Dam Cofferdam (SDCD) directly to the Nelson River, when the end-of-pipe Total Suspended Solids (TSS) concentration is greater than 50 mg/L. The duration of this request is until repairs to the upstream South Dam Cofferdam have been completed, which are anticipated to be completed by the middle of November 2018.

Dewatering of the South Dam Cofferdams started on September 16, 2018. After the fish rescue was completed on September 26, it became apparent that the foundation of the upstream SDCD was experiencing seepage at a rate higher than designed. This appears to be attributed to unforeseen geological conditions and/or alluvial deposits along the river bed.

The seepage is currently being managed with diesel pumps but will be difficult to maintain in the winter months and during construction of the South Dam. Steps are being taken to reduce the flows. A repair option was developed and should be executed before continuous freezing conditions occur. Based on past experience, it is likely that the end of pipe TSS concentration will increase above 50 mg/L during execution of cofferdam seepage repairs with short term spikes up to 1000 mg/L. To reduce the risk of schedule delays, a notice of alteration to EAL No. 3107 is being submitted to temporarily release impounded water from within the South Dam Cofferdams directly to the Nelson River in the Spillway Channel, even if TSS is greater than 50 mg/L.

Siobhan Burland Ross 2018 10 09 Page 2

Please refer to the attached description for details. If additional information is required, please contact Jodine MacDuff at 204-360-5539.

Yours truly,

Jane 120 1

Dave Bowen, P. Eng, M.Sc Director, Keeyask Project Generation & Wholesale

Att.



Client File No.: 5500.00	nvironment Act Licence No. : 3107	
Legal name of the Licencee: Keeyask Hydro	ppower Limited Partnership	
Name of the development: Keeyask Gene	eration Project	
Category and Type of development per Classes	of Development Regulation:	
Energy Production and Waste Conversion	Electrical generating facilities >100 MW	
Phone Number: (204) 360-4773 Fax:	Avenue, 17th Floor ovince: Manitoba Postal Code: R3C 0G8 Email: dbowen@hydro.mb.ca es of the environmental assessment (e.g. consultant):	
Phone: (204) 360-5539 M	ailing address: 360 Portage Avenue, 17th Floor /innipeg, MB R3C 0G8	
Email address: jmacduff@hydro.mb.ca		
Short Description of Alteration (max 90 charact	ters):	
Short release of seepage water from the So	uth Dam Cofferdam with elevated TSS.	
Alteration fee attached: Yes: No:	\checkmark	
If No, please explain: As per previous discuss	sions with Darrell Ouimet.	
Date: 10/09/2018	Dave i Don	
Printed na	Printed name: Dave Bowen	
 A complete Notice of Alteration (NoA) consists of the following components: ✓ Cover letter ✓ Notice of Alteration Form ✓ 4 hard copies and 1 electronic copy of the NOA detailed report (see "Informatic Bulletin - Alteration to Developments with Environment Act Licences") ✓ \$500 Application fee, if applicable (C payable to the Minister of Finance) 	For more information: Phone: (204) 945-8321	

Keeyask Generation Project Notice of Alteration - Environment Act Licence No. 3107 Short Term Release of Seepage Water with Elevated Total Suspended Solids at the South Dam Cofferdam

Manitoba Hydro, in its delegated authority to manage construction of the Keeyask Generation Project on behalf of the Keeyask Hydropower Limited Partnership, is requesting an alteration to Environment Act Licence (EAL) No. 3107 to temporarily release seepage water from the South Dam Cofferdam (SDCD) directly to the Nelson River, when the end-of-pipe Total Suspended Solids (TSS) concentration is greater than 50 mg/L. The duration of this request is until repairs to the upstream South Dam Cofferdam have been completed, which are anticipated to be completed by the middle of November 2018.

Background

The Keeyask Generation Project Environmental Protection Plan (EnvPP), section 7.21.2 #5, states:

Impounded water will be tested for total suspended solids (TSS) before release. If TSS concentration is < 25 mg/L, the water can be released directly to the Nelson River. If the water does not meet these criteria, it will be treated prior to release.

In July 2017, approval was received to add the following clause to the EnvPP:

At designated discharge locations, as shown in Figures 1 and 2, impounded water with total suspended solids (TSS) concentration up to 50 mg/L can be discharged directly to the Nelson River. When TSS concentrations exceed 25 mg/L, water discharge volumes along with corresponding TSS concentrations will be recorded and included in the annual Environmental Protection Plan report.

The Keeyask Generation Project South Dam will be located in the south channel of the Nelson River, Figure 1 and construction will occur in the summer of 2019. To prepare for this, excavation; surface/foundation preparations and installation of the grout curtain will occur in the fall/winter of 2018/2019 and must be conducted in the dry; therefore, the South Dam cofferdam needs to have a wellmanaged seepage plan.

Dewatering of the South Dam Cofferdams started on September 16. After the fish rescue was completed on September 26, it became apparent that the foundation of the upstream SDCD was experiencing seepage at a rate higher than designed at approximately 500 L/s (0.5 cms or 8,000 USgpm). This appears to be attributed to unforeseen geological conditions and/or alluvial deposits along the river bed. Although a cleaning operation was completed on the toe of the upstream SDCD to remove alluvial deposits on the river bed, it appears there is a bedrock low which was beyond the reach of the

Keeyask Generation Project Short Term Release of Seepage Water with Elevated TSS at the SDCD

equipment used for cleaning.

The seepage is currently being managed with diesel pumps but will be difficult to maintain in the winter months and during construction of the South Dam, therefore steps are being taken to reduce the flows. As well, removal of unclassified material within the footprint of the upstream and downstream SDCDs would increase the seepage rate to levels that could become unmanageable. A repair option has been developed for the northwest corner of the upstream SDCD and should be executed before continuous freezing conditions occur. During the first week of October 2018, the day temperatures at the Keeyask site have been below 5°C and overnight temperatures have been between -5 to 0°C.

Based on past experience, it is likely that the end of pipe TSS concentration will increase above 50 mg/L during execution of cofferdam seepage repairs with short term spikes up to 1000 mg/L. At the current seepage rates it is not feasible or practical to pump or transport the water by truck to the settling pond. Diverting this water to settling ponds for treatment would require running heated lines across the currently flowing spillway for a distance of 3.0 km to an existing settling pond north of the tailrace channel or running a heated line for a distance of at least 3.7 km south to the borrow site S2a. Therefore to meet the TSS concentration limits as stated in the EnvPP, pumping of the seepage water would need to be suspended until sediments settle. This could result in flooding of the South Dam footprint which would delay the South Dam foundation excavation and curtain grouting activities. There is also a risk that if pumping of seepage water is stopped due to high TSS levels that the downstream SDCD would be overtopped. The crest of the downstream SDCD is at elevation 145.6 m, the crest of the upstream SDCD is 152.2 m and current upstream water level is approximately 148 m. With the upstream water level approximately 2.4 m above the crest of the downstream SDCD the risk of uncontrolled overtopping of the cofferdam exists and needs to be avoided. A delay due to flooding in the South Dam channel would jeopardize activities scheduled for both the winter of 2018/2019 and summer of 2019.

To reduce the risk of schedule delays, an alteration to EAL No. 3107 is requested to temporarily release impounded water from within the South Dam Cofferdams directly to the Nelson River in the Spillway Channel, even if TSS is greater than 50 mg/L.

Description of Construction of South Dam Cofferdam Repair

Construction activities to decrease the seepage of the upstream SDCD includes constructing a rock groin upstream of the current upstream SDCD, widening the existing key-in to the Spillway Cofferdam and placing additional impervious material between the existing upstream SDCD and the proposed rock groin, Figures 2a and 2b. All this work will be within the footprint identified in the Notice of Alteration to Environment Act Licence which was approved on August 9, 2018.

Potential Environmental Effects

Repairs to the upstream SDCD will involve the placement of impervious material (clayey silt - Class A)

Keeyask Generation Project Short Term Release of Seepage Water with Elevated TSS at the SDCD which will be sourced from one of the current borrow sources, most likely from S2a located 3.5 km south of this site, Figure 3. Currently, cofferdam seepage water is "clean" and the TSS concentration is similar to the levels in the Nelson River. During the repair, it is anticipated that the material that is being placed will be suspended in the seepage water. Based on past experience, it is likely that the end of pipe TSS concentration will increase above 50 mg/L during execution of cofferdam seepage repairs with short term spikes up to 1000 mg/L. It is proposed to discharge this water directly to the Nelson River in the Spillway channel.

To determine potential effects of discharging water with elevated TSS, sediment plume modeling was conducted with a TSS concentration of 2,000 mg/L at a rate of 600 L/s (9,500 USgpm), which produces a sediment loading rate of 1.2 kg/s. Previous analyses investigated the same loading rate at the spillway for a flow of 3,500 cms in the Nelson River. The modeled sediment plume (Figure 4) showed in stream TSS increases of >5 mg/L were confined to a highly localized area at the point of discharge while the plume of TSS increase from 1-5 mg/L did not extend beyond the end of the discharge channel. Although the current river flow of about 2,700 cms is lower than the 3,500 cms used in the model, it can be expected that TSS increases >5 mg/L would similarly remain confined to a highly localized area near the point of discharge due to rapid mixing in the turbulent flow of the discharge channel. The area with TSS increases of 1-5 mg/L would likely affect a similarly narrow part of the flow but extending somewhat further downstream within the area of high flow velocities and turbulent conditions. River flows were projected to increase to about 3,300 cms (50th percentile estimate) by mid-November, bringing flow conditions closer to those represented in Figure 4.

Based on the models, the increase in TSS concentration will not be greater than 5 mg/L above background downstream of the Spillway Discharge Channel. Releasing seepage water with elevated TSS in the Spillway channel is expected to have negligible effects to fish.

Monitoring and Reporting

Monitoring TSS will continue to be performed by Manitoba Hydro Environmental Inspectors and the Contractor's environmental and water management team. A summary of the volume of water pumped and the TSS concentrations will be submitted to the Environment Officer, Environmental Approvals Branch once the repairs are complete.


The sampling location is at the pump station, these are sampled at least twice per day. Real-time monitoring of TSS cannot occur, therefore the relationship between turbidity and TSS that is provided in the *Sediment Management Plan for In-stream Construction* will be utilized which is:

TSS (mg/L) = 0.79 Tu (NTU) - 2.86

It should be noted that the SMP stations have been removed for the shoulder season, therefore monitoring SMP downstream at SMP 2 and 3 will not be possible.

Summary of Potential Effects


Model results for a moderate river flow showed that the sediment load from dewatering has a negligible, highly localized effect on in-stream TSS even if the end-of-pipe limit is increased to 2000 mg/L. The source of the sediment load will be from raw impervious material that is sourced within the project site. The effects on downstream sedimentation would not be measurable.




1.0

Figure 1

Satellite Imagery - August 19th, 2018








STEP #	DESCRIPTION
STEP 1	CONTRUCT PARTIAL ROCK GROI
STEP 2	CLEAN DS RIVER BOTTOM FROM PARTIAL CONT
STEP 3	EXCAVATE SWCD FOR TIE-IN
STEP 4	FILL TIE-IN EXCAVATION WITH CLA
STEP 5	PARTIAL INFILL BETWEEN CONTAINMENT GR
STEP 6	CONSTRUCT REMAINING CONTAINMEN
STEP 7	CLEAN DS RIVER BOTTOM FROM PARTIAL I
STEP 8	INFILL REMAINING AREA BETWEEN CONTAINMEN


1 - START (0+000): 2 - PVI (RADIUS 30m): 3 - END (0+239):

SPILLWAY COFFERDAM AND THE UPSTREAM SADDLE DAM.











ATA SOURCE:
Anitoba Hydro; Government of Manitoba; Government of Canada; K
cres; Manitoba Hydro 1999 1m Black & White DOI

CREATED BY: Manitoba Hydro - Hydro Power Planning - GIS & Special Studies

OORDIN	ate system: UTM NAD 1	983 Z15N	date created: 09-FEB-12	REVISION DATE: 20-JUN-13
	1	2 Kilometres	VERSION NO:	QA/QC:
	0.85	1.7 Miles	3.0	JCL/MES/ZZZ

Legend	
--------	--

terial	Soi	irce

Granular Borrow

Rock Quarry

- Proposed Access Road
- Impervious Borrow /// Keeyask Principal Structures
 - Initial Flooded Area (159 m)

Figure 3



KEEYASK	CREATED BY: Water Resources Engineering - Hydraulic Engineering			
	coordinate system: UTM NAD 1983 Z15N		on date: CT-18	
	0 0.55 1.1 Kilometres	VERSION NO: QA/QC 1.0 XXX	: YYY/ZZZ	

Legend TSS Increase (mg/l >200 100 - 200 25 - 100 5 - 25 1 - 5

Nelson River Flow = 3500cms Stephens Lake Water Level = 141m South Dam Coffer Dam pumping: 600 I/s @ TSS = 2000 mg/l Routine seepage pumping at other locations: TSS = 50mg/l **Keeyask GS** Analysis of Pumping Discharge with High TSS from the South Dam Cofferdam

