



## Sustainable Development

Environmental Stewardship Division

Environmental Approvals Branch

123 Main Street, Suite 160 (Box 80), Winnipeg, Manitoba, Canada R3C 1A5

T 204 945-8321 F 204 945-5229

[www.gov.mb.ca/conservation/eal](http://www.gov.mb.ca/conservation/eal)

**Client File No. 56.30**

October 18, 2016

Joe Richardson  
Public Works Manager  
Town of Carman  
Box 160  
Carman, MB R0G 0J0  
[info@townofcarman.com](mailto:info@townofcarman.com)

Dear Mr. Richardson:

**Re: Notice of Alteration the Town of Carman wastewater treatment lagoon -  
Environment Act Licence No. 2399**

Your letter received September 08, 2016 is hereby acknowledged as a Notice of Alteration (NofA) in accordance with Section 14 of *The Environment Act*. In your letter you requested an alteration to the Town of Carman wastewater treatment lagoon to replace the existing three inter-cell piping and isolation valves with new pipes and isolation valves.

Upon review of the NofA I have decided that the environmental impacts of the proposed alteration are insignificant and, pursuant to Section 14(2) of *The Environment Act*, the proposed alteration is approved subject to the following conditions:

1. The construction and commissioning associated with this NofA is to be completed on or before November 30, 2016.
2. HDPE or PVC pipes as well as stainless steel pipe may be used. The location of the new inter-cell pipes should not be more than 600 mm off the cell floor.

If you have any questions or would like to discuss these items, please contact Barsha Sagan, Environmental Engineer, at (204) 945- 5234.

Yours sincerely,

Tracey Braun, M.Sc.  
Director

cc: Don Labossiere/Donna Smiley/Tyler Kneeshaw, Environmental Compliance and Enforcement  
Branch, Manitoba Sustainable Development  
Public Registry