

Sewage Ejector System Decommissioning

The following procedure can be used to decommission a sewage ejector system.

Remove the sewage ejector standpipe. Plug the poly pipe with an insert plug and gear clamp. Landscape the area if required.

It is not necessary to remove or sever the poly pipe leading to the ejector if it is your intent to use this piping in conjunction with the construction of a new disposal field or alternative system. If you are not planning to use the piping for the installation of the new disposal field, the line should be severed at the septic tank outlet.

Providing the existing septic tank is in good working condition the septic tank can be used in conjunction with the construction of the new disposal field or alternative system.

If you plan to remove the septic tank, follow the decommissioning procedures as outlined in Guideline 2009-01E.

Guidelines can be found on the Manitoba Conservation website:

<http://www.gov.mb.ca/conservation/envprograms/wastewater/information/index.html>