



SAFE WORK



ME-019
August 2009

Special BH ULC S636 Venting Installation Requirements

The purpose of this bulletin is to provide further clarification and guidance on the process of installing BH ULC S636 venting in Manitoba.

Specifically, according to the requirements of the Chief Inspector, Mechanical and Engineering Branch, Manitoba Labour and Immigration, **the primer must be used on all pipe and fittings** regardless of the temperature at the time of pipe installation (contact your local supplier or the manufacture for the correct procedure).



Ensure all foreign material, dirt, labeling etc. is removed before assembling mating surface(s).