## COPY

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION

UNDER THE CLEAN ENVIRONMENT ACT

- RE: THE CLEAN ENVIRONMENT COMMISSION and FRONTIER SCHOOL DIVISION #48, Applicant,
- WHEREAS pursuant to the provisions of The Clean Environment Act, Frontier School Division #48 filed a registration with the department in connection with the operation of a sewage treatment plant located in Parcels 1 and 3, Plan No. 11379 WLTO serving the Wanipigow School with discharge of effluent to Lake Winnipeg;

AND WHEREAS in the absence of limits, terms and conditions prescribed by a regulation under the said Act, the registration was referred to The Clean Environment Commission to prescribe limits, terms and conditions:

- AND WHEREAS after giving notice of its intention to issue an order prescribing limits, terms and conditions concerning the registration, the Commission did not receive notice of representation from any person who was likely to be affected;
- AND WHEREAS the Commission considered the registration on the 16th day of March, 1988;

IT IS HEREBY ORDERED THAT

- 1. The Applicant shall operate and maintain the said sewage treatment plant in such a manner that the release of offensive odours is minimized.
- 2. The Applicant shall not release effluent from the said sewage treatment plant where:
  - (a) the organic content of the effluent, as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;

Continued

2 - FRONTIER SCHOOL DIVISION NO. 48 WANIPIGOW SCHOOL

- 2. (b) the total suspended matter content of the effluent, as indicated by the non-filterable residue is in excess of 30 milligrams per litre;
  - (c) the total coliform content of the effluent, as indicated by the MPN index, is in excess of 1500 per 100 millilitres of sample;
  - (d) the fecal coliform content of the effluent, as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample.
- 3. The Applicant shall
  - (a) measure the residual chlorine content of the effluent from the said sewage treatment plant;
  - (b) record the measured residual chlorine content, and
  - (c) submit the measurement data to the Environmental Management Division in a manner satisfactory to the Division.
- 4. The Applicant shall dispose of waste sludge produced by the sewage treatment plant in a manner satisfactory to the Environmental Management Division.

Order No. 1173

Dated at the City of Winnipeg

this 22th day of March 1988.

Chairperson, The Clean Environment Commission.

File: 2580.0