Environment Act Licence Loi sur l'environnement Licence



Licence No./Licence nº____

1498 RR

Issue Date/Date de délivrance August 22, 1991

Revised: July 11, 1995

July 28, 2003

IN ACCORDANCE WITH THE ENVIRONMENT ACT (C.C.S.M. c. E125) THIS LICENCE IS ISSUED TO:

GERDAU AMERISTEEL MRM SPECIAL SECTIONS INC.: APPLICANT

The following limits, terms, and conditions shall be complied with in connection with the operation of a Steel Mill located at or near River Lot 22 in the Parish of St. Clements in the Rural Municipality of St. Andrews, in the Province of Manitoba:

- The Applicant shall not cause or permit the emission of particulate matter from any point of emission of the operation in excess of 0.23 grams per dry standard cubic metre calculated at 25 degrees Celsius and 760 millimetres of mercury, corrected to 12 percent carbon dioxide for processes involving combustion.
- 2. The Applicant shall not cause or permit visible emissions from any point of emission of the operation that exhibit an opacity equal to or greater than:
 - 20 percent for a period of more than 4 minutes in the aggregate in any one (a) hour:
 - 40 percent at any time.
- 3. The Applicant shall limit the emission of particulate matter from the operation to such an extent that airborne particulate matter from any part or process of the operation does not at any time exhibit an opacity greater than 5 percent at any point beyond the property line of the operation.
- 4. The Applicant shall ensure that all particulate matter collected from the air pollution control equipment, and all slag collected from the melting furnaces are disposed of in a manner acceptable to the Director.
- The Applicant shall, at the request of the Director, ensure that adequate stack sampling facilities are installed in a manner satisfactory to the Director; the facilities shall include proper sampling ports, safe sampling platforms, safe access to the sampling platforms, access to electrical power to operate sampling equipment and such additional sampling facilities as are requested by the Director.

Gerdau Ameristeel MRM Special Sections Inc. Licence No. 1498 RR Page 2 of 2

- 6. The Applicant shall at the request of the Director:
 - (a) conduct emission testing for the emissions referred to in Clause 1 of this Licence within 60 days of the Director's request and in a manner satisfactory to the Director; and,
 - (b) submit a report containing the emission testing data and all other related data to the Director within 90 days after completion of the emission testing.
- 7. The Applicant shall at all times maintain a high standard of equipment maintenance and good housekeeping practices consistent with meeting the limits, terms and conditions prescribed by this Licence.
- 8. Licence No. 1498 R is hereby rescinded.

Larry Strachan, P. Eng.

Director

Environment Act

Client File No.: 1252.20