AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION

UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and MR. MICHAEL D. SKORONSKI, Applicant,

WHEREAS

pursuant to the provisions of The Clean Environment Act, Mr. Michael D. Skoronski, submitted an application to The Clean Environment Commission in connection with the operation of a sewage lagoon system located in part of Section 24-60-27 in the Local Government District of Consol, Manitoba, with discharge of effluent to a swamp, with eventual drainage to Little Atik Lake;

AND WHEREAS

a representation was made to the said Commission by a person who is, or is likely to be affected by an Order of the Commission setting limits in connection with the said operation;

AND WHEREAS

the said Commission held a public hearing on the 14th day of April, 1975, in the Board Room of the Provincial Building on Third Street in The Pas, Manitoba;

AND WHEREAS

the said Commission considered the said application on the 28th day of April, 1975;

IT IS HEREBY ORDERED THAT

- 1. The Applicant shall ensure that the said sewage lagoon system is so constructed, maintained and operated as to:
 - (a) prevent the contamination of groundwater; and
 - (b) minimize the release of offensive odours.

parent to water spentials

C-6-897

2

- 3. The Applicant shall ensure that the quality of the effluent from the said sewage lagoon system is such that:
 - (a) the total coliform content, as indicated by the MPN index, does not exceed 1500 per 100 millilitres of sample; and
 - (b) the biochemical oxygen demand (5-day BOD) does not exceed 30 milligrams per litre.
- 4. The Applicant shall ensure that no discharge of effluent from the said sewage lagoon system takes place between the first day of November, in any year, and the fifteenth day of May, of the following year.

Order No. <u>45/</u>

Dated at the City of Winnipeg

this 14th day of May, 1975.

Chairman,

Clean Environment Commission

С-b-897