AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and THE MANITOBA WATER SERVICES BOARD, Applicant,

WHEREAS

pursuant to the provisions of The Clean Environment Act, The Manitoba Water Services Board filed a proposal with the Department in connection with the operation of an expanded sewage lagoon system located in the SW4 of Section 35, Township 13, Range 1 EPM in the Rural Municipality of Rockwood serving the Town of Stonewall, Manitoba, with discharge of effluent to Grassmere Drain;

AND WHEREAS

in the absence of limits being prescribed by a Revalation under the said Act, the said proposal was referred to The Clean Environment Commission for the prescribe g or limits:

AND WHEREAS

no representations were made to the Commission by any reson who is or who is likely to be affected by a color of the Commission prescribing limits in connection of the the said operation;

AND WHEREAS

the Commission considered the propsal on the 25th day of February, 1980.

IT IS HEREBY ORDERED THAT

- 1. The Applicant shall not permit the hydraulic conductivity of the interior of the said sewage lagoon system to exceed 10⁻⁷ continete a per second over the entire lagoon.
- 2. The Applicant shall not permit the organic loading on the cell of the said sew to lagoon system designated as Cell No. 2 Appendix "A" to this order to exceed 56 kilograms per lecture permit in terms of five-day biochemical oxygen depend.

The Applicant shall not permit the discharge of effluent from the discharge of effluent sewage lagoon system between the 1st day of November of each year and the 15th day of May of the following year.

Applicant shall not permit the discharge of effluent from the said sewage lagoon system where the organic content of the effluent is, as indicated by five-day biochemical oxygen demand, in excess of 30 milligrams per liter.

5. The Applicant shall not permit the discharge of effluent from the said sewage lagoon system where the fecal coliform content of the said effluent is, as indicated by the MPN index, in excess of 200 per 100 milliliters of sample.

Order No. 872

Dated at the City of Winnipeg, this 29th day of February , 1980.

Charman Commission.

File: 204.3

RESCINITION