



Sustainable Development

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/sd/eal

Client File No. 1069.10

January 8, 2018

Mr. Chris Carroll, P.Eng., MBA
Manager of Wastewater Services Division
City of Winnipeg
110-1199 Pacific Avenue
Winnipeg, MB R3E 3S8

Dear Mr. Carroll:

Re: Notice of Alteration - City of Winnipeg South End Water Pollution Control Centre (SEWPCC) - Environment Act Licence No. 2716 RR

Receipt of your letter dated November 8, 2017 and Notice of Alteration form received December 22, 2017 is hereby acknowledged as a Notice of Alteration in accordance with Section 14 of The Environment Act. In your letter, you requested an extension to Clause 2 of the September 12, 2017 Notice of Alteration approval letter that required you to complete the construction of the upgraded wastewater treatment plant before February 29, 2020 such that the phosphorus limit of 1.0 mg/L will be met.

The intent of your Notice of Alteration request is to extend the completion deadline for construction of the upgraded wastewater treatment plant such that the phosphorus limit will be met by July 2020.

Based on the review of your request and submitted documents, the alteration is approved in accordance with Section 14(2) of The Environment Act subject to the following condition:

1. The construction of the upgraded wastewater treatment plant shall be completed before December 31, 2020 such that the phosphorus limit of 1.0 mg/L will be met.

All other conditions of the September 12, 2017 Notice of Alteration remain valid.

Please be advised that this approval is contingent on the acceptance of a revised Environment Act Licence to be issued in the near future.

Sincerely,

- original signed by -
Tracey Braun, M.Sc.
Director, Environmental Approvals Branch

c: Don Labossiere/Donna Smiley/Yvonne Hawryliuk, Environmental Compliance and Enforcement Branch
Public Registries