



Environment and Climate

Environmental Compliance and Enforcement
Box 36, 14 Fultz Blvd.
Winnipeg MB R3Y 0L6
T 204-945-7100
ECEBranch@gov.mb.ca

File No.: 1071.10

July 27, 2026

Cynthia Wiebe
Manager of Engineering Services
Water and Waste Department
City of Winnipeg
cwiebe@winnipeg.ca

Dear Cynthia Wiebe:

RE: North End Water Pollution Control Centre (NEWPCC) Interim Phosphorus Removal Summary Report

Environment and Climate Change reviewed the NEWPCC Interim Phosphorus Removal Summary Report, dated November 3, 2025, submitted per the requirements in June 24, 2022, letter from this department.

Per the report, please continue with ferric chloride dosing, including optimizing dosing locations, to maximize phosphorus removal in effluent while maintaining overall functionality of the plant. Please advise this department of the results of your investigations into effluent color and impact to ultraviolet transmission levels.

If you have any questions, please contact Neil Rentz, Senior Strategic Environmental Analyst, at 204-794-3546, or Neil.Rentz@gov.mb.ca.

Yours sincerely,

Yvonne Hawryliuk
Director

C. Tim Shanks [redacted] Chris Carroll [redacted] Linda McCusker [redacted]
[redacted] Jon Goodbrandson [redacted] Alison Weiss [redacted]
[redacted] Lana Obach [redacted] Michelle Paetkau [redacted]
Robert Taylor [redacted] – City of Winnipeg
Sonja Bridges, Neil Rentz – Environmental Compliance and Enforcement
Environmental Approvals Branch (EABDirector@gov.mb.ca)