



820 Taylor Ave • Winnipeg, Manitoba Canada • R3M 3T1
(204) 360-4394 • sjohnson@hydro.mb.ca

June 30, 2017

Client File No. 5433.00
Licence No. 3055

Ms. Tracey Braun
Director
Environmental Approvals
Manitoba Conservation
Suite 160, 123 Main Street
Winnipeg, MB R3C 1A5

Dear Ms. Braun:

RE: Bipole III Transmission Project (Licence 3055) – Tower 6198 Location Adjustment

Pursuant to the Bipole III Transmission Project *Environment Act* licence 3055, this letter serves to request approval for a minor right-of-way adjustment in construction segment S1 related to Tower 6198. After geotechnical investigation it has been determined the planned location for Tower 6198 is on an actively failing slope. Therefore, Manitoba Hydro requests the tower location be moved approximately 20 metres southeast. Per the attached map, this tower adjustment results in the minor adjustment to the edges of the right-of-way of 3-5m for approx. 350m between towers 6197 and 6198

Your earliest possible review of this request is very much appreciated as required equipment is only anticipated to be in the area until July 2017.

Should you have any questions or require further clarification please do not hesitate to contact me at 204-360-4394.

Regards,

Original signed by Shannon Johnson

Shannon Johnson
Manager
Licensing and Environmental Assessment Department
Manitoba Hydro
820 Taylor Ave (3)
Winnipeg, Manitoba
R3M 3T1

Attachments: 1 map



Manitoba Hydro Proposed
Adjustment to Tower 6198
in S1 Bipole III
Transmission Project