



Conservation and Climate

Environmental Approvals Branch
1007 Century St
Winnipeg MB R3H 0W4
T 204 945-8321 F 204 945-5229

File No: 5659.10

October 4, 2021

Mike Heppner
Manager, Waterworks Department
City of Steinbach
255 Reimer Avenue
Steinbach, MB R5G 2J1
mheppner@steinbach.ca

Dear Mike Heppner:

Re: Environment Act Licence No. 3364

Enclosed is Environment Act Licence No. 3364, issued to the City of Steinbach for land application of biosolids from the City of Steinbach aerated wastewater treatment lagoon to agricultural land, in accordance with the Proposal and additional information filed under The Environment Act.

In addition to the enclosed Licence requirements, please be informed that all other applicable federal, provincial and municipal regulations and by-laws must be complied with. A Notice of Alteration must be filed with the director for approval prior to any alteration to the development as licensed.

Should you have any questions concerning this matter, please contact Allan Cyrene, Acting Regional Supervisor, Environmental Compliance and Enforcement Branch at 204-485-6410 or Allan.Cyrene@gov.mb.ca.

Pursuant to Section 27 of The Environment Act, this licensing decision may be appealed by any person who is affected by the issuance of this licence to the Minister of Conservation and Climate within 30 days of the date of the licence.

Sincerely,

Original Signed by

Laura Pyles, A/Director
The Environment Act

cc: Darren Keam – WSP Canada Inc.
Kristal Harman, Yvonne Hawryliuk, Allan Cyrene – Environmental Compliance and Enforcement
Eshetu Beshada, Bereket Assefa – Environmental Approvals
Public Registry

LICENCE

File No. 5659.10

Licence No. / Licence n°: **3364**

Issue Date / Date de délivrance : **October 4, 2021**

In accordance with The Environment Act (C.C.S.M. c. E125)
Conformément à la Loi sur l'environnement (C.P.L.M. c. E125)

Pursuant to Section 11(1) / Conformément au Paragraphe 11(1)

THIS LICENCE IS ISSUED TO: / CETTE LICENCE EST DONNÉE À:

CITY OF STEINBACH; "the Licensee"

for the operation of the Development being the periodic transportation and land application of biosolids from the City of Steinbach aerated wastewater treatment lagoon located at sections 8 and 17-7-6 EPM in the Rural Municipality of Hanover, to agricultural land in accordance with the Proposal filed under The Environment Act on June 4, 2019, and subsequent information provided in a letter dated January 18, 2021, and subject to the following specifications, limits, terms and conditions:

DEFINITIONS

In this Licence,

"accredited laboratory" means a laboratory accredited by the Standards Council of Canada (SCC), another accrediting agency recognized by Manitoba Conservation and Climate to be equivalent to the SCC, or at a laboratory which can demonstrate to Manitoba Conservation and Climate that it has the quality assurance/quality control (QA/QC) procedures in place equivalent to accreditation based on the international standard ISO/IEC 17025, or otherwise approved by the Director;

"aerated lagoon" means the City of Steinbach aerated wastewater treatment lagoon;

"affected area" means a geographical area, excluding the property of the Development;

"approved" means approved by the Director, or an assigned Environment Officer, in writing;

"aquifer" means a water saturated geologic unit that will yield water to wells or springs at a sufficient rate so that the wells or springs can serve as practical sources of water supply;

"biosolids" means accumulated organic solids, resulting from wastewater treatment processes, that have received adequate treatment to permit the material to be recycled;

"Director" means an employee so designated pursuant to The Environment Act;

"Environment Officer" means an employee so designated pursuant to The Environment Act;

"first order waterway" means a drain or watercourse serving a watershed with a drainage area of up to one square mile;

"flooding" means the flowing of water onto lands, other than waterways, due to the overtopping of a waterway or waterways;

"fourth order waterway" means a drain or watercourse formed at the point of confluence of at least two third order waterways and may have tributaries of the third order and lower;

"noise nuisance" means an unwanted sound, in an affected area, which is annoying, troublesome, or disagreeable to a person:

- a) residing in an affected area;
- b) working in an affected area; or
- c) present at a location in an affected area which is normally open to members of the public;
- d) if the unwanted sound:
 - i) is the subject of at least 5 written complaints, received by the Director in a form satisfactory to the Director and within a 90-day period, from 5 different persons falling within clauses a), b) or c), who do not live in the same household; or
 - ii) is the subject of at least one written complaint, received by the Director in a form satisfactory to the Director, from a person falling within clauses a), b) or c) and the Director is of the opinion that if the unwanted sound had occurred in a more densely populated area there would have been at least 5 written complaints received within a 90-day period, from 5 different persons who do not live in the same household;

"odour nuisance" means a continuous or repeated odour, smell or aroma, in an affected area, which is offensive, obnoxious, troublesome, annoying, unpleasant or disagreeable to a person:

- a) residing in an affected area;
- b) working in an affected area; or
- c) present at a location in an affected area which is normally open to members of the public;
- d) if the odour, smell or aroma:
 - i) is the subject of at least 5 written complaints, received by the Director in a form satisfactory to the Director and within a 90-day period, from 5 different persons falling within clauses a), b) or c), who do not live in the same household; or

- ii) is the subject of at least one written complaint, received by the Director in a form satisfactory to the Director, from a person falling within clauses a), b) or c) and the Director is of the opinion that if the odour, smell or aroma had occurred in a more densely populated area there would have been at least 5 written complaints received within a 90-day period, from 5 different persons who do not live in the same household;

"reference material" means soil or biosolids material which is used as a reference;

"reference value" means the value established by the agency that supplied the reference material;

"second order waterway" means a drain or watercourse servicing a watershed with a drainage area greater than one square mile or having a tributary or tributaries which are first order waterways;

"Standard Methods for the Examination of Water and Wastewater" means the most recent edition of Standard Methods for the Examination of Water and Wastewater published jointly by the American Public Health Association, the American Waterworks Association and the Water Environment Federation;

"third order waterway" means a drain or watercourse formed at the point of confluence of a least two second order waterways and may have tributaries of the second order and lower; and

"water table" means the upper surface of the zone of saturation of a water bearing geologic unit.

GENERAL TERMS AND CONDITIONS

This Section of the licence contains requirements intended to provide guidance to the Licensee in implementing practices to ensure that the environment is maintained in such a manner as to sustain a high quality of life, including social and economic development, recreation and leisure for present and future Manitobans.

1. The Licensee shall at all times maintain a copy of this licence at the Development or at the premises from which the Development's operations are managed.
2. In addition to any of the limits, terms and conditions specified in this licence, the Licensee shall, upon the request of the Director:
 - a) sample, monitor, analyze and/or investigate specific areas of concern regarding any segment, component or aspect of pollutant storage, containment, treatment handling, disposal or emission systems, for such pollutants or ambient quality, aquatic toxicity, leachate characteristics and discharge or emission rates, for such duration and at such frequencies as may be specified;
 - b) determine the environmental impact associated with the release of any pollutant(s) from the Development;
 - c) conduct specific investigations in response to the data gathered during environmental monitoring programs; or

- d) provide the Director, within such time as may be specified, with such reports, drawings, specifications, analytical data, descriptions of sampling and analytical procedures being used, bioassay data, flow rate measurements and such other information as may from time to time be requested.
3. The Licensee shall, unless otherwise specified in this Licence:
 - a) carry out all preservations and analyses of liquid samples in accordance with the methods prescribed in the Standard Methods for the Examination of Water and Wastewater or in accordance with equivalent preservation and analytical methodologies approved by the Director;
 - b) carry out all sampling of, and preservation and analyses on biosolids, soil, compost, and air samples in accordance with methodologies approved by the Director;
 - c) have all analytical determinations undertaken by an accredited laboratory; and
 - d) report the results to the Director, in writing and in an electronic format acceptable to the Director, within 60 days of the samples being taken.
 4. The Licensee shall submit all information required to be provided to the Director or Environment Officer under this licence, in writing, in such form (including number of copies), and of such content as may be required by the Director or Environment Officer, and each submission shall be clearly labelled with the Licence Number and Client File Number associated with this licence.
 5. The Licensee shall, in the case of physical or mechanical equipment breakdown or process upset where such breakdown or process upset results or may result in the release of a pollutant in an amount or concentration, or at a level or rate of release, that causes or may cause a significant adverse effect, immediately report the event by calling 204-944-4888 (toll-free 1-855-944-4888). The report shall indicate the nature of the event, the time and estimated duration of the event and the reason for the event.
 6. The Licensee shall, following the reporting of an event pursuant to Clause 5,
 - a) identify the repairs required to the mechanical equipment;
 - b) undertake all repairs to minimize unauthorized discharges of a pollutant;
 - c) complete the repairs in accordance with any written instructions of the Director; and
 - d) submit a report to the Director about the causes of breakdown and measures taken, within one week of the repairs being done.
 7. The Licensee shall, during construction and operation of the Development, report spills of fuels or other contaminants to an Environment Officer in accordance with the requirements of the Environmental Accident Reporting Regulation or any future amendment thereof.
 8. The Licensee shall, during all biosolids land application activities, comply with the requirements of the Nutrient Management Regulation or any future amendment thereof.
 9. The Licensee shall only apply the biosolids to agricultural land located within SE 09-07-06 EPM; NE 10-07-06 EPM (west half); NW 10-07-06 EPM (south half); SW 15-07-06 EPM; Part of SW 08-07-06 EPM and Part of E 1/2 08-07-06 EPM; SE 08-07-06 EPM (east half); NE 08-07-06 EPM (east half); NW 08-07-06 EPM; SE 17-07-06 EPM (east half); Lot 1, Plan 14671 WLTO, in the City of Steinbach (east of the airstrip), and Lot 1, Plan 14671 WLTO, in the City of Steinbach (north of the airstrip) or other adjacent or nearby requested areas approved by the Director.

10. The Licensee shall transport biosolids in containers in such a manner to prevent loss of biosolids and associated liquids to the satisfaction of an Environment Officer.
11. The Licensee shall not cause or permit a noise nuisance to be created as a result of the construction, operation, or alteration of the Development, and shall take such steps as the Director may require to eliminate or mitigate a noise nuisance.
12. The Licensee shall not cause or permit an odour nuisance to be created as a result of the construction, operation, or alteration of the Development, and shall take such steps as the Director may require to eliminate or mitigate an odour nuisance.
13. The Licensee shall actively participate in any future watershed-based management study, plan or nutrient reduction program, approved by the Director, for the Red River and associated waterways and watersheds.

SPECIFICATIONS, LIMITS, TERMS AND CONDITIONS

Operation – General

14. The Licensee shall, at least thirty days prior to the commencement of removal of biosolids from the aerated lagoon, transportation to any licenced site, and land application of biosolids at any location(s) in any year other than 2021, provide public notice that presents information of each intended land application of biosolids that is to occur at any and all locations in that year to the satisfaction of the Environment Officer. For the year 2021 the Licensee shall provide the said public notice as soon as possible.
15. The Licensee shall notify the assigned Environment Officer not less than ten days prior to the commencement of removal, transportation and land incorporation of biosolids. The notification shall include the intended starting date of the activities and the name of the contractor responsible for the activities.
16. The Licensee shall, during removal, transportation, surface application, and incorporation of biosolids to land, operate, maintain and store all materials and equipment in a manner that prevents any deleterious substances (fuel, oil, grease, hydraulic fluids, coolant, paint, uncured concrete and concrete wash water, etc.) from entering the aerated lagoon, the discharge route and associated watercourses.
17. The Licensee shall locate all fuel storage and equipment servicing areas established for the construction and operation of the Development a minimum distance of 100 metres from any waterbody, and shall comply with the requirements of the Storage and Handling of Petroleum Products and Allied Products Regulation or any future amendment thereof.

Operation – Land Application

18. The Licensee shall:
 - a) apply biosolids to the identified agricultural land by incorporating it into the soil a minimum of 15 centimetres below the soil surface within 24 hours of application;
 - and

- b) complete the application and incorporation of the biosolids such that it is acceptable to an Environment Officer.
19. The Licensee shall apply biosolids such that the amounts of residual nitrate-nitrogen in the 0-24 inch soil depth and Olsen-P phosphorus in the 0-6 inch soil depth do not exceed the limits of the most limiting Nutrient Management Zone, regardless of size, set forth in the Nutrient Management Regulation under The Water Protection Act or any future amendment thereof.
20. The Licensee shall not apply biosolids:
- a) between November 10th of any year and April 10th of the following year, unless otherwise authorized in writing by the Director;
 - b) to frozen soil;
 - c) less than 75 metres from any occupied residence (other than the residence occupied by the owner of the land on which the biosolids are to be applied);
 - d) less than 400 metres from a residential area;
 - e) less than 8 metres from a major wetland, bog, marsh or swamp;
 - f) less than 15 metres from a first order waterway;
 - g) less than 30 metres from a second, third or fourth order waterway and less than 90 metres from any other waterway;
 - h) less than 50 metres from any groundwater well; or
 - i) on land that is subject to flooding.
21. The Licensee shall not apply biosolids on land:
- a) with a depth of clay or clay till of less than 1.5 metres between the soil surface and the water table;
 - b) within 100 metres of an identifiable boundary of an aquifer which is exposed to the ground surface;
 - c) where, prior to the application of biosolids, the soil pH is less than 6.0;
 - d) where the surface slope of the land is greater than five per cent;
 - e) where, prior to the application of biosolids, the level of nitrate-nitrogen exceeds 100 kilograms per hectare in the upper 60 centimetres of the soil; or
 - f) where, prior to the application of biosolids, the concentration of sodium bicarbonate extractable phosphorus, as P, exceeds 60 micrograms per gram in the upper 15 centimetres of the soil.
22. The Licensee shall not allow cattle to pasture on land on which biosolids have been applied, for a period of three years from the date of application of the biosolids. For application on land not owned by the Licensee, this requirement shall be included in any agreement between the Licensee and the landowner.
23. The Licensee shall, on all agricultural land onto which biosolids have been applied, plant one of the following crops at the commencement of the next growing season following such application and for a period of three years from the date of application of biosolids:
- a) a cereal crop;
 - b) a forage crop;
 - c) an oil seed crop;
 - d) field peas; or
 - e) lentils.

For application on land not owned by the Licensee, this requirement shall be included in any agreement between the Licensee and the landowner.

24. The Licensee shall apply biosolids onto agricultural land such that the cumulative weight per hectare of each heavy metal in the soil, as calculated by adding the amount of each heavy metal in the biosolids applied to the background level of the same metal, does not exceed the following levels: *

<u>Metal</u>	<u>Kilogram per Hectare</u>
Arsenic	21.6
Cadmium	2.5
Chromium (total)	115.2
Copper	113.4
Lead	126
Mercury	11.9
Nickel	90
Zinc	360

* Calculated values shall be based on a soil bulk density of 1200 kilograms per cubic metre and a soil depth of 15 centimetres. Analysis for heavy metals shall be carried out in accordance with Schedule "B" of this Licence.

MONITORING AND REPORTING SPECIFICATIONS

25. The Licensee shall conduct a monitoring and analysis program that is acceptable to the Director, and in accordance with Schedules "A" and "B" of this licence to determine:
- the composition of the biosolids;
 - the background levels of selected soil parameters for each parcel of land;
 - the surface slope of each parcel of land;
 - the presence of clay or clay till to a depth of 1.5 metres for each parcel of land;
 - whether metals-based, phosphorus-based, or nitrogen-based application limits are most appropriate for field-specific application rates for the lands on which the biosolids are to be applied; and
 - the crops grown on land on which biosolids have been applied during the previous 3-year period.
26. The Licensee shall, on or before the 1st day of December of each year, submit a report to the Environment Officer, which will include the following:
- details of the biosolids land application programs carried out during the previous 12 month period including:
 - a description of each parcel of land on which biosolids were applied;
 - the background levels of soil parameters as listed in Schedule "A" of this Licence, for each parcel of land;
 - the dry weight of biosolids applied per hectare;
 - the weight of each heavy metal, in milligrams per kilogram of soil, added to each parcel of land for the metals listed in Schedule "A" of this Licence; and
 - the cumulative weight, in kilograms per hectare, of each heavy metal for each parcel of land as calculated by adding the amount of each heavy metal applied to the background level of the same metal;

- b) the amount of nitrogen, phosphorus, and potassium which was added per hectare for each parcel of land;
 - c) the results of analysis of the biosolids and soil required by this licence; and
 - d) a copy of the analytical procedures used and the results of analysis of reference materials in accordance with Schedule “B” of this licence.
27. The Licensee shall undertake annual post-harvest soil testing of each field for Nitrate-N (0 – 24”) and phosphorus using the Olsen-P test (0 – 6”) for 3 years following biosolids application. Additionally, the Licensee shall supply information from the producer regarding the amounts of nutrients from other sources (fertilizer, manure, etc) being added to the field. Such soil test, fertilization, and cropping information shall be submitted to Manitoba Conservation and Climate on or before the 15th day of March of each year following a year when application of biosolids occurred.

REVIEW AND REVOCATION

- A. If, in the opinion of the Director, the Licensee has exceeded or is exceeding or has or is failing to meet the specifications, limits, terms, or conditions set out in this licence, the Director may, temporarily or permanently, revoke this licence.
- B. If the Licensee has not commenced operation of the Development within one year of the date of this licence, the licence is revoked.
- C. If, in the opinion of the Director, new evidence warrants a change in the specifications, limits, terms or conditions of this licence, the Director may require the filing of a new proposal pursuant to Section 11 of The Environment Act.

Original Signed by

Laura Pyles, A/Director
The Environment Act

SCHEDULE "A" TO ENVIRONMENT ACT LICENCE NO. 3364

Biosolids and Soil Sampling Requirements Pursuant to Clauses 25 and 26

Biosolids

A representative sample of biosolids shall be collected from each cell from which biosolids will be removed for land application. A representative sample of biosolids from each cell shall be a composite of biosolids samples taken from a minimum of 5 locations distributed over the area of that cell.

1. The sample of biosolids shall be analyzed for the following parameters:*

- | | |
|----------------------------|--------------|
| a. conductivity | j. lead |
| b. pH | k. mercury |
| c. total solids | l. nickel |
| d. volatile solids | m. potassium |
| e. nitrate nitrogen | n. cadmium |
| f. total Kjeldahl nitrogen | o. copper |
| g. ammonia nitrogen | p. zinc |
| h. organic nitrogen | q. chromium |
| i. total phosphorus | r. arsenic |

* Analysis for heavy metals must be carried out in accordance with Schedule "B" of this licence.

Soil

1. Composite samples from each field onto which biosolids will be applied shall be taken prior to application of biosolids. Each field of twenty-four hectares or less shall be sampled from a minimum of twelve representative sites or a minimum of one sample site per two hectares for larger fields. Each sample site shall be sampled from 0 to 15 centimetres and from 0 to 60 centimetres. The entire core extracted for each sample shall be collected. All samples from similar depths within a field shall be bulked in one container for thorough mixing prior to analysis yielding two samples per field.

2. Soil samples from 0 to 15 centimetres shall be analyzed for the following: *

- | | |
|--|-------------|
| a. pH | g. cadmium |
| b. potassium | h. chromium |
| c. nickel | i. copper |
| d. mercury | j. lead |
| e. zinc | k. arsenic |
| f. sodium bicarbonate extractable phosphorus, as P | |

* Analysis for heavy metals must be carried out in accordance with Schedule "B" of this licence.

3. Soil samples from 0 to 60 centimetres shall be analyzed for the following:

- | | |
|---------------------|-------------------|
| a. nitrate nitrogen | b. total nitrogen |
|---------------------|-------------------|

Crops

1. The type of crop grown on lands on which biosolids have been applied during the previous 3-year period shall be listed along with the legal description of the land and the date of application of biosolids.

SCHEDULE "B" TO ENVIRONMENT ACT LICENCE NO. 3364

Metals Analysis Requirements Pursuant to Clauses 24 - 26

The analysis for all metals shall be carried out in accordance with the following requirements:

1. The laboratory performing these analyses shall:
 - a) possess and maintain accreditation with the Canadian Association for Laboratories Accreditation Inc. (CALA) and/or the Standards Council of Canada (SCC);
 - b) operate a quality assurance program acceptable to the assigned Environment Officer;
 - c) monitor the accuracy of the sludge and soil analyses for each set of ten or less samples of sludge or soil through the use of a suitable reference material acceptable to the assigned Environment Officer; and
 - d) analyze field duplicates of samples based on a frequency of one in each set of ten or less field samples and that the acceptance criteria for duplicate analysis should be within ± 10 percent.
2. A copy of the analytical procedures and the analytical results for associated reference materials used in the laboratory, and any other controls used in the analysis, shall be submitted with the field sample results.
3. If the analytical results of any associated reference materials do not meet the following criteria, the soil and/or sludge samples must be re-analyzed:

- Arsenic	± 35 percent from the reference value
- Cadmium	± 25 percent from the reference value (for values above $1 \mu\text{g/g}$)
- Cadmium	± 35 percent from the reference value (for values below $1 \mu\text{g/g}$)
- Chromium	± 25 percent from the reference value
- Copper	± 25 percent from the reference value
- Lead	± 25 percent from the reference value
- Mercury	± 35 percent from the reference value
- Nickel	± 25 percent from the reference value
- Zinc	± 25 percent from the reference value