

Webb, Bruce (CWS)

Subject: Crane River Water Treatment Plant File: 5678.00

The attached material can be placed in the public registries for the above project:

Additional information – none requested

Public Comments – none received

Technical Advisory Committee Comments (10 pages)

- Manitoba Conservation and Water Stewardship, Environmental Compliance and Enforcement Branch, October 21, 2013
- Manitoba Conservation and Water Stewardship, Watersheds and Protected Areas Branch and Lands Branch, November 13, 2013
- Manitoba Conservation and Water Stewardship, Parks and Natural Areas Branch, October 18, 2013
- Manitoba Conservation and Water Stewardship, Wildlife Branch, November 14, 2013
- Manitoba Conservation and Water Stewardship, Water Science and Management Branch, Water Quality Management Section, November 13, 2013
- Manitoba Conservation and Water Stewardship, Office of Drinking Water, November 13, 2013
- Manitoba Conservation and Water Stewardship, Water Use Licensing Section, October 21, 2013
- Manitoba Conservation and Water Stewardship, Water Control Works and Drainage Licensing Section, October 16, 2013
- Manitoba Infrastructure and Transportation, Highway Planning and Design Branch, Environmental Services Section, November 13, 2013
- Manitoba Health, Public Health Branch, November 13, 2013

Bruce.

Webb, Bruce (CWS)

Subject: FW: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

From: Hagenson, Kayla (CWS)

Sent: October-21-13 2:11 PM

To: Webb, Bruce (CWS)

Subject: FW: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

Manitoba Conservation, Compliance and Enforcement branch has reviewed the above noted proposal and has no comments or concerns at this time.

Kayla Hagenson, *B.Env.Sc.*

Environment Officer

Conservation and Water Stewardship

Environmental Compliance and Enforcement, Western Region

27-2nd Ave SW

Dauphin, MB R7N 3E5

(204) 622-2316

Webb, Bruce (CWS)

From: Kaita, Adara (CWS) on behalf of +WPG1212 - Conservation_Circulars (CWS)
Sent: November-13-13 8:46 AM
To: Webb, Bruce (CWS)
Subject: EA Proposal - Arnason Industries Ltd. on behalf of ANA - Crane River Water Treatment Plant
File: 5678.00
Attachments: SE31-029-13W.doc

Hi Bruce,

The Watersheds and Protected Areas Branch has no concerns. The Lands Branch has no concerns, conditional upon the following:

- No haying or bale storage within 50 feet of structures/buildings
- The proponent will be responsible to determine if the project proposed will impact any Crown land. The proponent should be advised that any/all works involving or impacting Crown lands will require proper authorizations as per The Crown Lands Act (e.g., Crown Lands dispositions – Permits or leases, and/or Crown Land Work Permits etc.).
- Once Crown land applications are submitted, the Site Plan is to be updated to include the facility and associated structures.

Thanks,

Adara Kaita
Crown Land Programs and Policy Manager
Conservation and Water Stewardship
Box 25, 200 Saulteaux Crescent
Winnipeg, MB R3J 3W3
Cell: (204) 945-6301
F: (204) 948-2197

Webb, Bruce (CWS)

Subject: FW: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

From: Kelly, Jason (CWS)

Sent: October-18-13 3:36 PM

To: Webb, Bruce (CWS)

Subject: RE: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

Parks and Natural Areas Branch has reviewed the Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00 filed pursuant to the *Environment Act*. The Branch has no comments to offer as this does not impact any parks or ecological reserves.

Jason Kelly, M.N.R.M.
Ecological Reserves and Protected Areas Specialist
Parks and Natural Areas Branch
Conservation and Water Stewardship
Box 53, 200 Saulteaux Cres
Winnipeg, MB R3J 3W3

Phone: 204-945-4148

Cell:

Fax: 204-945-0012

Email: Jason.Kelly@gov.mb.ca

Webb, Bruce (CWS)

From: Boissonneault, Caroline (CWS)
Sent: November-14-13 7:42 AM
To: Webb, Bruce (CWS)
Subject: Emailing: Request for comments due Nov.14 Crane River Water Treatment Plant file 5678 added
Attachments: FW: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

Hello Bruce,
The Wildlife Branch does not have any concerns regarding this review.
Thank you.

Caroline Boissonneault
Wildlife Branch
Conservation and Water Stewardship
Tel.: 204-945-6810
Caroline.boissonneault@gov.mb.ca

Your message is ready to be sent with the following file or link attachments:

Request for comments due Nov.14 Crane River Water Treatment Plant file 5678 added

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.

Webb, Bruce (CWS)

Subject: FW: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

From: Gurney, Sharon (CWS)
Sent: November-13-13 11:34 PM
To: Webb, Bruce (CWS)
Cc: Page, Elaine (CWS)
Subject: RE: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

Bruce:

I have reviewed the proposal and provide the following comments for your consideration.

The proposal does not provide detailed information regarding the quality of the reject water, or attempt to evaluate what impact the reject water will have on the receiving stream. However, due to the small size of the facility (i.e. serving 130 people), it seems unlikely that the receiving stream would be significantly impacted by the discharge.

Thank you for the opportunity to provide comments on this proposal.

*Sharon Gurney M.Sc.
Water Quality Management Section
Manitoba Conservation and Water Stewardship
160 - 123 Main St.
Winnipeg, MB. Canada
R3C 1A5
Phone: 204-945-7114
Cell: 204-479-7114
Fax: 204-948-2357
Email: sgurney@gov.mb.ca*

Webb, Bruce (CWS)

From: Stibbard, James (CWS)
Sent: November-13-13 8:59 AM
To: Webb, Bruce (CWS)
Subject: Re: 5678.00 CraneRiver Water Treatment Plant EAP

Mr. Webb,

I reviewed the above noted EAP. The Proponent has submitted an application for a Permit to Construct or Alter a Public Water System, as required under *The Drinking Water Safety Act*, so I have no other cause for concern respecting drinking water safety with the EAP or proposed work.

If you have any questions, please call.

Regards,

James Stibbard P. Eng.

Approvals Engineer

Office of Drinking Water

1007 Century Street

Winnipeg MB R3H 0W4

phone: (204) 945-5949

fax: (204) 945-1365

email: James.Stibbard@gov.mb.ca

website: www.manitoba.ca/drinkingwater

Confidentiality Notice: This message, including any attachments, is confidential and may also be privileged and all rights to privilege are expressly claimed and not waived. Any use, dissemination, distribution, copying or disclosure of this message, or any attachments, in whole or in part, by anyone other than the intended recipient, is strictly prohibited.

Webb, Bruce (CWS)

Subject: FW: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

From: Matthews, Rob (CWS)

Sent: October-21-13 12:42 PM

To: Webb, Bruce (CWS)

Cc: Dey, Asit (CWS)

Subject: RE: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

Bruce,

No comments other than to say that the community has a valid water rights licence (2012-066) and that annual water use reporting is a condition of the licence. If as a result of the installation of the new water treatment plant that raw water use approaches or exceeds the licensed allocation on the water rights licence the community and/or ANA should apply for an increase in the authorized annual diversion of water under the water rights licence.

Rob Matthews,
Manager,
Water Use Licensing Section


Webb, Bruce (CWS)

From: Roberts, Dan (CWS)
Sent: October-16-13 9:00 AM
To: Webb, Bruce (CWS)
Subject: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

On behalf of the *Water Control Works and Drainage Licensing Section*, there are no concerns.

Dan Roberts

Water Resource Officer
Water Control Works and Drainage Licensing Section
Conservation and Water Stewardship
Box 640, 201 Fourth Ave. S., Swan River, MB R0L 1Z0
Cell: (204) 281-2122, Fax: 734-3733



Infrastructure and Transportation
Highway Planning and Design Branch
Environmental Services Section
1420 - 215 Garry St., Winnipeg, MB R3C 3P3
T (204) 818-4359 F (204) 845-0583

November 13, 2013

Tracey Braun, M. Sc.
Director, Environmental Approvals Branch
Manitoba Conservation and Water Stewardship
123 Main St., Suite 160
Winnipeg, MB R3C 1A5

RE: MB ANA - Community of Crane River WTP
Client File No. 5678.00.

Dear Ms. Braun:

MIT has reviewed the application under the Environment Act noted above and we do not have any concern with the proposed development.

Thank you very much for providing us the opportunity to review the application.

Sincerely,

Ryan Coulter, M. Sc., P. Eng.
Manager of Environmental Services

Webb, Bruce (CWS)

Subject: FW: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

From: Chang, Heejune (HEALTH)
Sent: November-13-13 3:43 PM
To: Webb, Bruce (CWS)
Cc: Frykoda, Amy (HEALTH)
Subject: RE: Request for comments - Due: Nov. 14, 2013 - Crane River Water Treatment Plant File: 5678.00

Hello,

Regarding EIA of this development.

- The report does not mention the proximity of the project to residential areas though it does note that the land is not used for anything at the moment. Would like to have further information on whether there may be any health issues during the construction period such as noise, dust, waste removal for residents near to the site (if any)
- Please provide information on any health issues related to the change over from the old treatment to the new treatment system and how this process will occur as safely as possible.

Thank you,

Sincerely,
Heejune

Dr. Heejune Chang PGY-5
Public Health and Preventive Medicine Resident
Manitoba Public Health Branch
4th Floor - 300 Carlton
Winnipeg MB, R3B 3M9

Phone: (204) 786-7335
Cellphone: (204) 791-7892
Fax: (204) 948-2204