

## **Webb, Bruce (CWS)**

---

**To:** Steele, Tania (CWS)  
**Subject:** Frontier School Division - Jack River School Water Treatment Plant Replacement File:  
5715.00

The attached material can be placed in the public registries for the above project:

*Request for additional information* – no additional information was required.

*Public Comments on the Environment Act Proposal* – no public comments received.

*Technical Advisory Committee Comments on the Environment Act Proposal* - (10 pages)

Manitoba Conservation and Water Stewardship, Environmental Programs and Strategies Branch, Air Quality Section,  
July 8, 2014

Manitoba Conservation and Water Stewardship, Lands Branch, July 9, 2014

Manitoba Conservation and Water Stewardship, Northeast Region Integrated Resource Management Team, July 8, 2014

Manitoba Conservation and Water Stewardship, Parks and Protected Spaces Branch, June 26, 2014

Manitoba Conservation and Water Stewardship, Office of Drinking Water, July 15, 2014

Manitoba Conservation and Water Stewardship, Water Use Licensing Section, June 17, 2014

Manitoba Conservation and Water Stewardship, Water Control Works and Drainage Licensing Section, June 18, 2014

Manitoba Infrastructure and Transportation, Highway Planning and Design Branch, Environmental Services Section, July  
2, 2014

Manitoba Agriculture, Food and Rural Development, Crops Branch, June 17, 2014

Office of the Fire Commissioner, July 8, 2014

Bruce.

DATE: 08 July, 2014

TO: Bruce Webb *BW*  
Environmental Approvals  
Conservation and Water  
Stewardship  
160-123 Main Street, Winnipeg

FROM: Muntaseer Ibn Azkar  
Air Quality-Environmental Programs  
& Strategies  
Conservation and Water Stewardship  
1007 Century Street, Winnipeg

**SUBJECT: Frontier School Division – Jack River School Water Treatment Plant (File 5715.00)**

---

Air Quality Section has reviewed the above proposal and provides the following comments:

- The proposal is not expected to have a significant impact on air quality provided that the measures cited are implemented.
- The noise clause is suggested to be included in the License.

## Webb, Bruce (CWS)

---

**From:** Kaita, Adara (CWS) on behalf of +WPG1212 - Conservation\_Circulars (CWS)  
**Sent:** July-09-14 2:13 PM  
**To:** Webb, Bruce (CWS) *BL*  
**Subject:** EA Proposal - Jack River S.D. Water Treatment Plant Replacement - File: 5715.00

Hello Bruce,

The Lands Branch has no concerns with this proposal and notes that the project is on municipal land.

Thank you for the opportunity to review.

**Adara Kaita**  
Crown Land Programs and Policy Manager  
Lands Branch | Conservation and Water Stewardship  
Box 25, 200 Saulteaux Crescent | Winnipeg, MB R3J 3W3  
Cell: (204) 945-6301 | F: (204) 948-2197

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

---

**From:** Hastman, David (CWS) BW  
**Sent:** July-08-14 10:24 AM  
**To:** Webb, Bruce (CWS); +WPG1212 - Conservation\_Circulars (CWS)  
**Cc:** Roberts, Pierce (CWS)  
**Subject:** RE: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

The NE IRMT has reviewed the EAP and responds with no concerns.

*David Hastman*

| RLM (NE) | Lands Branch | Conservation and Water Stewardship | Box 28, 59 Elizabeth Dr. | Thompson, Manitoba | R8N 1X4 |  
| 204-679-0987 | 204-677-6359 | [David.Hastman@gov.mb.ca](mailto:David.Hastman@gov.mb.ca) | [www.gov.mb.ca/conservation/lands\\_branch](http://www.gov.mb.ca/conservation/lands_branch)

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

---

**From:** Kelly, Jason (CWS)  
**Sent:** June-26-14 9:42 AM *BV*  
**To:** Webb, Bruce (CWS)  
**Subject:** RE: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

Parks and Protected Spaces Branch has reviewed the proposal submitted pursuant to *The Environment Act* for EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00. The Branch has no comments or concerns to offer as it does not affect any provincial parks, park reserves, ecological reserves, areas of special interest or proposed protected areas.

Jason Kelly, M.N.R.M.  
Ecological Reserves and Protected Areas Specialist  
Parks and Protected Spaces Branch  
Conservation and Water Stewardship  
Box 53, 200 Saulteaux Cres  
Winnipeg, MB R3J 3W3

Phone: 204-945-4148  
Cell:  
Fax: 204-945-0012

Email: [Jason.Kelly@gov.mb.ca](mailto:Jason.Kelly@gov.mb.ca)

**Webb, Bruce (CWS)**

---

**From:** Stibbard, James (CWS)  
**Sent:** July-15-14 9:33 AM  
**To:** Webb, Bruce (CWS) BW  
**Subject:** Re: 5715.00 Jack River School Water Treatment Plant EAP

Mr. Webb,

I reviewed the above noted EAP and note the following:

1. The project will need to file an Application for Permit to Construct or Alter a Semi-Public Water System with Office of Drinking Water before construction begins.
2. The EAPs for this project and the wastewater treatment plant note the raw water intake and treated effluent discharge pipes from the existing water and wastewater treatment plants will be retained and reused. It also notes both these pipes are in the Jack River. I am concerned about how far apart these pipes are and whether the water treatment plant intake is upstream of the wastewater plant outfall.

Apart from these points, Office of Drinking Water has no other concerns with this EAP or the proposed development. If you have any questions or concerns, please call.

Regards,

**James Stibbard P. Eng.**  
Approvals Engineer  
Office of Drinking Water  
1007 Century Street  
Winnipeg MB R3H 0W4  
phone: (204) 945-5949  
fax: (204) 945-1365  
email: [James.Stibbard@gov.mb.ca](mailto:James.Stibbard@gov.mb.ca)  
website: [www.manitoba.ca/drinkingwater](http://www.manitoba.ca/drinkingwater)

**Confidentiality Notice:** This message, including any attachments, is confidential and may also be privileged and all rights to privilege are expressly claimed and not waived. Any use, dissemination, distribution, copying or disclosure of this message, or any attachments, in whole or in part, by anyone other than the intended recipient, is strictly prohibited.

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

---

**From:** Matthews, Rob (CWS)

**Sent:** June-17-14 3:42 PM

**To:** Webb, Bruce (CWS)

**Subject:** RE: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

No concerns.

Rob Matthews, Manager, WULS, CWS.

**Webb, Bruce (CWS)**

---

**From:** Roberts, Dan (CWS)  
**Sent:** June-18-14 11:30 AM  
**To:** Webb, Bruce (CWS) BW  
**Subject:** Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement  
File: 5715.00

On behalf of the *Water Control Works and Drainage Licensing Section*, there are no concerns.

**Dan Roberts**

Water Resource Officer  
Water Control Works and Drainage Licensing Section  
Conservation and Water Stewardship  
Box 640, 201 Fourth Ave. S., Swan River, MB R0L 1Z0  
Cell: (204) 281-2122, Fax: 734-3733

**Manitoba**



Infrastructure and Transportation  
Highway Planning and Design Branch  
Environmental Services Section  
1420 - 215 Gary St., Winnipeg, MB R3C 3P3  
T (204) 619-4359 F (204) 945-0593

July 2, 2014

BW

Tracey Braun, M. Sc.  
Director, Environmental Approvals Branch  
Manitoba Conservation and Water Stewardship  
123 Main St., Suite 160  
Winnipeg, MB R3C 1A5

RE: Frontler School Division - Jack River School WWTP and WTP  
Client File No. 263.10 and 5715.00

Dear Ms. Braun:

MIT has reviewed the two proposals under the Environment Act noted above and we do not have any concern.

Thank you very much for providing us the opportunity to review the proposal.

Sincerely,



Ryan Coulter, M. Sc., P. Eng.  
Manager of Environmental Services

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

---

**From:** Wilson, Brian (MAFRD) BW  
**Sent:** June-17-14 2:43 PM  
**To:** Webb, Bruce (CWS)  
**Subject:** FW: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

There will be "no comment" on this project.

Brian Wilson  
[Brian.Wilson@gov.mb.ca](mailto:Brian.Wilson@gov.mb.ca)  
Soils Suitability Specialist  
Crops Branch  
Manitoba Agriculture, Food and Rural Development  
Box 1149 #65 - 3rd Avenue NE  
Carman, Manitoba R0G 0J0  
(204) 750-3180  
FAX (204) 745-5690

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant  
Replacement File: 5715.00

---

**From:** Kubish, Cheryl (OFC)  
**Sent:** July-08-14 10:12 AM BW  
**To:** Webb, Bruce (CWS)  
**Subject:** RE: Request for review/comment - EAP -Jack River S.D. Water Treatment Plant Replacement File: 5715.00

At this time, the Office of the Fire Commissioner has no concerns with the replacement of the WWTP.

Cheryl Kubish  
Administrative Assistant  
Office of the Fire Commissioner  
508-401 York Avenue  
Winnipeg MB R3C 0P8  
Phone: 945-3328  
Fax: 948-2089

E-Mail address: [Cheryl.Kubish@gov.mb.ca](mailto:Cheryl.Kubish@gov.mb.ca)