

Comments from Technical Advisory Committee (TAC)

DGHTA Proposal – Rural Municipality of St. Francois Xavier – Used Oil Products & Materials Collection Facility –FILE: 5843.00

Index

August 24, 2016

- Manitoba Sustainable Development, Environmental Compliance & Enforcement Branch, August 22, 2016 – 1 Page
- Office of the Fire Commissioner, August 10, 2016 – 1 page

Total pages (including this page) = 03

DATE: August 22, 2016

TO: Raj Rathamano
Environmental Approvals Branch
Manitoba Sustainable Development
1007 Century Street
Winnipeg, MB R3H 0W4

FROM: Sonja Bridges
Environmental Compliance and
Enforcement
Manitoba Sustainable Development
1007 Century Street
Winnipeg, MB R3H 0W4

PHONE NO.: (204) 918-4271

SUBJECT: Review of DGHTA Proposal for R.M. of St. Francois Xavier Used Oil Collection Facility
Client File No. 5843.00

The Environmental Compliance and Enforcement Branch of Manitoba Sustainable Development has reviewed the above noted proposal and would like to provide the following comments:

1. The proposal does not provide any information on the operating procedures of the depot. Please describe in detail the following:
 - a. How used oil, filters, and containers are received at the facility;
 - b. Any training programs in place including acceptance, handling, storage, and spill response;
 - c. Record keeping procedures; and
 - d. Any other operating procedures that are currently in place.
2. Are there vehicle barricades or fencing in place to prevent vehicle collisions with the storage tank and drum storage area?
3. Is there signage present identifying the area as a used oil collection facility?

From: Akinpelu, Ola (OFC)

Sent: August-10-16 12:51 PM

To: Rathamano, Raj (SD)

Subject: FW: DGHTA Licence application - Used Oil Collection Facility - RM of St. Francois Xavier 5843.00

Hello,

The OFC has reviewed the proposal for the operation of a used oil products & materials collection facility. The OFC recommends that the applicant:

review proposal with the local Fire Department to ensure compliance with NFC Division B Part 3 (Indoor and Outdoor Storage) and Part 4 (Flammable and Combustible Liquids).
submit a Fire Safety Plan (as per NFC Section 2.8) to AHJ.

Thanks

Ola Akinpelu,

Administrative Assistant

Office of the Fire Commissioner

508 - 401 York Avenue

Winnipeg MB R3C 0P8

Ph: (204) 945-1661

Fax: (204) 948-2089

E-mail: Ola.Akinpelu@gov.mb.ca

