



**Associated
Engineering**

*GLOBAL PERSPECTIVE.
LOCAL FOCUS.*



Moose Lake Provincial Park

ENVIRONMENT ACT PROPOSAL

Manitoba Water Services Board & Parks and Protected Spaces

Moose Lake Campground
Water Treatment Plant Upgrades

February 2017

CONFIDENTIALITY AND © COPYRIGHT

This document is for the sole use of the addressee and Associated Engineering (Sask.) Ltd. The document contains proprietary and confidential information that shall not be reproduced in any manner or disclosed to or discussed with any other parties without the express written permission of Associated Engineering (Sask.) Ltd. Information in this document is to be considered the intellectual property of Associated Engineering (Sask.) Ltd. in accordance with Canadian copyright law.

This report was prepared by Associated Engineering (Sask.) Ltd. for the account of Manitoba Water Services Board & Parks and Protected Spaces. The material in it reflects Associated Engineering (Sask.) Ltd.'s best judgement, in the light of the information available to it, at the time of preparation. Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Associated Engineering (Sask.) Ltd. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.



**Associated
Engineering**

GLOBAL PERSPECTIVE.
LOCAL FOCUS.

Associated Engineering (Sask.) Ltd.
203 – Five Donald Street
Winnipeg, Manitoba, Canada, R3L 2T4

TEL: 204.942.6391
FAX: 204.942.6399
www.ae.ca

March 30, 2017

File: 2012-4123.000

Ms. Tracey Braun, M. Sc.
Director, Environmental Approvals
Sustainable Development
123 Main Street, Suite 160
Winnipeg Manitoba, R3C 1A5

**Re: MANITOBA SUSTAINABLE DEVELOPMENT - PARKS AND PROTECTED SPACES
MOOSE LAKE WATER TREATMENT PLANT UPGRADES
ENVIRONMENT ACT PROPOSAL SUBMISSION FOR A CLASS 1 DEVELOPMENT**

Dear Ms. Braun:

On behalf of Parks and Protected Spaces and The Manitoba Water Services Board, please find attached our Environment Act Proposal submission for the above-mentioned project.

This application is for the seasonal surface discharge of residuals from the upgraded water treatment plant in the campground. The existing facility was not operating under any Environment Act Licence, thus one is being applied for as part of the upgrades.

We trust that the enclosed application contains sufficient information for your staff to complete the new Licence. Should the reviewer require any additional information or require any clarifications, please do not hesitate to contact myself.


Yours truly,

Ken Anderson, P.Eng.
Manager, Water

KA

Environment Act Proposal Form



Name of the development: Moose Lake Campground Water Treatment Plant Upgrades	
Type of development per Classes of Development Regulation (Manitoba Regulation 164/88): Class 1 Development - Waste Treatment and Disposal from a Water Treatment Plant	
Legal name of the applicant: Manitoba Sustainable Development - Parks and Protected Spaces Branch	
Mailing address of the applicant: 200 Saulteaux Cres., Winnipeg, MB R3J 3W3	
Contact Person: Rebecca Lauhn-Jensen, CSLA	
City: Winnipeg	Province: MB Postal Code: R3J 3W3
Phone Number: 204-945-4410	Fax: 204-945-0012 email: rebecca.lauhn-jensen@gov.mb.ca
Location of the development: Moose Lake Provincial Park Campground	
Contact Person: Rebecca Lauhn-Jensen, CSLA	
Street Address: 200 Saulteaux Cres., Winnipeg, MB R3J 3W3	
Legal Description: Section 12 - Twp 3 - Rge 16E	
City/Town: Winnipeg	Province: Manitoba Postal Code: R3J 3W3
Phone Number: 204-945-4410	Fax: 204-945-0012 email: rebecca.lauhn-jensen@gov.mb.ca
Name of proponent contact person for purposes of the environmental assessment: Ken Anderson - Associated Engineering (Sask) Ltd.	
Phone: 204-942-6391	Mailing address: 203 - Five Donald Street Winnipeg, MB R3L 2T4
Fax:	
Email address: andersonk@ae.ca	
Webpage address:	
Date: February 15, 2017	Signature of proponent, or corporate principal of corporate proponent:  Printed name: Ken Anderson

A complete **Environment Act Proposal (EAP)** consists of the following components:

- **Cover letter**
- **Environment Act Proposal Form**
- **Reports/plans supporting the EAP** (see "Information Bulletin - Environment Act Proposal Report Guidelines" for required information and number of copies)
- **Application fee** (Cheque, payable to Minister of Finance, for the appropriate fee)

Submit the complete EAP to:

Director
Environmental Approvals Branch
Manitoba Conservation and Water Stewardship
Suite 160, 123 Main Street
Winnipeg, Manitoba R3C 1A5

For more information:

Phone: (204) 945-8321

Fax: (204) 945-5229

<http://www.gov.mb.ca/conservation/ea>

Per Environment Act Fees Regulation
(Manitoba Regulation 168/96):

Class 1 Developments	\$1,000
Class 2 Developments	\$7,500
Class 3 Developments:	
Transportation and Transmission Lines ..	\$10,000
Water Developments	\$60,000
Energy and Mining	\$120,000

Executive Summary

The following Environment Act Proposal (EAP) is submitted on behalf of Sustainable Development Parks and Protected Spaces (Parks) and The Manitoba Water Services Board (MWSB). The EAP is for a Class 1 Development License under the Manitoba's *Environment Act* for the construction of a water treatment plant (WTP) at the Moose Lake Campground. This document provides the information required from Sustainable Development's Environment Act Proposal Report Guidelines and Supplementary Guidelines for Municipal Water Supply Systems.


This EAP describes the components of a new WTP, and associated work, which includes a plant residuals discharge line. The Moose Lake Campground is approximately 160 km southeast of Winnipeg, Manitoba and 11 km north of the border with the United States. The campground consists of 95 campsites (24 are serviced with electricity), five non-modern washrooms with no running water, and one modern washroom facility with two water closets and two showers. Treated water is provided to six stand pipes within the campground and the one modern washroom facility. The Moose Lake Campground operates seasonally from May to September.

The proposed project includes construction of a new semi-public water system that is capable of providing 0.35 L/s of treated water. This new water treatment system includes a two-step ion exchange process, UV primary disinfection, chlorine feed for secondary disinfection, potable water storage tanks, and distribution pumping. An existing building was used to house the new treatment equipment. The new treatment system will target the reduction of ammonia, iron, manganese, and organics.

An assessment of the environmental effects of the proposed WTP upgrade concluded that standard construction best management practices would be effective to mitigate any potential environmental impacts. The expected concentration of regeneration residuals entering the nearby marshlands is anticipated to have negligible if any impacts to water quality and the environment. Several environmental management measures are described herein to address other potential impacts to the environment.

Table of Contents

SECTION	PAGE NO.
EXECUTIVE SUMMARY	I
TABLE OF CONTENTS	II
LIST OF TABLES	IV
LIST OF FIGURES	V
1 INTRODUCTION	1
1.1 Background Information	1
2 DESCRIPTION OF PROPOSED DEVELOPMENT	4
2.1 Project Description	4
2.2 Certificate Of Title.....	7
2.3 Existing And Adjacent Land Use	7
2.4 Land Use Designation And Zoning.....	7
2.5 Project Schedule	7
2.6 Project Funding	7
2.7 Regulatory Approvals	8
2.8 Public Consultation.....	8
2.9 Storage Of Petroleum Products And Other Chemicals	8
3 PHYSICAL ENVIRONMENT	9
3.1 Physiographic Setting And Climate	9
3.2 Hydrogeology	10
3.3 Hydrology.....	10
3.4 Fish And Fish Habitat	11
3.5 Vegetation And Wildlife	11
3.6 Socioeconomic	11
3.7 Heritage Resources.....	11
4 POTENTIAL ENVIRONMENTAL EFFECTS	12
4.1 Air Quality	12
4.2 Soils.....	12
4.3 Surface Water And Fish Habitat.....	12
4.4 Water Quality.....	13
4.5 Groundwater Levels	13



4.6 Vegetation 13

4.7 Wildlife Habitat And Vegetation 13

4.8 Noise And Vibration 14

4.9 Human Health And Well Being 14

4.10 Climate Change 14

5 ENVIRONMENTAL MANAGEMENT MEASURES 15

5.1 Air Quality 15

5.2 Soils 15

5.3 Surface Water 15

5.4 Groundwater 16

5.5 Vegetation And Wildlife 16

5.6 Fisheries 16

5.7 Noise And Vibration 16

5.8 Water Conservation 16

5.9 Residual Environmental Effects 16

6 REFERENCES 17

APPENDIX A – DRAWINGS

APPENDIX B – WTP PREDESIGN REPORT

List of Tables

	PAGE NO.
Table 1-1 Raw Water Quality Summary	3
Table 2-1 Projected Regeneration Water Quality	6
Table 3-1 Climatic Averages for the Region (1996-2007)	9

List of Figures

	PAGE NO.
Figure 2-1: Regeneration Cycles and Regeneration Volume per Day.....	5
Figure 2-2: Discharge and Drainage Route.....	6

1 Introduction

On behalf of the Manitoba Water Services Board, Associated Engineering (Sask.) Ltd. (AE) has prepared the following Environmental Act Proposal (EAP) for the Moose Lake Campground Water Treatment Plant (WTP) Project (the Project). The EAP is based on detailed design prepared by AE.

The final user of the system is Manitoba Sustainable Development's department of Parks and Protected Spaces (The Parks).

This application is for the surface disposal of the plant residuals stream from the new water treatment plant in the campground.

1.1 BACKGROUND INFORMATION

The Moose Lake Campground can be found within the Moose Lake Provincial Park located approximately 160 km southeast of Winnipeg, MB and 11 km north of the border with the United States. The campground consists of approximately 95 campsites (24 that have electricity) and currently has five non-modern washrooms with no running water. These washroom facilities are connected to holding tanks that are emptied as required. The wastewater is hauled to nearby lagoons by contracted haulers at the end of each season. There is a modern washroom facility with two water closets and two showers; potable water is provided by the new water treatment plant. Wastewater from the modern washroom is collected and pumped to an onsite wastewater management system (Ecoflo Biofilter).

Prior to 2014, the Parks was providing an untreated water supply to the standpipes located throughout the campground. Then in 2014, the Parks completed the installation of a new water treatment plant inside an existing building on site. However, the new plant was not fully used until the new onsite wastewater management system was placed into service at the end of 2015.

With both systems fully operational in late 2015, it was determined that the regeneration residuals from the new WTP could not be directed to the new wastewater system. The onsite wastewater system supplier could not guarantee the performance of their system with these residuals due to the elevated mineral content.

Given the location of the campground, the option to store and haul the plant residuals is cost prohibitive, thus, this application is for the surface disposal of regeneration water. Although the water quality is high in mineral content similar to that of reverse osmosis concentrate (that is regularly disposed of to surface), the volume is relatively small given the small size of the system and low to zero use throughout most of the year. The system experiences peak use in July/August with lesser use in June/September, and no use from October to May.

1.1.1 Previous Studies

A predesign study for the new water system was prepared by AE in 2013. The study reviewed historic and projected water use as the raw well water quality. The report provides a summary of design considerations, water quality, and options for upgrades.

1.1.2 Population

The Moose Lake Campground has 95 sites and for design purposes, the serviced population was estimated to be 195 individuals assuming there is an average of two people per campsite and five campground staff. The nearest community is Sprague, MB, located 35 km to the southeast.

1.1.3 Projected Water Use

Treated water will be provided to the modern washroom facility as well as seven standpipes located throughout the campground. The modern washroom facility includes two toilets, two sinks, and two showers. The toilets will be low flow fixtures and the showers will also be low flow but will also be coin operated. Water demand will be based on this serviced population as well as the development of the new modern washroom facility. Considerations will also be given for a future modern washroom facility in the design.

Average Day use during the peak months is estimated to be approximately 30 L/c/day, thus 195 users x 30 L/c/d = **5,850 L/day**. The Peak Day use was based on estimating the maximum use of the two washrooms and two showers in a heavy use day; this was calculated to be **10,450 L/day**. The anticipated volume of 10,450 litres per day is assumed to be sufficient to provide each individual with 20 litres of water on site and the use of each toilet, sink and shower up to 100 times in a day.

The target for the new treatment system is therefore to produce 10,450 L over an eight-hour period. Thus, the treatment flow rate is designed to be **0.35 L/sec**.

1.1.4 Raw Water Source

Moose Lake Provincial Park Campground obtains their water from two ground water wells, installed near the existing WTP building. A pumping test for these wells yielded 1.14 L/sec and 1.36 L/sec and recommended pumping rate of 0.75 L/sec. The intakes for these pumps are located approximately 5.8 m and 6.4 m below grade when they were installed in 2005.

1.1.5 Water Rights Act

Moose Lake Provincial Park Campground will not require a Water Right Act licence as its annual average water use is under 25,000 L/day.

1.1.6 Water Quality

The Office of Drinking Water (ODW) performs annual audits of all public water systems which include sampling and chemistry analysis of raw water once every year for surface water sources. A raw water quality sample from 2010 is summarized in the following Table along with the water quality objectives set forth in Health Canada’s Guidelines for Canadian Drinking Water Quality (GCDWQ) (Health Canada, 2014).

Testing in July of 2012 also shows relatively similar levels for Iron, Manganese and UVT. The sample data shows that with the exception of turbidity, the raw water meets the health based quality parameters. The elevated turbidity is typically a result of oxidized iron and manganese during the sampling procedure. Also, manganese and iron are the two main parameters that exceed the aesthetic guidelines. The levels are high enough to result in discoloured water and staining of fixtures and laundry. The ammonia levels are also slightly elevated, enough so to complicate primary disinfection using only chlorine.

Since the raw water wells are quite shallow in an unconfined aquifer, they are considered as potentially under the direct influence of surface water (GUDI) and the treatment process should account for turbidity reduction and primary disinfection using UV for added protection, and primary disinfection strategy with ammonia.

Table 1-1 Raw Water Quality Summary

Parameter	Units	Raw Water Well #1	Raw Water Well #2	Current Limits (GCDWQ)	Treatment Objective
pH		7.94	7.92	6.5 – 8.5(AO)	6.5 – 8.5
Alkalinity	mg/L	168	171		
Hardness (CaCO ₃)	mg/L	170	179	200 (PO)	
TDS	mg/L	180	186	500 (AO)	< 500
UV Transmittance	%T	66.1	65.8		> 80%
Ammonia, Total (N)	mg/L	0.549	0.758		
TKN	mg/L	0.89	1.13		
Total Organic Carbon (TOC)		7.2	7.7		< 2.0
Arsenic	ug/L	0.55	0.43	10	
Chloride	mg/L	1.85	1.79	250 (AO)	
Colour	TCU	10	10	< 15 TCU	< 5
Fluoride	mg/L	0.19	0.20	1.5	0.80
Iron	mg/L	0.898	0.780	< 0.3 (AO)	< 0.10
Manganese	mg/l	0.106	0.176	< 0.05 (AO)	< 0.05
Turbidity	NTU	2.45	1.17		< 0.3, 95% of the time

Abbreviations:

AO = aesthetic objective
GCDWQ = guidelines for Canadian drinking water quality
PO = practical objective

IMAC = interim maximum acceptable concentration
MAC = maximum acceptable concentration
SMCL = secondary maximum contaminant level

The level of UV transmittance was concerning for a groundwater source, as it can impact the operation of the UV system. The treatment strategy would need to address the elevated TOC levels in order to increase the UVT values.

2 Description of Proposed Development

2.1 PROJECT DESCRIPTION

The proposed project was to install a water treatment Plant (WTP) that is capable of producing 0.35 L/s of treated water.

The projected included the following scope of works:

- The installation of two new well pumps in the existing wells;
- Miscellaneous retrofits to the existing building to accommodate the new plant equipment;
- Installation of new treatment equipment, potable water storage tanks, and distribution pumps;
- Upgrades to the existing standpipes in the campground; and
- Plant residuals collection to a manhole and pumping to the nearby slough.

2.1.1 Proposed Water Treatment Process

The original treatment system that was proposed was greensand filtration, granular activated carbon, UV disinfection and final chlorination.

However, during initial phases of construction, the process was revised through discussions with the selected treatment supplier. The supplier proposed a two-step ion exchange system that would greatly simplify the process and eliminate a significant amount of operational efforts. AE and the Owner accepted the revision as the new process would only require salt for ion exchange process as opposed to a potassium permanganate system, frequent replacement of the carbon media, and regular monitoring of chloramine levels.

The proposed treatment process is as follows:

- One Ø450mm x 1500mm ion exchange vessel for iron and manganese removal;
- One Ø450mm x 1500mm ion exchange vessel for ammonia and organics removal;
- One Ø450mm x 1500mm standby ion exchange vessel for any breakthrough of ammonia;
- Two UV reactors for primary disinfection;
- One chlorination system using sodium hypochlorite for secondary disinfection; and
- Potable storage tanks and distribution pumps.


2.1.2 Regeneration Water Disposal

As previously mentioned, the original intent was to direct the plant residuals to the new onsite wastewater management system, however, this practice was not recommended by the onsite system supplier. The option to store and haul the residuals from site was also found to be very costly due to the remoteness of the campground.

Thus, it is proposed that the plant’s regeneration water is discharged to the surface for disposal. Residuals from the new treatment process consists of the regeneration water from the ion exchange regeneration process. This flow is to be directed to a manhole outside the plant and then pumped to the slough 30m southwest of the WTP.

Regeneration cycles on the ion exchange units are triggered on volume use; vessel #1 will regenerate after 17,000 L of treated flow; vessel #2 after 10,000 L; and vessel #3 after 30,000 L. Based on the trends in campground use over the season, the frequency and daily volume of regenerations are calculated in **Figure 2-1** below. The chart shows the prediction of the units regenerating one to two times per week in the shoulder season, then peaking upwards of 0.35 to 0.70 m³/day every second day in July and August. There is no flow from mid-September to late-May.

Figure 2-1: Regeneration Cycles and Regeneration Volume per Day



The chart predicts in a given peak year, with full occupancy, the total annual regeneration water discharged could be upwards of 27m³/year. A relatively minor volume over only part of the year.

Table 2-1 is a summary of regeneration water quality from sampling facilities with similar ion exchange processes.


Table 2-1 Projected Regeneration Water Quality

Parameter	Units	Raw Water	Reject Water
pH		7.95	7.95
Alkalinity	mg/L	170	50
Hardness (CaCO ₃)	mg/L	180	1400
Chloride	mg/L	2.0	9000
Colour	TCU	10	20
Sodium	mg/L	2.0	6000
TDS	mg/L	190	15000
Turbidity	NTU	-	10

The plant residuals are to be discharged to the nearby slough that drains into a small creek that drains into a nearby creek that itself drains into a larger wetland to the south.

Figure 2-2 is a map of the discharge point and drainage route.

Figure 2-2: Discharge and Drainage Route



Since the volume of discharge is relatively small and only occurs in summer when the slough and marshlands are flowing, there is a large dilution factor to be expected. The water quality is not that different from concentrate streams from membrane treatment plants, and those types of plants regularly discharge to surface water bodies without having significant adverse effects. Thus, it is anticipated that the residuals stream from this new facility will have negligible effects on the water quality in the marshlands.

2.1.3 Operations and Maintenance

Manitoba Sustainable Development, Parks and Protected Spaces will be responsible for operation and maintenance of the WTP. Moose Lake campground has a water treatment plant operator who will be responsible for plant operation in accordance with their Licence and Regulations.

2.2 CERTIFICATE OF TITLE

The WTP will be located on provincially owned Crown land within the Moose Lake Provincial Park. The land is registered under Her Majesty The Queen.

2.3 EXISTING AND ADJACENT LAND USE

The WTP is located within the camping area. No change to the existing and adjacent lands is planned to occur as a result of this project. The existing lands are used for camping and recreational activities.

2.4 LAND USE DESIGNATION AND ZONING

All of the land comprising Moose Lake Provincial Park has been categorized as a Recreational Development. The main purpose of this land use category is to accommodate recreational development. Zoning for water pipelines on municipal owned land does not apply.

2.5 PROJECT SCHEDULE

The WTP project was completed in 2015, however, it was not in full operation until 2016 with the construction of the new onsite wastewater management system.

2.6 PROJECT FUNDING

The project is funded by Manitoba Sustainable Development, and managed through the Manitoba Water Services Board.

2.7 REGULATORY APPROVALS

The following departments will receive copies of the specifications and plans, for review and approval:

- Office of Drinking Water

2.8 PUBLIC CONSULTATION

Public consultation will not be required as the project does not involve private funding or property.

2.9 STORAGE OF PETROLEUM PRODUCTS AND OTHER CHEMICALS

The contractors will be required to ensure all equipment is to be maintained free of fluid leaks, and in proper operating condition. The contractor shall wash, refuel and service machinery, store fuel and other materials for the equipment away from the water to prevent deleterious substances from entering the water. No fuelling of equipment shall occur within 100 m of the watercourse during construction. If fuelling of large equipment does occur onsite, fuel should be provided by fueling trucks. Logs of refueling volumes should be recorded and spill kits and an emergency response plan shall be prepared for the site which involves spill prevention, notification and response procedures.

During operation of the WTP, no petroleum products are planned to be stored within the building. Sodium hypochlorite and salt will be required to be onsite for the water treatment process and will be stored in a designated area with suitable spill containment.



3 Physical Environment

3.1 PHYSIOGRAPHIC SETTING AND CLIMATE

Moose Lake Campground is located in the southeast corner of Manitoba off of Provincial Highway 308 and near Lake of the Woods and the American border. The project area is a part of the Precambrian Shield physiographic region. The Precambrian Shield stretches from northwestern to southeastern Manitoba and consists of a hummocky terrain of eroded crystalline bedrock, partly to mostly covered by Quaternary deposits (National Ecological Framework for Canada, 2013). Surface elevation generally does not exceed 350 m above sea level with relief seldom exceeding 30 m. Much of the land surface is occupied by swamp and muskeg as drainage is generally poor.

More specifically, the area is underlain by massive, crystalline, acidic, Archean bedrock, forming hummocky, broadly sloping uplands and lowlands (National Ecological Framework for Canada, 2013). Lowlands have lacustrine deposits forming level to undulating clay plains. The area is also interspersed with areas of fluviglacial outwash deposits. Bare rock outcrops are common, and Dystric Brunisols are the dominant soil on sandy morainal veneers and blankets. Mesisolic and Fibrisolic Organic soils can dominate areas while Gray Luvisolic soils are found on exposed clay deposits.

The climate in this ecoregion is more closely identified with the warmer, more humid southeastern mixed forest region, rather than with the colder, drier boreal regions to the north (National Ecological Framework for Canada, 2013). The climatic data was taken from an Environment Canada Weather Station (2014) located in Sprague, MB from 1996 to 2007. This station is the closest active station to Moose Lake Provincial Park.

Table 3-1 Climatic Averages for the Region (1996-2007)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec	Yearly Average
TEMPERATURE (°C)													
Monthly Average	-14.6	-12.3	-5.9	3.9	10.3	16.0	18.9	17.3	12.5	4.9	-3.6	-11.1	3.3
Average Max	-2.7	-0.2	6.1	15	19.1	23.9	28.7	26.5	20.8	12.7	6.1	-1.6	n/a
Average Min	-26.8	-23.4	-17.7	-7.1	0.4	7.5	11.5	8.9	4.1	-4.4	-15	-22.8	n/a
PRECIPITATION (mm)													
Monthly Average	23.0	18.4	23.3	27.9	83.8	121	84.3	77.5	51.4	61.4	30.2	20.0	52.2

* Environment Canada (http://climate.weather.gc.ca/climateData/monthlydata_e.html?timeframe=3&Prov=MB&StationID=10196&mlyRange=1996-02-01|2007-11-01&Year=2007&Month=01&Day=01)

3.2 HYDROGEOLOGY

A summary of the hydrogeology in the Precambrian Shield has been completed by Betcher, Groove and Pupp (1995). They have noted that hydraulic conductivity is typically very low in unfractured crystalline igneous and metamorphic rock. Most ground water movement occurs through secondary features consisting of joints, shears, or faults. There are large variations in the frequency of these secondary features on both a local and a regional scale, making a prediction of their location very difficult. In general, groundwater development from Precambrian rocks is quite limited in Manitoba, because of the small demand for groundwater in this region and the uncertainty, low yield and considerable expense of drilling into igneous and metamorphic rocks.

Most groundwater development in the Precambrian Shield has occurred in cottage areas of southeastern Manitoba, where sand and gravel aquifers are sparsely distributed (Betcher, Groove and Pupp, 1995). Several hundred wells have been completed into these units in this area with reported well yields ranging from “dry” holes to more than 14 L/s. Generally, though, well yields are low, often below 1.0 L/s and ranging from 0.01 to 0.001 L/s/m. Water producing zones can be found at depths in excess of 60 m and often depths of 100 m or more below the bedrock surface.

No information is available on hydrogeology located directly within Moose Lake Provincial Park.

3.3 HYDROLOGY

Lakes, ponds, and sloughs are present throughout the region and occupy shallow depressions. These wetlands appear to be interconnected but there is no drain index information available for Moose Lake Provincial Park to confirm their connectivity. Water from Moose Lake appears to flow northward into a large wetland complex that eventually flows eastward into Lake of the Woods. This large lake straddles the borders of Manitoba, Ontario and Minnesota.

Portions of Moose Lake are a part of a nutrient management zone which has been designated to protect water quality by encouraging responsible nutrient planning. Setback distances from the shoreline of the receiving water body have been set by the Province to regulate the application of materials containing nutrients. The location of the WTP does not fall within these management zones and is therefore not subject to its regulations. Moose Lake is also not considered as vulnerable in the Nutrient Management Regulation (MB SD, date unknown).

There is no running water to the non-modern washrooms at Moose Lake Campground. Wastewater from these washroom facilities is stored in underground tanks and then hauled away from site to the closest wastewater treatment facilities. Treated water is supplied to the modern washroom, and the wastewater from this facility is directed to an onsite wastewater management system (Ecoflo Biofilter).

The WTP is located at the south end of Moose Lake, in the campground area.

3.4 FISH AND FISH HABITAT

Fish habitat is present within Moose Lake with the presence of walleye, northern pike and yellow perch. Moose Lake is quite shallow, with a maximum depth of 5.5 metres (MB Conservation, 2012). The south end of the lake is aerated to help prevent winter-kill of fish in that area. Water level on the lake is maintained through the use of a water control structure that is operated by Manitoba Infrastructure.

3.5 VEGETATION AND WILDLIFE

Moose Lake Campground is within the Lake of the Woods Ecoregion of the Boreal Shield Ecozone (National Ecological Framework for Canada, 2013). Characteristic vegetation in the ecoregion includes trembling aspen, paper birch, and jack pine forests that transition to white spruce, black spruce, and balsam fir dominated stands. Warmer portions of the ecoregion support red and eastern white pine while cooler and wetter sites have black spruce and tamarack. The western limit for red and eastern white pine in Canada is found with this ecoregion.

The extent of wetlands is variable, being most extensive in the vicinity of Lake of the Woods. Treed bowl bogs and peat margin swamps are the predominant wetland types. Characteristic wildlife includes moose, black bear, wolf, lynx, snowshoe hare, and woodchuck. Bird species include ruffed grouse, hooded merganser, pileated woodpecker, bald eagle, turkey vulture, herring gull, and waterfowl.

3.6 SOCIOECONOMIC

The project is located within Moose Lake Provincial Park. The park is funded by the Province of Manitoba and provides recreation, camping, and day use areas to the public. As previously stated, the campground can have a peak of 195 individuals with five campground staff when it is operation from May to September. Fluctuations on the number of people staying at the campground occur from year to year and through the season.

Within the Park, there are also two cottage subdivisions, with 90 road-accessible leased cottage lots, can be found on the east and west sides of Moose Lake along with a resort and outfitting establishment (Silver Birch) along the south end of the lake.

3.7 HERITAGE RESOURCES

The project activities all occur within Moose Lake Provincial Park and primarily occur within previously disturbed or developed areas. The owner would work with Heritage Resources Branch to mitigate any concerns as required.

4 Potential Environmental Effects

An environmental effect includes a change that a project or development may cause to the environment. They may include, but are not limited to effects to:

- Air Quality;
- Soils;
- Surface Water, Fish and Fish Habitat;
- Water Quality;
- Ground Water Levels;
- Vegetation;
- Wildlife Habitat and Vegetation; and
- Socioeconomics aspects of the area.

4.1 AIR QUALITY

Construction activities will create dust and emissions from construction machinery. Dust suppression using water sprays or mists will be used to alleviate potential dust from being raised. Air quality effects from any dust generation during construction would be localized and temporary and is considered to have a low or negligible environmental effect. Emissions from construction equipment will be temporary and minimized by having machinery operating within normal limits and outfitted with mufflers (where application) to reduce air emissions. It is anticipated that during the operation of the WTP there would not be any release of pollutants to the air.

4.2 SOILS

A risk exists, during the construction of the facility, for a spill to occur from construction machinery and vehicle equipment. To reduce this risk storage of fuel, other petroleum products and lubricants will not be permitted within the area of the water supply. Therefore, the risk of occurrence is small based and additionally standard construction best practices for managing clean-up and removal of any impacted soils will be used to prevent any impacts.

During WTP operation activities are limited to regular maintenance activities. Daily checks of the WTP would involve recording readings, making minor adjustments to the plant treatment process, such as regeneration rates and disinfection dosing rates. These activities would have a minimal impact to soils in the area. Potential adverse impacts to soil quality are assessed to be minor.

4.3 SURFACE WATER AND FISH HABITAT

Any potential environmental impacts to surface water and fish habitat are expected to be minor and short term during construction. The majority of the work will take place in a new structure which will house the

water treatment plant. The installation of the residuals discharge line could temporarily increase erosion and sedimentation into a nearby wetland. Standard construction best management practices for sedimentation and erosion control will be implemented during construction to reduce potential effects to aquatic life.

Best management practices for sedimentation and erosion control will be implemented during construction to reduce sediment from entering Moose Lake. No work is expected to take place in proximity to the Lake.

4.4 WATER QUALITY

Impacts to the water quality of Moose Lake will be reduced during construction by using the proper mitigation measures (e.g. following best practices), as previously described.

Moose Lake has an approximate surface area of 639 ha (Google Maps). The plant's residuals discharge is to be directed to a nearby slough that drains into a large marshland to the south. The relatively minor amount of plant residuals water compared to the large volume of water in the marshland is expected to create a large dilution factor. Thus, any impact to water quality in the marshland is expected to be negligible with no expected adverse effects.

4.5 GROUNDWATER LEVELS

The supply of raw water to the WTP will come from two existing nearby groundwater wells. These wells are expected to continue to operate as they have in the past from May to September of each year. The proposed pumping rates for the new WTP are less than the recommended maximum pumping rates for the wells, thus, the potential environmental effects to groundwater resources are assumed to be negligible.

4.6 VEGETATION

The proposed development area at Moose Lake Provincial Park has previously been disturbed and is regularly managed. Best management construction practices were implemented to manage sedimentation and erosion control. The area of disturbance for the installation of the discharge line is minimal. Any areas which were disturbed have been restored to their natural state.

The operating and maintenance activities of the proposed development are minimal and will be restricted to established areas within the park. Potential impacts to vegetation are considered to be negligible.

4.7 WILDLIFE HABITAT AND VEGETATION

The potential effects to wildlife habitat loss were assessed to be negligible as all activities are occurring in areas previously developed.

4.8 NOISE AND VIBRATION

The construction equipment will create noise emissions. Predominately, machinery engines and powered hand tools are expected to be the sources of noise. The noise will be in addition to regular maintenance and park activities, and are expected to be short term and are considered to be minor.

4.9 HUMAN HEALTH AND WELL BEING

Potential adverse effects on the overall human health are considered to be negligible to minor. During construction, short term increases to dust and noise will occur. The construction and operation of the water treatment plant designed to produce treated water to meet current water quality standards is considered to have a positive effect on human health and wellbeing.

4.10 CLIMATE CHANGE

No climate change impacts are expected from the proposed development.



5 Environmental Management Measures

5.1 AIR QUALITY

Well maintained vehicles and equipment and reduction of unnecessarily transportation and idling of vehicles will assist in mitigating air quality impacts.

The control of dust with water sprays or an approved dust suppressant will limit the impact of dust to the air quality. Prompt re-establishment of vegetation disturbed during construction and also limiting certain work to periods of low winds will also help mitigate air quality impacts.

5.2 SOILS

Preparation of an emergency response plan to mitigate potential impacts to soil by contaminants from petroleum products as well as use and availability of on-site spill clean-up equipment and materials, using properly maintained equipment and fuelling procedures.

Minimal ground disturbance is anticipated during the construction phase. The reestablishment of vegetation and backfill of any short trenches or excavations will occur as soon as possible after any disturbance to reduce the loss of soil due to wind or water erosion.

5.3 SURFACE WATER

Surface water issues may be mitigated during construction by redirecting surface run-off, pumping accumulated water to adjacent ditches and installing proper erosion control practices such as silt fences and erosion control blankets.

Properly maintained, operated and fueled equipment will assist with the mitigation of potential fuel or petroleum spills. Regulatory authorities will be notified through the emergency response line and appropriate measures will be taken according to Provincial requirements.

Setback distances of 100m will be used for fueling and refueling purposes from any water courses. Vehicles will stay on established roads and not unnecessarily disturb riparian zones. Any disturbed vegetation will be re-established as soon as possible.

Chlorinated water used to disinfect the water treatment plant or distribution system will be neutralized prior to discharge.

5.4 GROUNDWATER

The same mitigation efforts as described for surface water can be applied to as mitigation measures to reduce potential impact to any groundwater

5.5 VEGETATION AND WILDLIFE

The establishment of re-vegetation will occur as soon as practically possible for disturbed areas. Minimizing laydown areas and construction activities will act as a measure to reduce disturbance to soils, and vegetation. Proper noise control and dust control as previously discussed will be implemented to mitigate potential impacts.

5.6 FISHERIES

Fisheries impacts will be mitigated by controlling run-off and any construction related discharge to the watercourse to reduce potential harmful effects. The work area will be set back from riparian zones. Proper erosion and sedimentation control measures for working near water will be implemented. These measures will limit any short term temporary impact to fisheries.

5.7 NOISE AND VIBRATION

Unnecessary operation of equipment, properly muffled vehicles and equipment on site and properly maintained equipment will be assist in mitigating noise and vibration issues.

5.8 WATER CONSERVATION

Coin operated showers and low flush fixtures will assist in water conservation measures related to the treatment and production of water at Moose Lake Provincial Park.

5.9 RESIDUAL ENVIRONMENTAL EFFECTS

Long-term residual effects are not anticipated, but short term residual effects are considered local, minor in magnitude, short term in duration, and reversible over time after environmental protection and mitigation measures are applied.

6 References

“Betcher, Groove and Pupp, 1995. Groundwater in Manitoba: Hydrogeology, Quality Concerns, Management.” Environment Canada, National Hydrology Research Institute Contribution No. CS-93017. Obtained from https://gov.mb.ca/waterstewardship/reports/groundwater/hg_of_manitoba.pdf

“Bruederlin, Bruno, 2015. Personal communication (email).” Regional Fisheries Biologist. Manitoba Conservation and Water Stewardship, Fisheries Branch. Brandon, MB.

“Environment Canada, Canadian Climate Normals” http://climate.weather.gc.ca/climate_normals

“National Ecological Framework for Canada, 2013.” Ecoregions of Canada, Lake of the Woods Ecoregion. <http://ecozones.ca/english/region/91.html>

MB Conservation, 2012. Moose Lake Provincial Park – Draft Management Plan.
https://www.gov.mb.ca/.../pdf/moose_lake_draft_management_plan.pdf

MB Conservation, date unknown. Vulnerable Water Bodies.
<http://www.gov.mb.ca/waterstewardship/wqmz/vulnerable.html>

ENVIRONMENT ACT PROPOSAL



Appendix A – Drawings

**MANITOBA CONSERVATION &
MANITOBA WATER SERVICES BOARD**



Moose Lake Campground Water Treatment Plant & Facility Upgrades

AE Project No. 2012-4123-01

M.W.S.B. Tender # 1093

Issued for Tender

Sheet No.	Drawing No.	Revision No.	Drawing Title
1	000	0	COVER
2	101	0	SITE PLAN & DETAIL
3	102	0	CAMPGROUND PLAN & DETAIL
4	201	0	SCHEDULES & CODE ANALYSIS
5	202	0	MAIN FLOOR PLAN
6	203	0	ELEVATIONS
7	204	0	SECTION
8	205	0	DETAILS
9	301	0	MAIN FLOOR PLAN
10	302	0	DETAILS
11	401	0	LEGEND
12	402	0	PROCESS FLOW DIAGRAM
13	403	0	WTP MAIN FLOOR PLAN - 3D ISOMETRIC
14	405	0	DETAILS
15	501	0	MAIN FLOOR PLAN - DRAINAGE
16	502	0	MAIN FLOOR PLAN - PLUMBING
17	504	0	MECHANICAL PLUMBING & VENTILATION
18	505	0	DETAILS & SCHEDULES
19	506	0	PRE-ENGINEERED METAL ROOF
20	507	0	DETAILS
21	601	0	SITE PLAN
22	602	0	POWER & LIGHTING PLAN
23	603	0	POWER & SYSTEMS PLAN
24	604	0	SCHEDULES






**Associated
Engineering**

**GLOBAL PERSPECTIVE.
LOCAL FOCUS.**

[Signature]
PROJECT MANAGER

OCT 11, 2012
DATE

DRAWING NUMBER	REV. NO.	SHEET
4123-01-000	0	1 / 24



NO.	DATE	ENG.	BY	SUBJECT	REVISIONS

PROJECT No. 2012-4123-01
SCALE AS SHOWN
DRAWN K. ANDERSON
DESIGNED K. ANDERSON

M.W.S.B. NO. 1093
**MOOSE LAKE CAMPGROUND
WTP & FACILITY UPGRADES**

**MANITOBA CONSERVATION &
M.W.S.B.**

CIVIL
CAMPGROUND PLAN & DETAILS

DRAWING NUMBER 4123-01-102
REV. NO. 0
SHEET 3
24

BUILDING CODE ANALYSIS

- THE BUILDING HAS BEEN DESIGNED IN ACCORDANCE WITH THE 2011 MANITOBA BUILDING CODE, PART 3, FIRE PROTECTION, OCCUPANT SAFETY AND ACCESSIBILITY.
- A. OCCUPANCY CLASSIFICATION (NBC ARTICLE 3.1.2) MAJOR OCCUPANCY GROUP F, BUILDING AREA < 48 SQ.M. (5177 SQ.FT.)
- B. OCCUPANT LOAD (NBC ARTICLE 3.1.17); 2 PERSONS PER PROCESS AREA. IT CAN BE GIVEN THE VALUE OF NO MORE THAN 2 PERSONS WILL OCCUPY THIS BUILDING AT ANY GIVEN TIME.
- C. RASHER FIRE RESISTANCE (NBC ARTICLE 3.8.1.1. (C)) NOT REQUIRED DUE TO NATURE OF OCCUPANCY.
- D. NUMBER AND SPACING OF EGRESS DOORS (NBC ARTICLE 3.3.1.1. (1), (2), (3), (4), (5)) AT LEAST 2 EGRESS DOORS SHALL BE PROVIDED WHEN THE AREA OF A ROOM OR SUITE OR DISTANCE MEASURED WITHIN THE ROOM OR SUITE TO THE NEAREST EGRESS DOOR EXCEEDS THE VALUES IN TABLE 3.3.1.1(A).
- E. NUMBER OF REQUIRED EXITS (NBC ARTICLE 3.4.2.1. (2)) ACCORDING TO TABLE 3.4.2.1.A, FOR AN OCCUPANCY F IS LESS THAN 200 SQ.M. AND TRAVEL DISTANCE LESS THAN 10 M, ONE EXIT IS TO BE PROVIDED.
- F. RESISTANCE TO FIRE FOR EXISTING DOORS (NBC ARTICLE 3.10.1.1) ACCORDING TO TABLE 3.10.1.1, FIRE RESISTANCE RATING IS NOT REQUIRED FOR THE MAIN FLOOR AND ROOF.
- G. FIRE ALARM SYSTEM (NBC ARTICLE 3.2.4.1) A FIRE ALARM IS NOT REQUIRED FOR A LOW HAZARD INDUSTRIAL OCCUPANCY WITH AN OCCUPANT LOAD LESS THAN 75.

GROUP / DIVISION	MAX. AREA OF ROOM	MAX. DISTANCE TO EGRESS DOOR
GROUP F, DIVISION 3	200 SQ.M.	15 M
GREATEST FLOOR AREA (W/P AREA)	= 23 SQ.M.	
GREATEST TRAVEL DISTANCE (W/P AREA)	= 6 M	

ROOM FINISH SCHEDULE

TAG	ROOM	FLOOR			WALL			CEILING		
		MATERIAL	FINISH	HEIGHT	MATERIAL	FINISH	HEIGHT	MATERIAL	FINISH	
101	TREATMENT AREA	CONCRETE	EPDM PAINT	2425	NEW WOOD SHEATHING	FRP PANELS	2425	EXISTING PL. WOOD	PAINT	
102	SHOWER STALL 1	CONCRETE	CERAMIC TILE	2425	WOOD SHEATHING	FRP PANELS	2425	WOOD SHEATHING	FRP PANELS	
103	SHOWER STALL 2	CONCRETE	CERAMIC TILE	2425	WOOD SHEATHING	FRP PANELS	2425	WOOD SHEATHING	FRP PANELS	
104	WASHROOM 1	CONCRETE	CERAMIC TILE	2425	WOOD SHEATHING	FRP PANELS	2425	WOOD SHEATHING	FRP PANELS	
105	WASHROOM 2	CONCRETE	CERAMIC TILE	2425	WOOD SHEATHING	FRP PANELS	2425	WOOD SHEATHING	FRP PANELS	




DOOR SCHEDULE

TAG	LOCATION	DOORS			FRAMES			HARDWARE				
		TYPE	F.F.R.	MATERIAL	FINISH	TYPE	F.F.R.	MATERIAL	FINISH	TYPE	F.F.R.	MATERIAL
1	THERMALLY BROKEN DOOR FRAME	1	INSUL.	STEEL	PAINT	1	P.S.	PAINT	•	•	•	•
2	THERMALLY BROKEN DOOR FRAME	2	INSUL.	STEEL	PAINT	2	P.S.	PAINT	•	•	•	•

DOOR TYPES

1. ALL DOORS TO HAVE 1.5 PARS OF BUTT HINGES.
 2. ALL HARDWARE TO BE KEVED TO MASTER KEYING SYSTEM.
 3. ALL HARDWARE TO BE KEVED TO MASTER KEYING SYSTEM.
 4. ALL EXTERIOR DOORS TO HAVE STOP CHAINS.
 5. ALL EXTERIOR DOORS TO HAVE STOP CHAINS.

ABBREVIATIONS:
 INSUL. = INSULATED
 P.S. = RECESSED STEEL
 F.F.R. = FIRE RESISTANCE RATING





DRAWING
 REDUCED TO
 HALF SIZE

PROJECT NO. 2012-4123-01		M.W.S.B. NO. 1093	
SCALE AS SHOWN	MOOSE LAKE CAMPGROUND		
DRAWN D. YANKECH	WTP & FACILITY UPGRADES		
DESIGNED K. ANDERSON	ARCHITECTURAL SCHEDULES & CODE ANALYSIS		
DRAWING NUMBER 4123-01-201		REV. NO. 0	SHEET 4

MANITOBA CONSERVATION & M.W.S.B.

Associated Engineering

NO.	DATE	ENG.	BY	SUBJECT



TAG	TYPE	MODEL	NOTES
CB	CORNER BENCH		REFER TO SPECIAL PROVISIONS
CH	COAT HOOK		REFER TO SPECIAL PROVISIONS
BBC	BABY CHANGE STATION		REFER TO SPECIAL PROVISIONS
FD	FLOOR DRAIN		REFER TO SPECIAL PROVISIONS
GB	U.S. GRAB BAR	GB-1.42" - GB-2.30" - GB-3" - 19"	REFER TO SPECIAL PROVISIONS
PT	PARTITION		REFER TO SPECIAL PROVISIONS
PTD	PAPER TOWEL DISPENSER		REFER TO SPECIAL PROVISIONS
WB	WASTE BIN		REFER TO SPECIAL PROVISIONS
SC	SHOWER CURTAIN & ROD		REFER TO SPECIAL PROVISIONS
SP	S.S. SHELF		REFER TO SPECIAL PROVISIONS
SI	SINK		REFER TO SPECIAL PROVISIONS
SD	SOAP DISPENSER		REFER TO SPECIAL PROVISIONS
TD	TOILET		REFER TO SPECIAL PROVISIONS
TPD	TOILET PAPER DISPENSER		REFER TO SPECIAL PROVISIONS
WD	WASTE WASTE DISPOSAL		REFER TO SPECIAL PROVISIONS
URN	URN		REFER TO SPECIAL PROVISIONS

PROJECT No. 2012-4123-01		M.W.S.B. NO. 1093	
SCALE AS SHOWN	DRAWN D. YANKECH	MOOSE LAKE CAMPGROUND	
DESIGNED K. ANDERSON		WTP & FACILITY UPGRADES	
ARCHITECTURAL MAIN FLOOR PLAN		DRAWING NUMBER 4123-01-202	REV. NO. 0
SHEET 5		24	

Associated Engineering


MANITOBA CONSERVATION & M.W.S.B.

REVISIONS


NO.	DATE	ENG.	BY	DESCRIPTION

DRAWING REDUCED TO HALF SIZE

NOTES:
 1. LUMBER SHALL BE PRESSURE TREATED (P.T.)
 2. NAILING PATTERNS TO COMPLY WITH TABLE B.2.3.4 IN PART 9 OF THE 2011 MANITOBA BUILDING CODE.



1 ELEVATION 1: INTERIOR WEST WALL 1:25



2 ELEVATION 2: INTERIOR EAST WALL 1:25

DRAWING REDUCED TO HALF SIZE

M.W.S.B. NO. 1093	
MOOSE LAKE CAMPGROUND	
WTP & FACILITY UPGRADES	
DRAWING NUMBER	4123-01-204
REV. NO.	0
SHEET	7
24	

MANITOBA CONSERVATION & M.W.S.B.
 ARCHITECTURAL SECTIONS

PROJECT NO.	2012-4123-01
SCALE	AS SHOWN
DRAWN	D. YANKECH
DESIGNED	K. ANDERSON




REVISIONS	
NO.	DATE
1	DATE
2	DATE
3	DATE
4	DATE
5	DATE
6	DATE
7	DATE
8	DATE
9	DATE
10	DATE


NO.	DATE	ENG.	BY	DESCRIPTION

PROJECT: 2012-4123-01 Moose Lake Campground WTP & Facility Upgrades
 DRAWN: D. YANKECH
 DESIGNED: K. ANDERSON
 PROJECT NO.: 2012-4123-01
 SCALE: AS SHOWN
 SHEET: 7 OF 24

- LAB COUNTER CONSTRUCTION**
1. ALL CONSTRUCTION IS 1/2" PLYWOOD, 5/8" WITH LAMINATE BOTH SIDES AND LAMINATE EDGES - COLOUR: LIGHT GREY
 2. CONCEALED CABLES AND SHELVES THROUGH PLYWOOD ON LAMINATE SIDING
 3. COUNTER TOP FABRIC AND CASINGS ASH, 1/8" THICK PLYWOOD ON INTERNAL RESISTANT LAMINATE SUPPORTS
 4. 1/2" PLYWOOD CASINGS ON 1/2" SPRUCE FRAMING
 5. 3/8" SPRUCE FRAMING WHERE REQUIRED
- TYPICAL HARDWARE**
1. DOORS: JAMNEY FULLS "SICHELIE," No. 5506 METAL FINISH 1/8"
 2. HINGES: AMERICO SYSTEM 4005 CONCEALED ALL METAL, ADJUSTABLE MALL DIRECTION, SELF-CLOSING
 3. SHELF: 3/8" SPRUCE, K-Y IN 2000, 1" WOOD BRACKET WITH 2000, 3" SUPPORT



2 PROFILE LAB COUNTER NTS



1 ELEVATION LAB COUNTER NTS

DRAWING REDUCED TO HALF SIZE

M.W.S.B. NO. 1093	PROJECT NO.	2012-4123-01
MOOSE LAKE CAMPGROUND	SCALE	AS SHOWN
WTP & FACILITY UPGRADES	DRAWN	K. ANDERSON
	DESIGNED	K. ANDERSON
DRAWING NUMBER	REV. NO.	SHEET
4123-01-205	0	8
		24

MANITOBA CONSERVATION & M.W.S.B. ARCHITECTURAL DETAILS


PROJECT NO.	2012-4123-01
SCALE	AS SHOWN
DRAWN	K. ANDERSON
DESIGNED	K. ANDERSON



NO.	DATE	ENG.	BY	DESCRIPTION

SUBJECT	
REVISIONS	

10/10/2019 10:00 AM. Drawing: 4123-01-205. Scale: 1/2" = 1'-0".



PROJECT NO. 2012-01-01		M.W.S.B. NO. 1093																					
SCALE AS SHOWN		MOOSE LAKE CAMPGROUND																					
DRAWN BY D. YANKECH		WTP & FACILITY UPGRADES																					
DESIGNED BY D. YANKECH		DRAWING NUMBER 4123-01-301																					
		REV. NO. 0																					
		SHEET 9																					
		24																					
		MANITOBA CONSERVATION & M.W.S.B.																					
		STRUCTURAL MAIN FLOOR PLAN																					
<table border="1"> <thead> <tr> <th>NO.</th> <th>DATE</th> <th>ENG.</th> <th>BY</th> <th>SUBJECT</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>		NO.	DATE	ENG.	BY	SUBJECT																REVISIONS	
NO.	DATE	ENG.	BY	SUBJECT																			

GENERAL NOTES:


- SITE CONFIRM DIMENSIONS. REPORT DISCREPANCIES TO ENGINEER.
- ALL REINFORCING STEEL TO BE CSA G40.21 (400 MPa) GRADE 400R DEFORMED BARS.
- ALL REINFORCING TO BE KEPT IN ACCORDANCE WITH THE REINFORCING STEEL NOTES.
- ALL REINFORCING TO BE PROPERLY COATED, UNLESS OTHERWISE NOTED.
- ALL REINFORCING TO BE PROPERLY COATED, UNLESS OTHERWISE NOTED.
- ALL REINFORCING TO BE HELD IN PLACE AND TIED BY THE USE OF PROPER ACCESSORIES, SUCH AS CHAIRS, SPACERS, ETC. TO BE SUPPLIED BY THE CONTRACTOR. CHAIRS TO HAVE FOUR LEGS AND BE STAPLED OR NAILED TO THE FORMWORK.
- ALL REINFORCING TO BE HELD IN PLACE AND TIED BY THE USE OF PROPER ACCESSORIES, SUCH AS CHAIRS, SPACERS, ETC. TO BE SUPPLIED BY THE CONTRACTOR. CHAIRS TO HAVE FOUR LEGS AND BE STAPLED OR NAILED TO THE FORMWORK.
- DO NOT FIELD BEND OR FIELD WELD REINFORCEMENT EXCEPT WHERE INDICATED ON DRAWINGS OR AS AUTHORIZED BY ENGINEER.
- CLEAN BARS FREE FROM LOOSE RUST, M.D., OIL, OR OTHER BOND REDUCING CONTAMINANTS.

CONCRETE NOTES:


- ALL CONCRETE IS TO BE MANUFACTURED AND INSTALLED IN ACCORDANCE WITH THE CANADIAN STANDARD SPECIFICATION FOR CONCRETE. REFER TO THE METHODS OF CONCRETE CONSTRUCTION AND CANCSA 342.1 METHOD OF CONCRETE. CANCSA 342.1, ALTERNATIVE 1, TO GIVE FOLLOWING QUALITY FOR ALL CONCRETE: TYPE I PORTLAND CEMENT.
- MINIMUM COMPRESSIVE STRENGTH AT 28 DAYS: 30 MPa.
- TEMPERATURE CORRECTIVE WHEN PLACED AT 15°C TO 20°C NOT ABOVE 25°C.
- MIX DESIGN TO MINIMIZE SHRINKAGE AND TO MAXIMIZE WATER TIGHTNESS.
- PROVIDE ENCLOSED ENCASEMENT FOR THE CONCRETE WHENEVER AIR TEMPERATURE IS BELOW 5°C OR WIND VELOCITY IS ABOVE 15 KM/H.
- TEMPERATURE CORRECTIVE WHEN PLACED AT 15°C TO 20°C NOT ABOVE 25°C.
- FINISH CONCRETE IN ACCORDANCE WITH CANCSA 342.1.

FORMWORK NOTES:


- VERIFY LEVELS AND CENTERLINE BEFORE PROCEEDING WITH FRAMEWORK.
- INSPECT FORMWORK PRIOR TO PLACING CONCRETE TO ENSURE THAT IT IS PROPERLY SUPPORTED AND TIED TO PREVENT DEFLECTION, CRACKING, OR OTHER FOREIGN MATERIALS.




1 DETAIL
STANDARD HOUSEKEEPING PAD




2 DETAIL
STRUCTURAL HOUSEKEEPING PAD



3 DETAIL
CONCRETE SLAB & CURB




4 DETAIL
CONCRETE CONTAINMENT



5 DETAIL
SIDEWALK

DRAWING
REDUCED TO
HALF SIZE

				PROJECT NO: 2012-4123-01	
				SCALE: AS SHOWN	
MANITOBA CONSERVATION & M.W.S.B. MOOSE LAKE CAMPGROUND WTP & FACILITY UPGRADES				DRAWN: D. YANKECH	
				DESIGNED: D. TOWELS	
STRUCTURAL NOTES & DETAILS				DRAWING NUMBER: 4123-01-302	REV. NO: 0
NO.	DATE	ENG.	BY	SUBJECT	REVISIONS



DRAWING
REDUCED TO
HALF SIZE

M.W.S.B. NO. 1093
MOOSE LAKE CAMPGROUND
WTP & FACILITY UPGRADES

MANITOBA CONSERVATION &
M.W.S.B.

PROJECT NO.	20124123-01
SCALE	AS SHOWN
DRAWN	K. ANDERSON
DESIGNED	K. ANDERSON



NO.	DATE	ENG.	BY	SUBJECT


REVISIONS				
NO.	DATE	ENG.	BY	SUBJECT

DRAWING NUMBER
4123-01-402

REV. NO.
0

SHEET
12

TOTAL SHEETS
24



1 DETAIL
 EXHAUST WALL PENETRATION

2 DETAIL
 INTAKE WALL PENETRATION

3 SCHEMATIC
 EXHAUST FAN CONTROL

HEATING & VENTILATION EQUIPMENT SCHEDULE

TAG	DESCRIPTION	LOCATION	TYPE	DESIGN BASIS MAKE/MODEL	HEATING INPUT (kW)	FLOW (L/s)	ESP (Pa)	hp	V/1/2"φ	NOTES
EF001	EXHAUST FAN	WTP ROOM	WALL PROPELLOR	SEL-110-440-E	-	200	65	FRAC		DIRECT DRIVE MOTOR GUARD
MD001	MOTORIZED DAMPER	WTP ROOM	CEILING	GREENHECK SP-430	-	50	65	FRAC	120/80/1	STAINLESS STEEL GRILLE, EXHAUST W/CG, INTERNAL SPEED CONTROL
MD002	MOTORIZED DAMPER	WTP ROOM	ELECTRIC	EQUAL-EE-AIR EASH-100	2,500	-	-	FRAC	120/80/1	COMPLETE WITH SPEED CONTROL
CF001	FLOOR HEAT BOILER	WTP ROOM	CEILING FAN	BOILER	3,000	-	-	FRAC	120/80/1	
B001				LOUN LEB-3				FRAC	240/80/1	

LOUVER, DAMPER & GRILLE SCHEDULE

TAG	DESCRIPTION	LOCATION	SERVICE	TYPE	DESIGN BASIS MAKE/MODEL	WKH	NOTES
MD001	MOTORIZED DAMPER	WTP ROOM	EF-001 EXHAUST	INSUL PARALLEL	TAMCO 9000 BF	300X300	MOTORIZED DAMPER
MD002	MOTORIZED DAMPER	WTP ROOM	EF-001 INTAKE	INSUL PARALLEL	TAMCO 9000 BF	300X300	
S1	DOOR GRILLE	WASHROOM/SHOWER	EF-002 INTAKE	LOUVER FACE ALUM		250X800	PRIVACY-OBSOURED ANODIZED ALUMINUM

DRAWING
REDUCED TO
HALF SIZE

		PROJECT No. 2012-4123-01 SCALE AS SHOWN DRAWN D. YANKECH DESIGNED K. ANDERSON	
		M.W.S.B. NO. 1093 MOOSE LAKE CAMPGROUND WTP & FACILITY UPGRADES	
MANITOBA CONSERVATION & M.W.S.B.		BUILDING MECHANICAL DETAILS & SCHEDULES	
DRAWING NUMBER 4123-01-504		REV. NO. 0	
SHEET 19		24	

NO.	DATE	ENG.	BY	DESCRIPTION

REVISIONS	
NO.	DESCRIPTION

PROJECT NO.	2012-4123-01
SCALE	AS SHOWN
DRAWN	K. ANDERSON
DESIGNED	K. ANDERSON

M.W.S.B. NO. 1093 MOOSE LAKE CAMPGROUND WTP & FACILITY UPGRADES	
MANITOBA CONSERVATION & M.W.S.B.	
BUILDING MECHANICAL PRE-ENGINEERED IN FLOOR HEAT	

DRAWING NUMBER	4123-01-505
REV. NO.	0
SHEET	20

**DRAWING
REDUCED TO
HALF SIZE**

1 PLAN
MAIN FLOOR IN FLOOR HEAT

1:20

Labels in plan: RETURN MANFOLD, CHILTING PUMPS, C-POCK AIR F, SUPPLY MANIFOLD, TUBING ORGANIZER, BLU-OS PREHEATER, COORDINATE WITH NEW CONCRETE AND EXISTING FOOTING, SUPPLY MANIFOLD AND RETURN MANIFOLD, B-001 BOILER MOUNTED TO WALL, EXPANSION TANK OVER BOILER, PUMPS, GLYCOL MAKEUP, TEMPERATURE CONTROL LOOP #1, TEMPERATURE CONTROL LOOP #2, LOOP #1, LOOP #2.




NOTES:

1. IN FLOOR HEAT SYSTEMS PRE-ENGINEERED PACKAGE SUPPLIED BY WISELEY.

COORDINATE INSTALL THROUGH WALL PUMP WITH STAINLESS STEEL PLATE CONNECTION. ANY EXPOSED EQUIPMENT IN WASHROOM.

CROSS IN-TO FLOOR WITH PIPES REBAR IN STRUCTURAL SLAB WITH LUBRICANT MANUFACTURER APPROVED TIE WRAPS. MANIFOLD UNITS RESUMMER CANNOT BE MANIPULATED IN WASHROOM.





NOTES:

- BUILDING IS AS SHOWN. USE SEE-FIT EQUIPMENT UNLESS NOTED OTHERWISE.
- UPGRADE EXISTING 20KV TO 25KV OVERHEAD MAST AND SERVICE.
- WELLS AND CONNECT SEPTIC TANK EQUIPMENT. SERVICE PUMP CONTROLS WITH CONTROL PANEL. MAIN SERVICE MAST LOCATION ON CAMPUS. MAIN SERVICE MAST TO BE INSTALLED WITHIN 10M OF EXISTING MAIN SERVICE MAST. MAIN SERVICE MAST TO BE INSTALLED WITHIN 10M OF EXISTING MAIN SERVICE MAST. MAIN SERVICE MAST TO BE INSTALLED WITHIN 10M OF EXISTING MAIN SERVICE MAST.
- PROVIDE SUPPORT AT WELLS AND ENCLOSURE WITH UNDERGROUND TECK CABLE TO SUPPORT WITH CONTROL PANEL AND ENCLOSURE WITH RECEPTACLE.
- REMOVE EXISTING SERVICE MAST AND RECONNECT EQUIPMENT AS SHOWN.
- ON MAIN SERVICE MAST, COORDINATE WITH LOCAL UTILITY. MAKE TRIP MARK AND PERMANENT ARRANGEMENTS.
- MAKE DETAILED REVIEWS OF BURIED CABLES AND CABLE TRAYS. MAKE DETAILED REVIEWS OF BURIED CABLES AND CABLE TRAYS. MAKE DETAILED REVIEWS OF BURIED CABLES AND CABLE TRAYS.
- MAKE DETAILED REVIEWS OF BURIED CABLES AND CABLE TRAYS. MAKE DETAILED REVIEWS OF BURIED CABLES AND CABLE TRAYS.

DRAWING
REDUCED TO
HALF SIZE

M.W.S.B. NO. 1093		Moose Lake Campground	
WTP & FACILITY UPGRADES		ELECTRICAL SITE PLAN	
DRAWING NUMBER	REV. NO.	0	21
4123-01-601			


MANITOBA CONSERVATION & M.W.S.B.		PROJECT NO. 2012-4123-01	
ELECTRICAL SITE PLAN		SCALE AS SHOWN	
		DRAWN D. ROBINSON	
		DESIGNED D. ROBINSON	

Associated Engineering		PROJECT NO. 2012-4123-01	
78		SCALE AS SHOWN	
		DRAWN D. ROBINSON	
		DESIGNED D. ROBINSON	

REVISIONS		SUBJECT	
NO.	DATE	ENG. BY	DESCRIPTION

1. PLAN SITE 1:50

The Drawing is the Final Contract Document and shall govern over all other drawings.
 No representation is made by the Engineer for any other drawings.



SYMBOL LEGEND

- WALL MOUNT FIXTURE OR BEACON
- ⊕ DUPLEX RECEPTACLE
- ⊙ SPECIAL RECEPTACLE OR EQUIPMENT CONNECTION
- ⊙ JUNCTION BOX
- ⊙ MOTOR
- ⊙ MOTOR STARTER
- ⊙ MOTOR DISCONNECT
- ⊙ MOTORIZED DAMPER
- ⊙ WEATHER PROOF
- PLC PROGRAMMABLE LOGIC CONTROLLER
- HMI HUMAN MACHINE INTERFACE
- CP CONTROL PANEL
- ATS AUTO TRANSFER SWITCH
- MCC MOTOR CONTROL CENTER
- PNL PANELBOARD
- E EXISTING
- APPX APPROXIMATE
- AFF ABOVE FINISHED FLOOR
- AFG ABOVE FINISHED GRADE
- TYP TYPICAL

DRAWING
 REDUCED TO
 HALF SIZE

1 PLAN
 MAIN FLOOR LIGHTING
 1:20

M.W.S.B. NO. 1093
 MOOSE LAKE CAMPGROUND
 WTP & FACILITY UPGRADES

MANITOBA CONSERVATION &
 M.W.S.B.
 ELECTRICAL
 LIGHTING PLAN

PROJECT NO.	2012-4123-01
SCALE	AS SHOWN
DRAWN	D. ROBINSON
DESIGNED	D. ROBINSON



NO.	DATE	ENG.	BY	SUBJECT

REVISIONS				
NO.	DATE	ENG.	BY	SUBJECT

DRAWING NUMBER	4123-01-602
REV. NO.	0
SHEET	22
TOTAL SHEETS	24

Tag	Description	Nº	VA	A	Value	Protection	Control	Feeder	Notes
						COFD Disconnect	Type	Location	Desc
UB-1	Electric Unit Heater	1	2500		250V	15/2	NS/1		2.412
UB-2	Electric Unit Heater	1	2500		250V	15/2	NS/1		2.412
EF-1	Exhaust Fan	1	120V		120V	15/2	OS		2.412
EF-2	Exhaust Fan	1	120V		120V	15/2	OS		2.412
EF-3	Exhaust Fan	1	120V		120V	15/2	OS		2.412
EF-4	Exhaust Fan	1	120V		120V	15/2	OS		2.412
EF-5	Exhaust Fan	1	120V		120V	15/2	OS		2.412
HW-1	Hot water tank	1	13.500		120V	15/2	OS		2.412
HW-2	Hot water tank	1	13.500		120V	15/2	OS		2.412
SWP-1	Raw Water Pump	1	1000		240V	15/2	FVNR		2.412
SWP-2	Raw Water Pump	1	1000		240V	15/2	FVNR		2.412
UV-1	UV System 1	1	1000		240V	15/2	REC		2.412
UV-2	UV System 2	1	1000		240V	15/2	REC		2.412
BWP-1	Backwash Pump	1	240V		202	A	FVNR		2.412
CP-1	Treatment Control Panel	2	120V		151				2.412
CP-2	Distribution Control Panel	2	240V		492				2.412
DP-1	Distribution Pump	1	240V		151		FVNR	CP-02	2.412
DP-2	Distribution Pump	1	240V		151		FVNR	CP-02	2.412
MP-1	Mining Pump - Potassium Perm	2	120V		151	REC	OS	CP-01	2.412
MP-2	Mining Pump - Chrome	2	120V		151	REC	OS	CP-01	2.412
MP-3	Mining Pump - Chrome	2	120V		151	REC	OS	CP-01	2.412
MP-4	Mining Pump - Chrome	2	120V		151	REC	OS	CP-01	2.412

OS/OD - Occupancy Protection Device (ground breaker for typical loads, MOP by typical motor loads). Use when as indicated in Contract Documents.
 REC - Recyclable
 FVNR - Field Vandal Resistant
 VFD - Variable Frequency Drive
 VSSS - Variable Speed Solid State
 SSSS - Solid State Soft Start / Soft Stop
 WNN - Wireless Network Node
 MSN - Motor Starter with thermal overload and pilot light
 OS - Occupancy sensor

LUMINAIRE SCHEDULE

TYPE	DESCRIPTION	LAMP	VOLTAGE	MANUFACTURER	NOTES
A	1x1 FT RECESSED INDOOR TRACK LIGHT	LED - 3000K	120V	WAC LUMINAIRE (SEE X1000/1/1/1) WIRE GUARD (W/G) (SEE)	ACTIVATED ON MOTION NEAR DOOR
B	ALUMINUM RECESSED SURFACE MOUNTED LIGHT FIXTURE	SOLID STATE	120V	FEDERAL SERIAL P/P OR EQUAL	
C	2 LUMINAIRE (RECESSED INDOOR TRACK LIGHT) SURFACE MOUNTED LIGHT FIXTURE (TO BE RELOCATED)	2 T12 (78/94)	120V	CFE1, V1253, 1250 UTAHNIA, DMV 232 (2) METHUEN, V1232DR 130	FIXTURES AND EXHAUST FANS TO BE ACTIVATED ON ENTRY INTO WASHROOMS AND SHOWERS OCCUPANCY SENSOR LEVITON (DSC05-RMV) (ONE PER ROOM)
D	EXISTING LUMINAIRE TO BE RELOCATED				
E	FIVE (5) 1x4 FT RECESSED TRACK LIGHT	3000K HCS	120V		

DRAWING
REDUCED TO
HALF SIZE

M.W.S.B. NO. 1093	PROJECT NO.	2012-4123-01
MOOSE LAKE CAMPGROUND	SCALE	AS SHOWN
WTP & FACILITY UPGRADES	DRAWN	D. ROBINSON
	DESIGNED	D. ROBINSON
DRAWING NUMBER	REV. NO.	0
4123-01-604		24
		24

MANITOBA CONSERVATION &
M.W.S.B.
ELECTRICAL
SCHEDULES

PROJECT NO.	2012-4123-01
SCALE	AS SHOWN
DRAWN	D. ROBINSON
DESIGNED	D. ROBINSON



NO.	DATE	ENG.	BY	REVISIONS

SUBJECT	
ELECTRICAL SCHEDULES	

ENVIRONMENT ACT PROPOSAL



Appendix B – WTP Predesign Report

Predesign Report



MB Conservation

Manitoba Water Services Board

Moose Lake Campground Water Treatment Plant

August 2012



Associated
Engineering

GLOBAL PERSPECTIVE.
LOCAL FOCUS.

CONFIDENTIALITY AND © COPYRIGHT

This document is for the sole use of the addressee and Associated Engineering Ltd. The document contains proprietary and confidential information that shall not be reproduced in any manner or disclosed to or discussed with any other parties without the express written permission of Associated Engineering Ltd. Information in this document is to be considered the intellectual property of Associated Engineering Ltd. in accordance with Canadian copyright law.

This report was prepared by Associated Engineering Ltd. for the account of MB Conservation Manitoba Water Services Board. The material in it reflects Associated Engineering Ltd.'s best judgement, in light of the information available to it, at the time of preparation. Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Associated Engineering Ltd. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Table of Contents

SECTION	PAGE NO.
Executive Summary	i
Table of Contents	ii
List of Tables	iv
List of Figures	v
1 Introduction.....	1
2 Design Considerations.....	3
2.1 Design Population and Water Demand.....	3
2.2 Proposed Water Treatment Plant Capacity	4
2.3 Water Rights Licencing.....	5
2.4 Environment Act Licence.....	5
2.5 Existing Wtp Equipment	5
2.6 Building Mechanical	6
2.7 Design Summary.....	6
3 Water Quality	7
3.1 Raw Water Quality	7
3.2 Treated Water Quality Objectives	8
4 Treatment Plant Technologies	9
4.1 Iron and Manganese Removal.....	9
4.2 Organics Removal.....	10
4.3 Ultraviolet Disinfection	11
4.4 Final Chlorination	11
4.5 Treatment Process Recommendations.....	11
4.6 Process Schematic.....	12
4.7 Equipment Selection	13
5 Peripheral Facilities.....	14
5.1 Structural and Building	14
5.2 Heating and Ventilating	15
5.3 Controls and Instrumentation.....	15
5.4 Hot Water Tanks	16
5.5 Residuals Management.....	16

6	Opinion of Probable Costs	17
7	Closure.....	7-1
	Appendix A – Equipment Cut Sheets	

List of Tables

	PAGE NO.
Table 2.1 – Water Production Rate Comparison	4
Table 2.2 – Existing Equipment List	5
Table 2.3 – System Summary	6
Table 3.1 – Raw Water Quality Summary	7
Table 3.2 – Treatment Objectives	8
Table 4.1 – Chemical Oxidant Summary	9
Table 4.2 – Treatment Equipment Summary	11

List of Figures

	PAGE NO.
Figure 1.1 – Moose Lake Campground Location Map	1
Figure 1.2 – Moose Lake Campground.....	2
Figure 4.1 – Moose Lake Treatment Process.....	12
Figure 5.1 – Proposed Equipment Layout.....	14

1 Introduction

The Moose Lake Campground is located approximately 160 km south east of Winnipeg. The campground consists of 95 sites, 24 of which are serviced with electricity. The campground is currently serviced with five non-modern washrooms with no running water. These washrooms are all connected to holding tanks that are emptied as required. Untreated water is provided at three standpipes throughout the campground that are connected to a groundwater well.


It is MB Conservation's intent to upgrade this campground with a treated water supply and also to provide at least one modern washroom with shower facilities. A second modern washroom with showers shall be a future consideration.

In 2005, a 9.1 m x 5.5 m building was relocated to the campground to be used as a washroom facility and water treatment facility. Two wells were also drilled next to the facility which will provide the source water.

Figure 1.1 – Moose Lake Campground Location Map



Figure 1.2 – Moose Lake Campground



2 Design Considerations

2.1 DESIGN POPULATION AND WATER DEMAND

The Moose Lake campground population will be based on 71 basic and 24 electrified campsites, as well as five campground staff individuals. In discussions with MB Conservation, there are no immediate plans to expand the campground and add more sites. The service population for the design will be based on 95 sites and 5 staff.

Water demand will be based on this serviced population as well as the development of the new modern washroom facility. Considerations will also be given for a future modern washroom facility in the design.

Treated water will be provided to the modern washroom facility as well as seven stand pipes located throughout the campground. The modern washroom facility will include two toilets, two sinks, and two showers. The toilets will be low flow fixtures and the showers will also be low flow but will also be coin operated.

Based on this level of service it is estimated that the average day use will be **55** litres per person per day (L/p/d). Assuming on average **two** individuals per campsite and five staff members, the serviced population is assumed to be **195** individuals.

Daily Demand: 195 persons x 55 L/p/d = **10,450 litres per day demand.**

This number can also be equated in terms of “usage”. 10,450 litres per day is sufficient to provide each individual with 20 litres of water on site and the use of each toilet, sink and shower up to 100 times per day.

Fixture	Consumption	Frequency of use Per Day	Total Volume Consumed Per Day
Individual Use	20 litres per individual	195 individuals	3,900 L
Showers (2)	25 litres per use	100 uses per day per unit	5,000 L
Toilets (2)	6 litres per flush	100 uses per day per unit	1,200 L
Sinks (2)	2 litres per use	100 uses per day per unit	400 L
		TOTAL:	10,500 L

2.2 PROPOSED WATER TREATMENT PLANT CAPACITY

The treatment equipment should then be able to produce **10,450 L** in a day. The design will also be based on being able to produce this volume over an **eight hour** period. Implementing an eight hour production day will allow the park staff to more easily monitor the equipment during regular hours, allow for some peaking factor, as well as provide a production rate that can keep up with full time shower use.

Production rate: $10,450 \text{ L} \div 8 \text{ hours} \times (3,600 \text{ seconds per hour}) = \mathbf{0.35 \text{ L/s (6 usgpm)}}$

Table 2.1 demonstrates that the proposed treatment should be able to meet the demands of the proposed new modern shower facility. However, further improvements to the WTP may be required in the future if a second shower facility is installed (eg. More storage and greater distribution pumping). The Table also shows that the recommended pumping rate per well is sufficient for the anticipated needs.

Table 2.1 – Water Production Rate Comparison

Proposed Equipment Production Rate	0.35 L/s	5.5 usgpm
Recommended pumping rate per well	0.76 L/s	12 usgpm
Two showers operating at 7.6 litres per minute each	0.26 L/s	4 usgpm
Future (four showers operating at once)	0.52 L/s	8 usgpm

2.2.1 Distribution Pumping

The proposed distribution pumping will be two (2) end suction pumps on variable frequency drives (VFD); one duty and one standby. The existing pump on site is too large for the system (0.4 - 1.4 L/s); it would cycle much too frequently on average demand flows. It is proposed to install two smaller (0.1 – 0.7 L/s) pumps that are more suited to the demand flows. A hydro pneumatic tank will also be installed to accommodate the very low flow periods; approximately six toilet flushes in the night before the pump starts. The variable frequency drives will maintain a set pressure in the system and modulate flow from the distribution pumps to suit demands.

2.2.2 Storage Requirements

The on-site storage requirements should be based on providing a minimum **20 minutes** of chlorine contact time. The number of poly tanks that can fit into the existing space will also limit the maximum amount of storage. For poly tanks in series there is a baffling factor of **0.2** to account for short circuiting. Peak usage is assumed to be when both showers are running and some taps are being used. This is assumed to be similar to the production rate of 0.35 L/s.

Storage Requirement: $0.35 \text{ L/s} \times 20 \text{ min.} \times (60 \text{ sec} / \text{min.}) \div 0.2 \text{ baffling factor} = \mathbf{2,100 \text{ Litres}}$

There are two 750 L poly tanks on site, a third will be added to provide a total of 2,250 L of storage.

It is worth noting that this volume of storage is also sufficient to provide 0.5 log inactivation for Giardia at 10°C, pH 8.0 and chlorine dosage at 1.5 mg/L. This is a consideration since the source may be Ground Water Under the Direct Influent (GUDI) of surface water.

2.2.3 Well Pumping

There are currently three pairs of pumps of various sizes on site ranging from 0.3 L/s to 0.6 L/s. One of these pairs will be used for the new process. The flows will have to be verified based on pump set depth and piping. It is expected that the existing ½ HP pumps will have to be removed from the wells and replaced with the ¾ HP pumps on site.

2.2.4 Process Waste Pumping

Backwash waste will be directed to a gravel sump south of the building. Based on the equipment selection, it is likely that the backwash feed pump will provide sufficient head to pump the waste stream to the sump. If the system requires additional pumping, a small submersible pump may be provided.

2.3 WATER RIGHTS LICENCING

Since water consumption does not exceed 25,000 litres per day, a Water Rights Licence is not required.

2.4 ENVIRONMENT ACT LICENCE

An Environment Act Licence may not be required based on the size of the system. In discussion with MB Conservation, AE will submit a process description and they will decide if a full Environment Act Proposal will be required. The contact at MB Conservation does not believe an Environment Act Licence will be difficult to acquire for this facility.

2.5 EXISTING WTP EQUIPMENT

There is currently some process equipment on site in the WTP facility that was purchased in 2005/06 but never put into use. The intent will be to incorporate this equipment into the design if they are suitable. In addition to miscellaneous small diameter PVC valves and fittings, the following is a list of the more significant equipment that will be reutilized:

Table 2.2 – Existing Equipment List

Quantity	Item	Model Description	Rating
(1)	Distribution Pump	Grundfos CR3-8 / 1.5 HP 3Ø	1.0 L/s @ 56m (80 psi)
(1)	VFD for Dist. Pump	Aquavar / 1.5 HP 1Ø	-
(1)	Chemical Feed Pump	LMI AA171-450BI	1.6 Lph @ 9.7 bar (140 psi)
(1)	Hydro Tank	Goulds V45	15 L draw down
(2)	Poly Tanks	-	750 L each
(2)	Well Pump	½ HP- 1Ø (in the wells now)	0.30 L/s
(2)	Well Pump	¾ HP- 1Ø c/w control box	0.44 L/s
(2)	Well Pump	1 HP- 1Ø c/w control box	0.63 L/s

2.5.1 Electrical Service

The current electrical service is 200 Amp single phase power. The circuit panel has 64 circuits with only ten in use at this time. Based on projected loads, the 200 Amp service appears to be adequate and there is also sufficient spares in the panel to accommodate the new systems.

2.6 BUILDING MECHANICAL

The WTP side of the building currently has no ventilation equipment or permanent heat. The upgrades will incorporate an intake louver and exhaust fan in the building as well as two small electric unit heaters.

2.7 DESIGN SUMMARY

The following is a summary of the current system demands, the projected demands, and the capacities of the proposed new equipment.

Table 2.3 – System Summary

Equipment	Comments	Flow Rate
Design Daily Demand	10,450 L/d	0.12 L/s
Peak Instantaneous Flow	Showers and taps running	0.70 L/s
Proposed Treatment Rate	Based on 8 hour operation	0.35 L/s
Well Pumps – Two Existing	2 x ¾ HP 1Ø	0.35 L/s each
Distribution Pumps - Two New Pumps	2 x 1.0-HP, 1Ø on VFD	0.1 to 0.7 L/s each
Two existing and one New Poly Storage Tank	3 x 750 L	2,250 L
Hydro pneumatic Tank on Distribution	1 x 120 L	30 L draw down

3 Water Quality

3.1 RAW WATER QUALITY

The Raw Water Quality from a 2010 sample is summarized in the Table below along with the water quality objectives set forth in the Guidelines for Canadian Drinking Water Quality.

Table 3.1 – Raw Water Quality Summary

Parameter	Units	Raw Water Well #1	Raw Water Well #2	Current Limits (2010 GCDWQ)	Treatment Objective
pH		7.94	7.92	6.5-8.5(AO)	6.5 - 8.5
Alkalinity	mg/L	168	171		
Hardness (CaCO ₃)	mg/L	170	179	200 (PO)	
TDS	mg/L	180	186	500 (AO)	< 500
UV Transmittance	%T	66.1	65.8		> 80
Ammonia, Total (N)	mg/L	0.549	0.758		
Nitrate +Nitrite	mg/L	-	-	45	
TKN	mg/L	0.89	1.13		
Total Organic Carbon	mg/L	7.2	7.7		< 2.0
Arsenic	ug/L	0.55	0.43	10	
Chloride	mg/L	1.85	1.79	250 (AO)	
Colour	TCU	10	10	< 15 TCU	< 5
Fluoride	mg/L	0.19	0.20	1.5	0.80
Iron	mg/L	0.898	0.780	< 0.3 (AO)	< 0.10
Manganese	mg/L	0.106	0.176	< 0.05 (AO)	< 0.05
Turbidity	NTU	2.45	1.17		< 0.3 95% of the time

Abbreviations:

AO = aesthetic objective

SMCL = secondary maximum contaminant level

PO = practical objective

MAC = maximum acceptable concentration

IMAC = interim maximum acceptable concentration

Recent testing in July of 2012 shows relatively similar levels for Iron, Manganese and UVT. The sample data shows that with the exception of turbidity, the raw water meets the health based quality parameters. The elevated turbidity is typically a result of oxidized iron and manganese during the sampling procedure.

UV transmittance is of some concern as it can impact the operation of the UV system. Typically, when the UVT is below 70, many UV systems may tend to alarm as full dosage is not achievable. The low UVT is expected to be the result of the elevated TOC in the source water. Not only can the high TOC levels impact UV performance, they may also present a problem with disinfection by products in the distribution if they are not sufficiently removed through the treatment.

Manganese and iron are the two main parameters that exceed the aesthetic guidelines. The levels are high enough to result in discoloured water and staining of fixtures and laundry. The new treatment process will target these two parameters specifically.

Since the wells are quite shallow and in an unconfined aquifer, they should be considered potentially GUDI and the treatment process should account for turbidity reduction and primary disinfection (UV) for added protection.

3.2 TREATED WATER QUALITY OBJECTIVES

Based on the water quality data, it is recommended that the proposed treatment system address iron and manganese removal, complimented by organics reduction and UV disinfection.

With the assumption that the regulators could classify this aquifer as GUDI, it is recommended that the proposed treatment process include UV disinfection for multi barrier treatment, and to achieve the minimum 3-log credit for Giardia and Cryptosporidium inactivation. The process will target organics reduction prior to UV in order to increase UVT to at least 75%.

Table 3.2 summarizes the treatment objectives for the proposed new process equipment.

Table 3.2 – Treatment Objectives

Parameter	Units	Raw Water	Treatment Objective
pH		7.9	6.5 - 8.5
Iron	mg/L	~ 1.0	< 0.10
Manganese	mg/L	~ 0.20	< 0.05
TOC	mg/L	~7.0	< 3.0
Turbidity*	NTU	1.05	<0.3 95% of the time
UV Disinfection		65% UVT	40 mJ/cm2 RED @ 0.35 L/s UVT objective > 75%

4 Treatment Plant Technologies

4.1 IRON AND MANGANESE REMOVAL

The most common method of removing iron and manganese from municipal drinking water supplies is chemical oxidation followed by filtration. Iron out of groundwater supplies is typically in its soluble form (Fe^{2+}) and needs to be oxidized to the insoluble form (Fe^{3+}) in order to be filtered out. Similarly, manganese in its soluble form (Mn^{2+}) needs to be oxidized to the insoluble form (Mn^{4+}) to be filterable.

Commonly used chemical oxidants in water treatment include oxygen, chlorine, and potassium permanganate. Chlorine dioxide and ozone can also be used as oxidants, but require more complex systems to use.

The ability and effectiveness of an oxidant to convert the soluble forms of iron and manganese to their insoluble forms depends on a variety of factors including overall water chemistry. The selection of the oxidant is also dependant on the filter media selected; many “coated” types of media require potassium permanganate for regeneration.

Table 4.1 is a summary of the pros and cons of the three most common forms of chemical oxidant.

Table 4.1 – Chemical Oxidant Summary

Oxidant	Pros	Cons
Oxygen (Aeration)	<ul style="list-style-type: none"> ✓ No chemicals ✓ Effective for iron removal ✓ Can be effective at stripping other contaminants in the water 	<ul style="list-style-type: none"> ✗ Not effective for manganese oxidation (requires long detention time prior to filtration) ✗ Larger power requirement for blower
Chlorine (sodium Hypochlorite)	<ul style="list-style-type: none"> ✓ Simplifies chemical supply. Residual can be retained after filtration for final disinfection. ✓ Effective for iron removal 	<ul style="list-style-type: none"> ✗ Requires higher dosage for manganese oxidation. Also could be complexed by other constituents in the water. The result is the potential for too high of a residual after filtration. ✗ Not recommended if GAC filters are downstream.

Oxidant	Pros	Cons
Potassium Permanganate	<ul style="list-style-type: none"> ✓ Effective and rapid oxidation of both iron and manganese ✓ Can be used to regenerate greensand media and Manganese oxide coated media 	<ul style="list-style-type: none"> ✗ Need to pay attention to dosing rate. Underfeed and removal efficiency is reduced – Overfeed and the water could be tinted pink. ✗ Regulated chemical. ✗ Messy to work with.

Since the Moose Lake system will be designed to remove iron as well as manganese, the recommended oxidant will be potassium permanganate. It not only will be the oxidant, but will also be used to regenerate the proposed filter media.

During operation of the plant, it will be determined if the system can switch to intermittent regeneration without impacts to manganese removal efficiency. This is essentially stopping the continuous permanganate feed and only uses it during backwashing to regenerate the media. The oxidation and adsorption process then occurs simultaneously in the filter, referred to as contact oxidation. The effectiveness of this is dependent on water chemistry. If feasible, it can simplify operations and chemical use.

Once the iron and manganese is oxidized into a soluble (filterable) form it must be removed by a physical separation process; a filter. Manganese removal below the treated objective of 0.05 mg/L is typically unreliable with standard anthracite and sand media filters. As a result, most manganese removal processes prefer to use a combination of adsorption and physical separation. For the adsorptive process, the filter media needs to be conditioned with potassium permanganate to create a manganese oxide coating on the surface to allow the Fe²⁺ and Mn²⁺ to readily adsorb onto the media. Regular backwashing is required to remove the adsorbed iron and manganese, thus freeing up the media for more adsorption surfaces.

For Moose Lake, it is proposed to use either Green Sand (coated glauconite) or Green Sand Plus (coated anthracite) media for manganese adsorption. The filters would also have an anthracite cap to capture the oxidized iron.

4.2 ORGANICS REMOVAL

Following the greensand filters will be a granular activated carbon (GAC) filter for organic carbon adsorption. The filter will be equipped with a by pass and pressure regulation in order to provide the ability to send a portion of the water stream through the GAC. Having the flexibility to pass only a portion of the flow (50%-70%) through the GAC may extend the life of the media.

4.3 ULTRAVIOLET DISINFECTION

The regulating bodies would likely consider this source potentially GUDI, as it is a shallow unconfined well close to the Lake. It is recommended that the treatment process include UV for primary disinfection. The reactor will be rated to achieve 3-log inactivation of Giardia and Cryptosporidium; minimum 40 mJ/cm² RED @ 0.35 L/s.

4.4 FINAL CHLORINATION

Following UV disinfection, the treated water will then be dosed with chlorine for residual disinfection. Two chemical feed pumps will be provided, one duty and one standby.

4.5 TREATMENT PROCESS RECOMMENDATIONS

Table 4.2 is a summary of the proposed treatment system.


Table 4.2 – Treatment Equipment Summary

Process	Treatment System	Comments
Oxidant	Potassium Permanganate	Will initially be set up as a continuous feed for oxidation and regeneration.
Iron/Manganese Removal Process	Greensand (Plus) Filtration	3 x 325 mm diameter pressure tanks with automatic Fleck control valves. Filtration rate: 5.75 m/hr
Optional Multimedia Filtration	Sand / anthracite filter	If a 150 mm anthracite cap cannot be placed on greensand filters, a polishing filter may be required for turbidity reduction.
Organics Removal	GAC Contactor	1 x 325 mm diameter pressure tank with automatic Fleck control valve. Contact: 3.5 minutes at 100% flow
Primary Disinfection	UV Hallett 15x Crossfire	One unit with spare lamps.
Secondary Disinfection	Chlorine (Sodium Hypochlorite)	Two pumps with degassing heads.

4.6 PROCESS SCHEMATIC

Figure 4.1 is a schematic of the proposed treatment process.

Figure 4.1 – Moose Lake Treatment Process



NOTE: After tender award, the supplier (Aslan) proposed replacing the Greensand and GAC filters with three ion exchange vessels. The ion exchange process was much more effective at removing Ammonia, Manganese, and Organics (improving UVT). Discussions were had with MWSB and Parks and the design change was approved.

4.7 EQUIPMENT SELECTION

The proposed treatment rate is quite small; it is very close to a large residential system, or a small commercial system. As a result, the proposed equipment will be “off the shelf” components that will be assembled by the contractor. All the equipment will be NSF Certified.

4.7.1 Filters

The proposed filters will be structural poly glass vessels. The vessels will either be 0.330 m diameter x 1.37 m tall or 0.355 m x 1.65 m tall re proposed for ease of maintenance and portability.

Top mounted Fleck Control valves (or equal) will be installed on the vessels for feed and backwash control. Backwashing will be manually initiated by the operator.



4.7.2 Chemical Feed Pumps

The proposed chemical feed pumps will be Grundfos ALLDOS DME diaphragm dosing pump. The selection of the pump is based on the low feed rates, simplicity of operation and local support from suppliers. The feed rate is adjustable from 0.0025 to 48 L/h.



4.7.3 UV Reactor

The proposed UV system would be a Hallett 15x. It is rated 55 mJ/cm² at 1.0 L/s and 70% UVT. It is NSF certified and simple to maintain and operate.

The reactor is suited for hard water and elevated iron and manganese levels.



4.7.4 Distribution Pumps

The proposed distribution pumps are two (2) Grundfos vertical multistage centrifugal pumps; Model CR1-9, 1 HP 208-230/3/60. Each pump is rated for 0.1 to 0.7 L/s at 450 kPa (65 psi). The pumps are sized for 100% redundancy; one duty and one standby in alternating operation.

The pumps will each be on a variable frequency drive, Aquavar CPC20071. The drives will not only modulate flow maintaining a set system pressure, but they are also required to convert the single phase power source to the pumps.



4.7.5 Well Pumps

The well pumps are currently on site in the WTP building. The ½ HP pumps in the wells will be changed out with the ¾ HP pumps, along with the starter controls.


5 Peripheral Facilities

5.1 STRUCTURAL AND BUILDING

The equipment will be situated in an existing building in the campground. Some modifications to the building will be made to accommodate the new ventilation and process equipment.

Figure 5.1 is a sketch of the existing floor plan showing the proposed new equipment.

Figure 5.1 – Proposed Equipment Layout



5.2 HEATING AND VENTILATING

The building area currently has no ventilation equipment installed. The upgrades will incorporate a new intake louver and exhaust fan for proper air changes. Two unit heaters will also be installed in the room to keep the area above freezing over the winter. Some of the equipment, though robust, should not be kept below freezing over the winter. This includes some electrical equipment.

Air conditioning and dehumidification are typically not incorporated into these smaller designs due to costs, however, the owner could request the equipment if they have budget.

It is expected that the tanks and piping will sweat in the summer with the colder groundwater. Spill decks and containment will be incorporated into the design to minimize the amount of water that could pool on the floor.

5.3 CONTROLS AND INSTRUMENTATION

In general the control strategy will be kept simple. The treatment equipment will start and stop based on water levels in the storage tanks. The distribution pumps will operate on VFDs to maintain a consistent pressure in the system.

The filter systems will include an automated backwash system that can either be triggered by timer on the control valve or operator initiated.

Influent flows will be monitored by a magnetic flow meter on the raw water line. Flows to distribution will be monitored by a turbine meter for totalizing.

The client will need to confirm what level of alarming will be required for the system, and what the preferred communication method will be (land line or pager – cel phone coverage is poor). It is assumed that the park staff will regularly be visiting the plant throughout the day, or at least driving by the plant. An alarm strobe will be mounted on the building exterior as a visual notification that there is a problem.

At minimum the system should monitor:

- Low distribution pressure
- Low water level
- High water level
- Intrusion alarm
- Low room temperature
- High room temperature

5.4 HOT WATER TANKS

It is proposed to provide two (2) 170 L (45 gal) high efficiency 208V single phase electric water heaters.

Two showers operating at peak usage may require upwards of 120 litres of hot water per hour. This is based on the showers operating at 7.6 litres/min, 10 uses per hour at three minutes each use. This is also based on a ground water temperature of 15⁰C and the showers will be fitted with a mixing valve set to 20⁰C. Two high efficiency hot water tanks can recover approximately 140 litres per hour. Thus, during periods of moderate usage, the system should keep up with the hot water demand.

5.5 RESIDUALS MANAGEMENT

Residuals from the plant will be backwash water from the filters. On average, every two to three days the filters may require a backwash. If all filters are backwashed in one day, the total volume of process waste water discharge is approximately 1.5 m³ to 2.0 m³. This would be an excessive hydraulic loading to the proposed small wastewater treatment system that the campground is considering.

It would be preferable to send the backwash water back to the environment through a gravel sump or manhole south of the WTP.

We are in discussion with MB Conservation to determine if the volume of discharge is sufficiently low enough to not require a full Environment Act Proposal.

6 Opinion of Probable Costs

The following is a preliminary opinion of probable construction costs based on budget pricing from the suppliers and contractor discussions. A much more detailed

Item	Budget
Hydro Electrical Contribution Allowance (likely not required)	\$10,000
Process Treatment Equipment Five (5) polyglass vessels, media, control valves, shipping Backwash pump UV Reactor Shipped loose – assembled by Contractor	\$22,000
Two (2) Distribution Pumps Two (2) Aquavar VFDs Two (2) Harmonic Filters (might be required)	\$9,000
Building Construction Modifications Concrete Sidewalk Openings	\$6,000
HVAC & Mechanical Intake, Exhaust Plumbing Process piping Hot water tanks	\$45,000
Electrical Unit Heaters Lighting Power Distribution Controls and Instrumentation	\$70,000
Sub-total	\$162,000.00
Contingency (~20%)	\$35,000
Total	\$197,000

The following is a preliminary opinion of annual operational costs based on selected equipment and usage rates. It is considered that the treatment equipment will operate only six months of the year.

Item	Annual Budget
Media Replacement for filters (annual amortization) Greensand typically replaced every four years at ~\$2,000. GAC may be replaced every year or two at ~\$350 Multimedia filters typically replaced every five years at ~\$250	\$1,000
Treatment Chemicals Potassium Permanganate Sodium Hypochlorite	\$1,000
Miscellaneous Consumables UV Lamps Pump maintenance kits Chemical feed pump maintenance kits	\$500
Asset Amortization (Depreciation over 10 years)	\$3,000
<i>Hydro for treatment equipment and pumps only</i>	~\$4,000
<i>Hydro for building and Hot Water Tanks</i>	~\$2,000
Sub-total	\$11,500.00
Contingency (~20%)	\$2,000
Total	\$13,500 / year

7 Closure

This report was prepared for the MB Conservation Manitoba Water Services Board to provide a conceptual design for upgrades to their existing WTP.

The services provided by Associated Engineering Ltd. in the preparation of this report were conducted in a manner consistent with the level of skill ordinarily exercised by members of the profession currently practicing under similar conditions. No other warranty expressed or implied is made.

Respectfully submitted,
Associated Engineering Ltd.

A handwritten signature in blue ink, appearing to read "K. Anderson".

Ken Anderson, P. Eng.
Project Manager

Driller's Report

Well Location	QTR SEC TWP RGE E <input checked="" type="checkbox"/> W <input type="checkbox"/>	GPS Reading
	R. Lot Parish	N 49° 11' 38" W 95° 19' 42" Location Sketch of Well
Well Owner	Remarks Moose Lake Name Manitoba Conservation Address Box 70	
Well Identification	Sprague, MB. R0A 120 Phone _____ N.E. Side of pump house	Location Sketch of Well
Well Use	Production <input checked="" type="checkbox"/> Test Well <input type="checkbox"/> Recharge <input type="checkbox"/> Observation <input type="checkbox"/>	
Water Use	Domestic <input checked="" type="checkbox"/> Livestock <input type="checkbox"/> Industrial <input type="checkbox"/> Irrigation <input type="checkbox"/> Air-condition <input type="checkbox"/> Other <input type="checkbox"/> Specify _____	
Date well completed	September 13 2005	

Depth Below Ground in Feet	DESCRIPTION WELL LOG	Water Record
0 2	Sod and Sandy Brown Till	
2 12	Medium to Course Sand	
12 14	Grey Till	
14 40	Fine Grey Sand	

WELL CONSTRUCTION											
Depth Below Ground Level	Casing	Open Hole	Perforations	Gravel Pack	Casing Grout	Inside Diameter	Outside Diameter	Screen Slot size	TYPE	MATERIAL	MAKE
0 21	X						5 5/2		Insert Glued	PVC	
21 26			X					25	Stainless steel screen		
15 30				X					20-40 Grade Silica Sand		
0 15					X				Enviroplug Grout		

Top of Casing 2 Feet above Below

REMARKS: **Well must be vented**

PUMPING TEST	CONTRACTOR
Date of Test: September 13 2005	License Number 594 5
Pumping <input checked="" type="checkbox"/> Flowing <input type="checkbox"/> Rate 18 I.G.P.M.	Name Friesen Drillers Ltd.
Water level before pumping 3 Above <input type="checkbox"/> Below <input checked="" type="checkbox"/>	Address Box 1, Grp. 15, R.R.#1 Steinbach, MB. R5G 1L9
Pumping level at end of test 21 Above <input type="checkbox"/> Below <input checked="" type="checkbox"/>	Drill Operator Jim Shoemaker
Duration of test 1/2 HRS Minutes	
Recommended pumping rate 10 I.G.P.M. (12 u.s.g.p.m.)	
With pump intake at 21 Feet below ground level	

PROVINCE OF MANITOBA
THE MANITOBA WATER SERVICES BOARD

PROJECT No.

SCHEME

Moose Lake Park

DATE


June/05

SHEET

OF

ENGINEER A. Pedersen

Testing Area ML 78-1



SWL ~ 6 feet

Test with 2-inch suction pump for 1/2 hour

Campground Tips

- Be sure matches are extinguished. Break them in half before discarding.
- Build no fires except in a designated firepit or use a camp stove. Before leaving make sure your fire is completely out.
- Be careful with your cigarettes, cigars and pipe ashes. Crush them thoroughly before discarding. Never toss them from a vehicle.
- Please! Do not litter.
- Be sensitive to wildlife. Bears can be dangerous and should not be fed. Food must be stored away from your campsite, preferably in a locked vehicle, to avoid attracting hungry animals. Do not store food in your tent.
- Warm clothing is needed for cool nights.
- The use of insect repellent will add to your comfort.
- Learn to recognize and avoid poisonous plants such as poison ivy.
- In case of injury or illness contact a Campground Attendant or Park Patrol Officer. They can assist you to reach medical help.
- Canoeists and hikers travelling in backcountry areas should advise a friend of their intended destination and anticipated length of trip.
- Backcountry camping is only allowed at designated campsites.
- It is illegal to use or transport elm firewood.
- Out of Province Firewood can spread harmful pests and destroy our forests - buy it locally, burn it locally.

● Home of a provincially rare stand of white pine trees



A perfect lakeside location, Moose Lake Campground offers 24 electrical sites and 72 regular sites. A picnic shelter and popular play areas make Moose Lake a great place to get away for a weekend with the family. For summertime fun, the campground has many outdoor activities including a horseshoe pitch, two volleyball courts, excellent fishing and watersports.

Take a leisurely stroll along the long beach on the shore of Moose Lake. Bring your tackle box and rod and go fishing off the sand or in a boat. The boat dock and launch are in the campground. The convenience store is located within the park at the Silver Birch Resort.


The park is home to a provincially rare stand of white pine trees. Though common in Ontario, they reach their western limit from here to the southern Whiteshell.

160 kms from Winnipeg. Travel south on highway #12 then turn left onto Provincial Road #308, for 35 kilometers.

More information on Moose Lake Campground and Moose Lake Provincial Park is available on request from the park office.

Moose Lake Campground

Moose Lake Provincial Park




NOTE:

- For campsite and group use reservations: www.manitobaparks.com or 1-888-4U2-Camp (1-888-482-2267). In Winnipeg call 204-948-3333.
- Remember, a Park Vehicle Permit is required and must be displayed year round.
- For more information or last minute campsite availability call 1-800-214-6497. In Winnipeg call 204-945-6784 or visit us at: www.manitobaparks.com
- IN CASE OF EMERGENCY, use land line to contact Manitoba 911 (RCMP: 204-437-2135) (Ambulance: 204-425-3222)

LEGEND

	ACCOMMODATION		HIKING TRAIL		REFUSE DISPOSAL
	BEACH / SWIMMING UNSUPERVISED		HORSESHOE PITCH		SHOWER (COIN-OPERATED)
	BOAT-LAUNCH		LIFE JACKET LOAN KIOSK		TRAILER SANITARY STATION
	FIREWOOD (CONCESSIONAIRE)		PARKING		VOLLEYBALL COURT
	FISH CLEANING AREA		PUBLIC TELEPHONE		WASHROOMS (NON-MODERN)
	GAS STATION		PICNIC SHELTER		WASHROOMS (MODERN)
	GROCERY STORE		PLAYGROUND		WATER SUPPLY
	ELECTRICAL SERVICE				





Environmental Division

Certificate of Analysis

Eastern

ATTN: WILLIAM PREVOST

MOOSE LAKE PROV PARK
BOX 70
SPRAGUE MB R0A 1Z0

Report Date: 04-MAY-10 13:01 (MT)

Version: FINAL

Lab Work Order #: L879229

Date Received: 21-APR-10

Project P.O. #: NOT SUBMITTED

Job Reference: MOOSE LAKE PROV PARK

Legal Site Desc:

CofC Numbers:

Other Information:

Comments:

Paul Nicolas
Account Manager

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL WITHOUT THE WRITTEN AUTHORITY OF THE LABORATORY.
ALL SAMPLES WILL BE DISPOSED OF AFTER 30 DAYS FOLLOWING ANALYSIS. PLEASE CONTACT THE LAB IF YOU
REQUIRE ADDITIONAL SAMPLE STORAGE TIME.

ALS LABORATORY GROUP ANALYTICAL REPORT

Sample Details/Parameters	Result	Qualifier*	D.L.	Units	Extracted	Analyzed	Batch
L879229-1 1) MOOSE LAKE PUMP STATION - WELL 1							
Sampled By: BILL PREVOST on 21-APR-10 @ 11:00							
Matrix: WATER - UNTREATED WELL							
MB Conservation test 72D							
Alkalinity							
Alkalinity, Total (as CaCO3)	168		1.0	mg/L		03-MAY-10	R1247297
Bicarbonate (HCO3)	206		2.0	mg/L		03-MAY-10	R1247297
Carbonate (CO3)	<0.60		0.60	mg/L		03-MAY-10	R1247297
Hydroxide (OH)	<0.40		0.40	mg/L		03-MAY-10	R1247297
Ammonia-N Low Level							
Ammonia-N	0.549		0.0050	mg/L		03-MAY-10	R1246714
Chloride Dissolved							
Chloride (Cl) - Dissolved	1.85		0.40	mg/L	21-APR-10	28-APR-10	R1244125
Conductivity							
Conductivity	300		0.40	umhos/cm		22-APR-10	R1240807
Fluoride, Dissolved							
Fluoride (F) - Dissolved	0.19		0.10	mg/L	21-APR-10	27-APR-10	R1243563
Hardness Calculated							
Hardness (as CaCO3)	170		0.30	mg/L		23-APR-10	
Ion Balance Calculation							
Ion Balance	102			%		04-MAY-10	
TDS (Calculated)	166			mg/L		04-MAY-10	
Hardness (as CaCO3)	170			mg/L		04-MAY-10	
Langelier Index 4C							
Langelier Index (4 C)	0.13					04-MAY-10	
Langelier Index 60C							
Langelier Index (60 C)	0.90					04-MAY-10	
Nitrate+Nitrite-N							
Nitrate+Nitrite-N	<0.0060		0.0060	mg/L		23-APR-10	R1242026
Sulphate Dissolved							
Sulphate (SO4) - Dissolved	2.1		2.0	mg/L	21-APR-10	28-APR-10	R1244380
Total Carbon							
Total Carbon	46.5		1.0	mg/L		22-APR-10	R1240472
Total Dissolved Solids							
Total Dissolved Solids	180		5.0	mg/L		23-APR-10	R1242227
Total Inorganic Carbon							
Total Inorganic Carbon	39.3		1.0	mg/L		22-APR-10	R1240472
Total Metals by ICP-MS							
Aluminum (Al)-Total	0.0431		0.0050	mg/L	22-APR-10	22-APR-10	R1240945
Antimony (Sb)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Arsenic (As)-Total	0.00055		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Barium (Ba)-Total	0.0254		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Beryllium (Be)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Bismuth (Bi)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Boron (B)-Total	0.015		0.010	mg/L	22-APR-10	22-APR-10	R1240945
Cadmium (Cd)-Total	<0.000010		0.000010	mg/L	22-APR-10	22-APR-10	R1240945
Calcium (Ca)-Total	40.5		0.10	mg/L	22-APR-10	22-APR-10	R1240945
Cesium (Cs)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Chromium (Cr)-Total	<0.0010		0.0010	mg/L	22-APR-10	22-APR-10	R1240945
Cobalt (Co)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Copper (Cu)-Total	0.00035		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Iron (Fe)-Total	0.898		0.020	mg/L	22-APR-10	22-APR-10	R1240945
Lead (Pb)-Total	0.000413		0.000090	mg/L	22-APR-10	22-APR-10	R1240945
Lithium (Li)-Total	0.0056		0.0020	mg/L	22-APR-10	22-APR-10	R1240945
Magnesium (Mg)-Total	16.7		0.010	mg/L	22-APR-10	22-APR-10	R1240945
Manganese (Mn)-Total	0.106		0.00030	mg/L	22-APR-10	22-APR-10	R1240945

* Refer to Referenced Information for Qualifiers (if any) and Methodology.

ALS LABORATORY GROUP ANALYTICAL REPORT

Sample Details/Parameters	Result	Qualifier*	D.L.	Units	Extracted	Analyzed	Batch
L879229-1 1) MOOSE LAKE PUMP STATION - WELL 1							
Sampled By: BILL PREVOST on 21-APR-10 @ 11:00							
Matrix: WATER - UNTREATED WELL							
Total Metals by ICP-MS							
Molybdenum (Mo)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Nickel (Ni)-Total	<0.0020		0.0020	mg/L	22-APR-10	22-APR-10	R1240945
Phosphorus (P)-Total	<0.20		0.20	mg/L	22-APR-10	22-APR-10	R1240945
Potassium (K)-Total	1.79		0.020	mg/L	22-APR-10	22-APR-10	R1240945
Rubidium (Rb)-Total	0.00415		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Selenium (Se)-Total	<0.0010		0.0010	mg/L	22-APR-10	22-APR-10	R1240945
Silicon (Si)-Total	4.81		0.050	mg/L	22-APR-10	22-APR-10	R1240945
Silver (Ag)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Sodium (Na)-Total	1.89		0.030	mg/L	22-APR-10	22-APR-10	R1240945
Strontium (Sr)-Total	0.0605		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Tellurium (Te)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Thallium (Tl)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Thorium (Th)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Tin (Sn)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Titanium (Ti)-Total	0.00152		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Tungsten (W)-Total	<0.0010		0.0010	mg/L	22-APR-10	22-APR-10	R1240945
Uranium (U)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Vanadium (V)-Total	0.00055		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Zinc (Zn)-Total	<0.0050		0.0050	mg/L	22-APR-10	22-APR-10	R1240945
Zirconium (Zr)-Total	<0.00040		0.00040	mg/L	22-APR-10	22-APR-10	R1240945
Total Organic Carbon							
Total Organic Carbon	7.2		1.0	mg/L		22-APR-10	R1240472
True Colour							
Color, True	10.0		5.0	T.C.U.		21-APR-10	R1239943
Turbidity							
Turbidity	2.45		0.10	NTU		21-APR-10	R1239944
pH							
pH	7.94		0.10	pH units		22-APR-10	R1240807
ODW test 695 VOC+BTX							
Volatile Organic Compounds							
1,1,1-Trichloroethane	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
1,1,2-Trichloroethane	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
1,1-Dichloroethylene	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
Benzene	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
Dichloromethane	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
Ethyl Benzene	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
m+p-Xylenes	<1.0	VC:RHS	1.0	ug/L		24-APR-10	R1241626
MTBE	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
o-Xylene	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
Tetrachloroethylene	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
Toluene	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
Trichloroethylene	<0.50	VC:RHS	0.50	ug/L		24-APR-10	R1241626
Xylenes (Total)	<1.5		1.5	ug/L		24-APR-10	R1241626
Miscellaneous Parameters							
Total Kjeldahl Nitrogen	0.89		0.20	mg/L	21-APR-10	23-APR-10	R1241405
Transmittance, UV (254 nm)	66.1		1.0	% T	26-APR-10	26-APR-10	R1242679
L879229-2 2) MOOSE LAKE PUMP STATION - WELL 2							
Sampled By: BILL PREVOST on 21-APR-10 @ 11:00							
Matrix: WATER - UNTREATED WELL							
MB Conservation test 72D							
Alkalinity							

* Refer to Referenced Information for Qualifiers (if any) and Methodology.

ALS LABORATORY GROUP ANALYTICAL REPORT

Sample Details/Parameters	Result	Qualifier*	D.L.	Units	Extracted	Analyzed	Batch
L879229-2	2) MOOSE LAKE PUMP STATION - WELL 2						
Sampled By:	BILL PREVOST on 21-APR-10 @ 11:00						
Matrix:	WATER - UNTREATED WELL						
Alkalinity							
Alkalinity, Total (as CaCO3)	171		1.0	mg/L		03-MAY-10	R1247297
Bicarbonate (HCO3)	209		2.0	mg/L		03-MAY-10	R1247297
Carbonate (CO3)	<0.60		0.60	mg/L		03-MAY-10	R1247297
Hydroxide (OH)	<0.40		0.40	mg/L		03-MAY-10	R1247297
Ammonia-N Low Level							
Ammonia-N	0.758		0.0050	mg/L		03-MAY-10	R1246714
Chloride Dissolved							
Chloride (Cl) - Dissolved	1.79		0.40	mg/L	21-APR-10	28-APR-10	R1244125
Conductivity							
Conductivity	304		0.40	umhos/cm		22-APR-10	R1240807
Fluoride, Dissolved							
Fluoride (F) - Dissolved	0.20		0.10	mg/L	21-APR-10	27-APR-10	R1243563
Hardness Calculated							
Hardness (as CaCO3)	179		0.30	mg/L		23-APR-10	
Ion Balance Calculation							
Ion Balance	107			%		04-MAY-10	
TDS (Calculated)	171			mg/L		04-MAY-10	
Hardness (as CaCO3)	179			mg/L		04-MAY-10	
Langelier Index 4C							
Langelier Index (4 C)	0.13					04-MAY-10	
Langelier Index 60C							
Langelier Index (60 C)	0.90					04-MAY-10	
Nitrate+Nitrite-N							
Nitrate+Nitrite-N	<0.0060		0.0060	mg/L		23-APR-10	R1242026
Sulphate Dissolved							
Sulphate (SO4) - Dissolved	2.3		2.0	mg/L	21-APR-10	28-APR-10	R1244380
Total Carbon							
Total Carbon	48.1		1.0	mg/L		22-APR-10	R1240472
Total Dissolved Solids							
Total Dissolved Solids	186		5.0	mg/L		23-APR-10	R1242227
Total Inorganic Carbon							
Total Inorganic Carbon	40.4		1.0	mg/L		22-APR-10	R1240472
Total Metals by ICP-MS							
Aluminum (Al)-Total	0.0263		0.0050	mg/L	22-APR-10	22-APR-10	R1240945
Antimony (Sb)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Arsenic (As)-Total	0.00043		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Barium (Ba)-Total	0.0321		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Beryllium (Be)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Bismuth (Bi)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Boron (B)-Total	0.017		0.010	mg/L	22-APR-10	22-APR-10	R1240945
Cadmium (Cd)-Total	<0.000010		0.000010	mg/L	22-APR-10	22-APR-10	R1240945
Calcium (Ca)-Total	42.0		0.10	mg/L	22-APR-10	22-APR-10	R1240945
Cesium (Cs)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Chromium (Cr)-Total	<0.0010		0.0010	mg/L	22-APR-10	22-APR-10	R1240945
Cobalt (Co)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Copper (Cu)-Total	0.00039		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Iron (Fe)-Total	0.780		0.020	mg/L	22-APR-10	22-APR-10	R1240945
Lead (Pb)-Total	0.000338		0.000090	mg/L	22-APR-10	22-APR-10	R1240945
Lithium (Li)-Total	0.0053		0.0020	mg/L	22-APR-10	22-APR-10	R1240945
Magnesium (Mg)-Total	17.9		0.010	mg/L	22-APR-10	22-APR-10	R1240945
Manganese (Mn)-Total	0.176		0.00030	mg/L	22-APR-10	22-APR-10	R1240945
Molybdenum (Mo)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945

* Refer to Referenced Information for Qualifiers (if any) and Methodology.

ALS LABORATORY GROUP ANALYTICAL REPORT

Sample Details/Parameters	Result	Qualifier*	D.L.	Units	Extracted	Analyzed	Batch
L879229-2 2) MOOSE LAKE PUMP STATION - WELL 2							
Sampled By: BILL PREVOST on 21-APR-10 @ 11:00							
Matrix: WATER - UNTREATED WELL							
Total Metals by ICP-MS							
Nickel (Ni)-Total	<0.0020		0.0020	mg/L	22-APR-10	22-APR-10	R1240945
Phosphorus (P)-Total	<0.20		0.20	mg/L	22-APR-10	22-APR-10	R1240945
Potassium (K)-Total	2.16		0.020	mg/L	22-APR-10	22-APR-10	R1240945
Rubidium (Rb)-Total	0.00408		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Selenium (Se)-Total	<0.0010		0.0010	mg/L	22-APR-10	22-APR-10	R1240945
Silicon (Si)-Total	5.47		0.050	mg/L	22-APR-10	22-APR-10	R1240945
Silver (Ag)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Sodium (Na)-Total	2.09		0.030	mg/L	22-APR-10	22-APR-10	R1240945
Strontium (Sr)-Total	0.0655		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Tellurium (Te)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Thallium (Tl)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Thorium (Th)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Tin (Sn)-Total	<0.00020		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Titanium (Ti)-Total	0.00096		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Tungsten (W)-Total	<0.0010		0.0010	mg/L	22-APR-10	22-APR-10	R1240945
Uranium (U)-Total	<0.00010		0.00010	mg/L	22-APR-10	22-APR-10	R1240945
Vanadium (V)-Total	0.00037		0.00020	mg/L	22-APR-10	22-APR-10	R1240945
Zinc (Zn)-Total	<0.0050		0.0050	mg/L	22-APR-10	22-APR-10	R1240945
Zirconium (Zr)-Total	<0.00040		0.00040	mg/L	22-APR-10	22-APR-10	R1240945
Total Organic Carbon							
Total Organic Carbon	7.7		1.0	mg/L		22-APR-10	R1240472
True Colour							
Color, True	10.0		5.0	T.C.U.		21-APR-10	R1239943
Turbidity							
Turbidity	1.17		0.10	NTU		21-APR-10	R1239944
pH							
pH	7.92		0.10	pH units		22-APR-10	R1240807
ODW test 695 VOC+BTX							
Volatile Organic Compounds							
1,1,1-Trichloroethane	<0.50		0.50	ug/L		24-APR-10	R1241626
1,1,2-Trichloroethane	<0.50		0.50	ug/L		24-APR-10	R1241626
1,1-Dichloroethylene	<0.50		0.50	ug/L		24-APR-10	R1241626
Benzene	<0.50		0.50	ug/L		24-APR-10	R1241626
Dichloromethane	<0.50		0.50	ug/L		24-APR-10	R1241626
Ethyl Benzene	<0.50		0.50	ug/L		24-APR-10	R1241626
m+p-Xylenes	<1.0		1.0	ug/L		24-APR-10	R1241626
MTBE	<0.50		0.50	ug/L		24-APR-10	R1241626
o-Xylene	<0.50		0.50	ug/L		24-APR-10	R1241626
Tetrachloroethylene	<0.50		0.50	ug/L		24-APR-10	R1241626
Toluene	<0.50		0.50	ug/L		24-APR-10	R1241626
Trichloroethylene	<0.50		0.50	ug/L		24-APR-10	R1241626
Xylenes (Total)	<1.5		1.5	ug/L		24-APR-10	R1241626
Miscellaneous Parameters							
Total Kjeldahl Nitrogen	1.13		0.20	mg/L	21-APR-10	23-APR-10	R1241405
Transmittance, UV (254 nm)	65.8		1.0	% T	26-APR-10	26-APR-10	R1242679

* Refer to Referenced Information for Qualifiers (if any) and Methodology.