

File No.: 5951.00

EABDirector@gov.mb.ca

October 18, 2023

Chris Carroll Manager of Wastewater Services Division City of Winnipeg 109-1199 Pacific Avenue Winnipeg MB R3E 3S8 ccarroll@winnipeg.ca

Dear Chris Carroll:

Re: Environment Act Licence No. 3377 - Notice of Alteration Request

Thank you for your notice of alteration dated May 12, 2023. The department understands you wish to have the biosolids sampling criteria as described in Schedule A of Environment Act Licence No. 3377 altered such that required sampling and analysis activities could be less labour intensive while providing representative composite samples.

I approve the alteration per Section 14(2) of The Environment Act with the condition that the opening paragraph of the current Schedule A to this licence be replaced as follows:

• Every two weeks during which time biosolids are being removed from the Licensee's treatment facility for application to land in that year, a representative composite sample of biosolids shall be formed of approximately equal quantities of biosolids samples taken from each operating biosolids centrifuge on a minimum of eight separate days during each such two-week period.

All other clauses of Environment Act Licence No. 3377 remain in effect. This approval is available on the public registry at https://www.gov.mb.ca/sd/eal/registries/index.html.

If you have any questions regarding this approval, please contact Robert Boswick, Senior Environmental Engineer, Environmental Approvals Branch, at <u>Robert.Boswick@gov.mb.ca</u> or 204-918-5853.

For questions relating to the ongoing administration of the licence, please contact Sonja Bridges, Acting Regional Supervisor, Environmental Compliance and Enforcement Branch, at <u>envcewinnipeg@gov.mb.ca</u> or 204-918-4271.

Sincerely,

Original Signed By Agnes Wittmann Director The Environment Act

c. M. Paetkau – Water and Waste K. Barenz – Water and Waste D. Keam – WSP Canada Robert Boswick Sonja Bridges