



## Sustainable Development

Environmental Stewardship Division  
Environmental Approvals Branch  
1007 Century Street, Winnipeg, Manitoba R3H 0W4  
T 204 945-8321 F 204 945-5229  
[www.gov.mb.ca/sd](http://www.gov.mb.ca/sd)

**CLIENT FILE NO.: 6012.00**

October 4, 2019

Stephanie Backhouse  
Environmental Licensing and Protection  
Manitoba Hydro  
360 Portage Avenue (16)  
Winnipeg MB R3C 0G8  
[SBackhouse@hydro.mb.ca](mailto:SBackhouse@hydro.mb.ca)

Dear Ms. Backhouse:

This is in response to your email of October 1, 2019 to Bruce Webb of this branch concerning clarifications on several clauses of Environment Act Licence No. 3297.

With respect to Clause 1 c) of the Licence, thank you for the notification concerning the removal of treated well water to the outdoor tanks as part of the project. Accordingly, as you have noted, upgrades to the aeration building are no longer required and are no longer part of the project.

With respect to Clauses 17 c) and 25 e) of the Licence, I concur with your request to determine the total phosphorus of the effluent on the basis of a six month rolling average (Clause 17 c)), since effluent samples will be collected monthly (Clause 25 e)).

With respect to Clauses 21 and 22 c) of the Licence, I concur that the determination of total residual chlorine is obtained from a meter on-site, and is not determined in an accredited laboratory.

Thank you for seeking clarification on these matters.

Sincerely,

Siobhan Burland Ross, M. Eng., P. Eng.  
Director, Environment Act

- c. S. Kohler /P. Crocker/C. Huculak: Environmental Compliance and Enforcement  
B. Webb: Environmental Approvals  
Public Registries