

## Yazon, Edwin (CC)

---

**From:** Fagan, Paul (CC)  
**Sent:** June 1, 2020 11:06 AM  
**To:** Yazon, Edwin (CC)  
**Subject:** RE: Request for Review/Comment - DGHTAL 6050.00 - Municipality of Brenda-Waskada  
- Waskada Recycling Centre Hazardous Waste Depot

Hi Edwin

Manitoba Conservation and Climate has reviewed the aforementioned DGHTAL 6050.00 application and has no concerns at this time

Thank you

**Paul Fagan B.Sc.**

Environment Officer - Western

Manitoba Conservation & Climate

Environmental Compliance and Enforcement

1129 Queens Ave.

Brandon, MB. R7A 1L9

(204) 761-7964

<mailto:Paul.Fagan@gov.mb.ca>

To report an Environmental Emergency please call our

**24/7 Environmental Emergency Response Line (204) 944-4888**

***Toll Free in Manitoba 1-855-944-4888***



## Yazon, Edwin (CC)

---

**From:** Rathamano, Raj (CC)  
**Sent:** June 1, 2020 3:50 PM  
**To:** Yazon, Edwin (CC)  
**Subject:** RE: Request for Review/Comment - DGHTAL 6050.00 - Municipality of Brenda-Waskada  
- Waskada Recycling Centre Hazardous Waste Depot

Good afternoon Edwin,

These are my comments:

- As per the Household hazardous waste registration form submitted, Aerosols (flammable) are going to be collected. The check list for licence application does not include Aerosols. This needs to be clarified.
- Building layout of the Household hazardous waste depot with clearly marked adjacent properties is required.

Thank you.

Raj Rathamano  
Environmental Compliance and Enforcement Branch  
Manitoba Conservation and Climate  
Tel: 204-945-7086

## Yazon, Edwin (CC)

---

**From:** Roberecki, Susan (HSAL)  
**Sent:** May 28, 2020 8:05 PM  
**To:** Yazon, Edwin (CC)  
**Cc:** Ochoo, Benjamin (HSAL)  
**Subject:** RE: Request for Review/Comment - DGHTAL 6050.00 - Municipality of Brenda-Waskada  
- Waskada Recycling Centre Hazardous Waste Depot

Hi Edwin

Here are our comments

From the information provided it is difficult to get an understanding of the community

- Can you provide more information on the actual physical distance from residences and schools? It appears from the map that a school is about 300 M away. The map shows a number of buildings near the facility. Can the purpose of these structures be outlined? Is this an industrial area?
- Can you provide more details about the building where the waste will be held? Will anything be stored outside? What is the anticipated volume of traffic to the facility and how will it be managed? Has the community around the site been consulted?
- The proposal indicates that compressed gas may be stored at the site, which may pose an explosion risk. Can you outline the potential fire /explosion risk with in this facility and your plans for explosion or fire within the facility? Please include a discussion of the proximity of the other buildings nearby and their use.

Thanks

Susan

---

## Yazon, Edwin (CC)

---

**From:** Porteous, Marianne (ARD)  
**Sent:** May 22, 2020 9:08 AM  
**To:** Yazon, Edwin (CC)  
**Subject:** RE: Request for Review/Comment - DGHTAL 6050.00 - Municipality of Brenda-Waskada  
- Waskada Recycling Centre Hazardous Waste Depot

Hello,

No concerns from the Forestry Branch.

Marianne

---

## Yazon, Edwin (CC)

---

**From:** +WPG574 - HRB Archaeology (SCH)  
**Sent:** May 27, 2020 9:19 AM  
**To:** Yazon, Edwin (CC)  
**Subject:** RE: Request for Review/Comment - DGHTAL 6050.00 - Municipality of Brenda-Waskada  
- Waskada Recycling Centre Hazardous Waste Depot

The Archaeological Assessment Services Unit (AASU) has finished its review of the DGHTA license for Waskada for heritage resources.

Further to your request for the above noted DGHTA license, the Historic Resources Branch has examined the location in conjunction with Branch records for areas of potential concern. There are known heritage resource sites in the area around the proposed DGHTA license, but the potential to impact significant heritage resources at the proposed easement is believed to be low and, therefore, the Historic Resources Branch has no concerns with the proposed development at this time.

If at any time, however, heritage resources are encountered in association with these lands during testing and development, the Historic Resources Branch may require that an acceptable heritage resource management strategy be implemented by the developer to mitigate the effects of development on the heritage resources.

If you have any questions or comments, please feel free to contact the Branch as below.

Thanks,

Reid Graham

Impact Assessment Archaeologist  
Historic Resources Branch | Manitoba Sport, Culture and Heritage  
213 Notre Dame Avenue, Main Floor | Winnipeg, MB | R3B 1N3  
[Reid.Graham@gov.mb.ca](mailto:Reid.Graham@gov.mb.ca)  
t. 204.945.2118

## Yazon, Edwin (CC)

---

**From:** Garcia, Norman (OFC)  
**Sent:** May 25, 2020 8:47 AM  
**To:** Yazon, Edwin (CC)  
**Cc:** Morhun, Lisa (OFC)  
**Subject:** RE: Request for Review/Comment - DGHTAL 6050.00 - Municipality of Brenda-Waskada  
- Waskada Recycling Centre Hazardous Waste Depot

Good morning Edwin,

Thank you for the opportunity to review this file and provide comments.

The ITS recommends that the proponent to:

- Comply with the Manitoba Fire Code,
- Submit Fire Safety Plan (as per NFC Section 2.8) to the local fire department, and
- Obtain required permits from the authority having jurisdiction.

Regards,

Norman A. Garcia, P.Eng., LEED AP BD+C

Building and Fire Safety Engineer  
Inspection and Technical Services

Municipal Relations

norman.garcia@gov.mb.ca / 204-794-3840

508-401 York Ave., Winnipeg, MB R3C 0P8

## Yazon, Edwin (CC)

---

**From:** Kiss, Brian (ARD)  
**Sent:** May 25, 2020 1:47 PM  
**To:** Yazon, Edwin (CC)  
**Subject:** RE: Request for Review/Comment - DGHTAL 6050.00 - Municipality of Brenda-Waskada  
- Waskada Recycling Centre Hazardous Waste Depot

No wildlife related concerns.

-Brian Kiss