

DATE: September 19, 2023

TO: Gaylene Mischuk
Park Regional Manager, North,
Parks Branch
Natural Resources and Northern
Development
Gaylene.Mischuk@gov.mb.ca

FROM: Eshetu Beshada, Ph.D., P. Eng.
Environmental Engineer
Industrial and Wastewater Section

**SUBJECT: File 844.40 – Paint Lake Provincial Park – Wastewater Treatment Lagoon
Expansion - Liner Approval.**

Thank you for providing the hydraulic conductivity test result for the Shelby Tube samples collected on August 29, 2023 from the expansion of primary cell at Paint Lake Provincial Park lagoon. The samples tested were collected from the cutoff wall and lagoon floor. The liner meets the requirements of clause 21 of Environment Act Licence No. 1304 R. The new primary cell may be placed into operation in accordance with clause 24 of the licence.

Per clause 25 of the licence, record drawings are due by January 19, 2024. One electronic copy of the record drawings is sufficient, and can be emailed to EABDirector@gov.mb.ca.

Thank you.

Cc: Brett McCormac, JR Cousin Consultants Ltd, bmccormac@jrcc.ca